



**Licensing Notice - Unsolicited Correspondence - 1 for Monaghan
Licence (D0061-01)**

Licence: Monaghan (D0061-01)

Status Reason: Closed

Issued On: 28/08/2013

Action Type: Licensing Notice

Status History Action: Unsolicited Correspondence

1no pumping station has been omitted for question 4. Confirming that the number of Emergency Overflows is 5No including the one at Old Cross Square.

*For inspection purposes only.
Consent of copyright owner required for any other use.*

QUESTION 4 REV A

Local Authority Site Name	Existing (ING)	Northling (ING)	Forward Flow Capacity (ls)	Is there emergency overflow facility (Y/N)	Nr of duty pump units	Power Rating of pumps (kW)	Nr Standby Pumps	Nr Assist Pumps	Forward Flow Capacity (ls)	Construction Date (Year)	Total Head (m)	Nr Standby Pumps	Nr Assist Pumps	Separate Storm water pumps (Y/N)	Pump Type
Sewerage Monaghan - Old Cross Square PS	267407	333535	53 Y	1	26	1	1	0	53	2007	6	1	0	N	Centrifugal
Sewerage Monaghan - Corran PS	267298	331937	11 N	1	2.25	1	1	0	11	1997	3	1	0	N	Centrifugal
Sewerage Monaghan - Ardglass PS	267525	333021	28 N	1	3.6	1	0	0	28	1998	4.5	1	0	N	Centrifugal
Sewerage Monaghan - Old Armagh Road PS	268733	333764	39 Y	1	19	1	1	1	39	1970	6	1	1	Y	Centrifugal
Sewerage Monaghan - Halting Site PS	265457	332258	N	1	2.2	1	0	0	0	2004	6	1	0	N	Centrifugal
Sewerage Monaghan - Emyvale Road (SLI) PS	267881	335404	17 Y	1	11	1	1	1	17	2009	6	1	1	N	Centrifugal
Sewerage Monaghan - Ballyabany Bridge (SLI) PS	267487	335231	10 Y	1	9	1	0	0	10	2009	6	1	0	N	Centrifugal
Sewerage Monaghan - St Davnets (SLI) PS, Rooskey	268016	334269	34 Y	1	13.5	1	0	0	34	2009	6	1	0	N	Centrifugal

For inspection purposes only.
 Consent of copyright owner required for any other use.