

## Monaghan town Storm overflows and Emergency overflows

No	Location	Type	Operation	Easting	Northing
SW3	Old Cross Square pumping station	Storm overflow & emergency	As storm overflow - very rarely, after very heavy and prolonged rain. As Emergency overflow during power outages of over 1 hour, overflows due to mechanical failure have not occurred (5 pumps in sump)	267405  (267385)	333531  (333570)
<b>SW4</b>	Old peoples Homes at Old Cross Square	Storm overflow	<b>Has been blocked up/closed.</b>	267536	333637
SW5	Dawson street (MH)	Storm overflow Discharge point	Rarely heavy prolonged rain	267123 (267334)	333596 (333544))
SW6	Park Street (MH)	Storm overflow Discharge point	Very rarely, very heavy rain	266996 (267132)	333605 (333404)
SW7	Market Street/Road (MH)	Storm overflow Discharge point	Rarely heavy prolonged rain	267045 (267132)	333500 (333404)
SW8	Cootehill road (MH)	Storm overflow	Rarely heavy prolonged rain	267324	332645
SW9 New	Traffic lights (MH)	Storm overflow	Overflow from high level in manhole operates only to stop overflow onto roadway	267123 (267166 )	333500 (333451)
SW10 New	Emyvale road pumping station	Emergency overflow	Never so far capacity for 18 hours flow.2 pumps duty and standby	267859	335392
SW11 New	ST, Davnets pumping station	Emergency overflow	Never so far, capacity for 18 hours flow.2 pumps duty and standby Never so far 2 pumps in sump duty and standby	268065	334120
SW12 New	Ballyalbanny pumping station	Emergency overflow	Never so far capacity for 18 hours flow.2 pumps duty and standby	267487	335214
SW13 New	Old Armagh road pumping station	Emergency overflow	Never so far capacity for 36 hours flow.2 pumps duty and standby	267525	333021

NB Note\*\* Where overflow point is different from discharge point , the grid reference for the discharge point is shown in brackets below that of the overflow point.