



## Licensing Notice - Unsolicited Correspondence - 1 for Mogeely Licence (D0428-01)

**Licence:** Mogeely (D0428-01)

**Status Reason:** Closed

**Issued On:** 07/11/2013

**Action Type:** Licensing Notice

**Status History Action:** Unsolicited Correspondence

See attached operational reports for previous five months The following table summarises data extracted from the Executive Summary of each report

	Hydraulic loading pe	Biological Loading pe
October 2013	347	220
September 2013	364	234
August 2013	313	122
July 2013	388	232
June 2013	411	296
Average Loadings	367	221

The plant pe loadings are below the Certificate criterion of 500 pe. We factored up these figures to 450 pe to allow for monthly anomalies and future development up to 2019.