

Licensing Reply - Reg 18(3)(b) Reply Received - 4 for Churchtown and Environs Licence (D0444-01)

Licence: Churchtown and Environs (D0444-01)

Status Reason: Closed

Issued On: 20/11/2013

Action Type: Licensing Reply

Status History Action: Reg 18(3)(b) Reply Received

Dear Applicant

I refer to your application for a waste water discharge licence relating to agglomeration named Churchtown and Environs.

Having examined the documentation submitted, I am to advise that the Agency is of the view that the documentation does not comply with Regulation 16 of the Waste Water Discharge (Authorisation) Regulations 2007, as amended.

You are therefore requested, in accordance with Regulation 18(3)(b) of the regulations, to take the steps to supply the information detailed below.

REGULATION 16 COMPLIANCE REQUIREMENTS

For inspection purposes only.
Consent of copyright owner required for any other use.

Question

Carry out a risk screening and technical assessment of the primary discharge to the percolation area at Churchtown WWTP, in accordance with Guidance on the Authorisation of Discharges to Groundwater, published by the Environmental Protection Agency, available at <http://www.epa.ie/pubs/reports/water/ground/dischgw/Guidance%20on%20the%20Authorisation%20of%20Discharges%20to%20Groundwater%20Version%201%20Part1%20of%202.pdf>

Provide a report on the outcome of the risk screening and technical assessment and where relevant the recommendations of the technical assessment in relation to the setting of groundwater compliance points and values. The report should demonstrate compliance with the European Communities Environmental Objectives (Groundwater) Regulations 2010 as amended.

Associated Documents

Response

See attached response in relation to RI001217 for Churchtown (D0444-01).
Regards, Gillian O'Sullivan, Waste Water Liaison, Cork Co. Council.

Associated Documents

- Copy of Site Investigation.pdf
- Figure 8.gif
- Ground Investigation locations.pdf
- Plan view of works.gif
- Typical Section Detail.gif

Please supply the information by 04/10/2013. Please note that all maps/drawings should not exceed A3 in size.

Please direct any queries that you may have in relation to the above to the Inspector Loretta Joyce or to OCLR Admin Team E.

Yours sincerely

Loretta Joyce

Environmental Licensing Programme

Office of Climate, Licensing & Resource Use

Tel: 053-9160600

For inspection purposes only.
Consent of copyright owner required for any other use.