



**Emissions To Atmosphere Report
Monitoring of Stack Emission August 2013**

**The Recycling Village,
Unit 21 Duleek Business Park,
Commons,
Duleek,
Co. Meath,
Ireland.**

*For inspection purposes only.
Consent of copyright owner required for any other use.*

**Licence Number: WFP/MH/11/0005/01
Report Date: 04th September 2013**

**Report Number:
3660-13-01
Version No: 0**

AXIS environmental services
40 Coolraine Heights, Old Cratloe Road, Limerick
Phone: 061 324587 Mobile: 087 6367436
Email: info@axisenv.ie Website: www.axisenv.ie

Report for the Periodic Monitoring of Emissions to Air

Part 1: Executive Summary – Cover Sheet

IPPC Licence No: WFP/MH/11/0005/01

Operator: The Recycling Village

Installation: Unit 21 Duleek Business Park
 Commons,
 Duleek,
 Co Meath

Contact Name: Nikita Coulter

Contact No. 041 686 2366

Contract Technician: Mark Mc Garry

Monitoring Dates: 13th August 2013

Monitoring Organisation: AXIS environmental services

Address: 40 Coolraine Heights,
 Old Cratloe Road,
 Limerick


Date of Report: 04th September 2013

Report Approved By: Mark Mc Garry

MCERTS Reg. No. MM05 573

Function: Environmental Manager

Signed:



For inspection purposes only. Consent of copyright owner required for any other use.

Contents

- 1. Part 1 – Executive Summary**
 - 1.1 Monitoring Objectives**
 - 1.2 Special Monitoring Requirements**
 - 1.3 Summary of Methods**
 - 1.4 Results Main Stack**
 - 1.5 Monitoring Deviations**
- 2. Part 2 – Supporting Information**
 - Appendix I: General Information**
 - Appendix II: Raw Data**
 - Appendix III: Uncertainty of Measurement**
 - Appendix IV: Certificates of Analysis**

*For inspection purposes only.
Consent of copyright owner required for any other use.*

1 Part 1: Executive Summary

1.1 Monitoring Objectives

The Recycling Village is required to carry out air emissions monitoring for the purpose of a waste licence application. All monitoring procedures were carried out to standard methods as listed and AG2 requirements. A summary of compliance standings has been listed below:

Emission Point	Process Name	Parameters	Licence Limits	Units	Reference Conditions	Emission Summary
Main Stack	Recycling Process	Particulates	-	mg/Nm ³	STP	There are no licence limits as yet.
		Metals	-	mg/Nm ³		
		Mercury	-	mg/Nm ³		
Notes:						

1.2 Special Monitoring Requirements

None

1.3 Summary of Methods

Substance	Standard Method	AG2 Compliant	Axis Env. SOP	Limit of Detection	Calculation Spreadsheet
Flow Rates	EN 13284-1	Yes	2000	<0.8 m/s	-
Particulates	EN 13284-1	Yes	2002	<0.19 mg/m ³	5001
Metals	EN 14385	Yes	2012	<0.1 ug/m ³	5017
Mercury	EN 13211	Yes	2016	<0.1 ug/m ³	5017
Note: Limits of Detection will change between monitoring periods depending on stack conditions and volumes of air sampled.					

1.4 Monitoring Results

This table presents atmospheric emissions from analysis undertaken on behalf of The Recycling Village.

Emission Point Reference: Main Stack										
Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units Reference Conditions 273 K, 101.3 kPa	Uncertainty Of Measurement +/-	Stack Flow Rate Nm ³ /Hr	Limit Nm ³ /Hr	Date of Sampling	Sampling Start/End Times	Method Reference	Operating Status
Particulates	None	1.92	mg/Nm ³	0.39	8,335		13-08-2013	09:42 – 10:12	EN 13284-1	As Normal
Arsenic		<0.002	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Cadmium		<0.003	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Chromium		<0.036	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Cobalt		<0.001	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Copper		0.234	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Lead		0.184	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Manganese		0.009	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Antimony		<0.003	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Nickel		0.018	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Thallium		<0.001	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Vanadium		<0.001	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Phosphorous		<0.002	mg/Nm ³	8.35%				11:21 – 12:00	EN 14385	
Mercury		<0.001	mg/Nm ³	8.35%				11:21 – 12:00	EN 13211	
Total Metals		0.4943	mg/Nm ³							

From inspection purposes only. Consent of copyright owner required for any other use.

1.6 Monitoring Deviations

Emission Point Reference	Substance Deviations	Monitoring Deviations	Other Relevant Information
Main Stack	All substances as outlined in the quote were tested.	All standard were followed – minimal sample lines were utilized	-

For inspection purposes only.
 Consent of copyright owner required for any other use.

Report for the Periodic Monitoring of Emissions to Air

Part 2: Supporting Information

IPPC Number: None
Operator: The Recycling Village
Installation: Duleek, Co Meath.
Monitoring Dates: 13th August 2013

Organisation and Monitoring Team Details

AXIS environmental services,
40 Coolraine Heights,
Old Cratloe Road,
Limerick.

Email: info@axisenv.ie
Phone: 061 324587
Fax: 061 324587
Mobile: 087 6367436


Date of Report: 04th September 2013

Report Approved By: Mark Mc Garry

MCERTS Reg. No: MM05.573

Function: Environmental Manager

Signed:


.....

For inspection purposes only.
Consent of copyright owner required for any other use.

Appendix I

Sampling Personnel

Team Leader	David Noonan
--------------------	--------------

Equipment Checklist References

Equipment	Reference Number
TCR Tecora	AX002A
Impinger System	AX003
Sampling Nozzles	AX005
Portable Balance	AX027

For inspection purposes only.
 Consent of copyright owner required for any other use.

Appendix II – Raw Data

POINT LIST																							
start ts	Port	Point	Distance	Elapsed Time	rw avg	t _{amb} avg	t _{amb} min	t _{amb} max	t _{probe} avg	t _{box} avg	t _{aux1} avg	t _{aux2} avg	t _{pitot} avg	P _s avg	dP pitot avg	P _{amb} avg	P _{static} avg	P _{diff} avg	v _a avg	v _a min	v _a max	qV _a avg	
[time:stamp]	[##]	[##]	[m]	[hh:mm:ss]	[m/s]	[°C]	[°C]	[°C]	[°C]	[°C]	[°C]	[°C]	[°C]	[kPa]	[Pa]	[kPa]	[kPa]	[kPa]	[m/s]	[m/s]	[m/s]	[m³/s]	
13/08/2013 09:45:29	1	1	7.7	00:05:38	0	17.431	17.328	17.509	12.556	12.813	15.234	14.562	16.553	101.549	32.023	94.571	101.554	6.019	4.496	7.883	16.865		
13/08/2013 09:51:15	1	2	23.1	00:05:38	0	17.528	17.424	17.801	13.404	13.906	15.386	14.933	16.984	101.557	20.287	95.047	101.554	4.034	0	7.63	11.51		
13/08/2013 10:13:44	1	3	38.5	00:05:39	0	17.513	17.463	17.568	13.868	15.105	15.82	15.492	17.403	101.572	32.734	94.363	101.554	6.093	4.511	7.562	17.265		
13/08/2013 10:19:27	1	4	53.9	00:05:38	0	17.568	17.512	17.642	14.052	15.15	15.782	15.609	17.627	101.576	33.362	94.323	101.554	6.152	4.177	7.744	17.423		
13/08/2013 10:25:18	2	1	7.7	00:05:39	0	17.647	17.543	17.707	14.714	15.434	15.972	15.579	17.832	101.569	51.256	91.568	101.554	7.626	5.28	9.497	21.376		
13/08/2013 10:31:01	2	2	23.1	00:05:38	0	17.8	17.693	17.914	15.113	16.004	16.573	16.609	18.063	101.577	51.457	91.482	101.554	7.656	4.239	9.066	21.63		
13/08/2013 10:36:48	2	3	38.5	00:05:38	0	17.928	17.815	18.029	14.713	15.926	16.213	15.806	18.302	101.587	51.676	91.495	101.554	7.668	5.738	9.834	21.544		
13/08/2013 10:42:32	2	4	53.9	00:05:38	0	18.04	17.961	18.09	15.246	16.252	16.498	16.381	18.519	101.593	50.979	91.707	101.554	7.623	5.974	9.177	21.301		
NORMALIZATION FACTOR																							
T _{norm}		[K]	273																				
P _{norm}		[kPa]	101.3																				
PITOT DATA SPECIFICATION																							
Name			p0.83																				
Velocity	[m/s]	2.51	0.834																				
Velocity	[m/s]	5.04	0.832																				
Velocity	[m/s]	10.01	0.832																				
Velocity	[m/s]	20.25	0.831																				
Velocity	[m/s]	37.53	0.823																				
DUCT AND GAS SPECIFICATION																							
Name			VILLAGE																				
Section			Rectangular																				
Size	[m]x[m]	0.615																					
Area	[m²]	0.372																					
Port	[#]	2																					
Points	[#]	4																					
Density	[kg/m³]	1.286	[1.286; 1.286]																				
Carbon dioxide	CO ₂ [%]	0	[0.000; 0.000]																				
Oxygen	O ₂ [%]	20.9	[20.900; 20.900]																				
Water vapor ratio	rw	[0;1]	0 [0.000; 0.000]																				
Nozzle	nz	[mm]	8																				
Turbulence factor	ft	[sec]	1																				
DUCT FLOW RATE																							
Dry actual	QV _a [m³/s]	8851	[0; 13171]																				
Moist actual	QV _a [m³/s]	8851	[9403; 10271]																				
Moist standard [T _{norm} , P _{norm}]	QV _a [m³/s]	8335	[9090; 9645]																				
Dry standard [T _{norm} , P _{norm}]	QV _a [m³/s]	8335	[9090; 9645]																				
AVERAGE VALUES																							
Total Points	[#]	8																					
Velocity	v _a [m/s]	6.608	[0.000; 9.834]																				
Stack temperature	t _s [°C]	17.681	[17.326; 18.090]																				
Stack Static Pressure	P _{s static} [kPa]	101.572	[101.532; 101.613]																				
Isokinetic Deviation	DI [%]	-0.8																					
Velocity at nozzle	v _n [m/s]	6.553	[0.000; 8.483]																				
Probe temperature	t _{probe} [°C]	14.208	[9.616; 19.983]																				
Box temperature	t _{box} [°C]	15.073	[10.229; 19.842]																				
Aux1 temperature	t _{aux1} [°C]	15.934	[12.482; 19.800]																				
Aux2 temperature	t _{aux2} [°C]	15.621	[12.419; 19.620]																				
Stack Differential Pitot Pressure	dP _{pitot} [Pa]	39.566	[0.000; 44.118]																				
Ambient Pressure	P _{amb} [kPa]	101.554	[101.554; 101.554]																				
SAMPLED VOLUMES																							
Elapsed time	et	[s]	00:45:06																				
Total encoder impulses		[#]	19261																				
Standard Volume [T _{norm} , P _{norm}]	V _{sp} [m³]	0.828																					
Volume at dgm conditions	V _{dgm} [m³]	0.9631																					
Gas meter temperature	t _{gm} [°C]	17.757	[16.423; 18.621]																				
Gas Meter Pressure	P _{gm} [kPa]	92.791	[89.855; 100.695]																				

For inspection purposes only.
 Consent of copyright owner required for any other use.

start ts (timestamp)	Port (#)	Point (#)	Distance (cm)	Elapsed Time (hh:mm:ss)	rw avg (0-1)	t _{total} avg [°C]	t _{total} min [°C]	t _{total} max [°C]	t _{total} avg [°C]	t _{total} avg [°C]	t _{total} avg [°C]	t _{total} avg [°C]	P ₁ avg (kPa)	DP pitot avg (Pa)	P _{static} avg (kPa)	P _{static} avg (kPa)	V ₁ avg (m/s)	V ₁ min (m/s)	V ₁ max (m/s)	qV ₁ avg (m³/s)	DI (%)	V ₂ avg (m³/s)	pn avg (kg/s)	
13/08/2013 11:21:46	1	1	7.7	00:05:38	0	18.12	18.03	18.194	15.61	16.583	17.121	16.98	18.94	101.605	34.453	94.7	101.604	6.256	4.653	8.65	17.537	-1.1	6.181	1.286
13/08/2013 11:27:14	1	2	23.1	00:05:38	0	18.232	18.143	18.299	16.004	16.846	16.946	17.04	18.974	101.602	33.099	94.85	101.604	6.135	4.688	7.765	17.296	-0.5	6.099	1.286
13/08/2013 11:33:14	1	3	38.5	00:05:38	0	18.307	18.26	18.366	16.036	16.816	16.898	17.07	19.059	101.61	32.757	94.824	101.604	6.105	4.146	7.636	17.345	0	6.117	1.286
13/08/2013 11:39:30	1	4	53.9	00:05:38	0	18.375	18.284	18.44	15.609	16.57	16.743	16.999	19.149	101.603	57.758	91.212	101.604	8.113	6.364	9.81	22.987	0	8.11	1.286
13/08/2013 11:45:14	2	1	7.7	00:05:38	0	18.481	18.413	18.578	15.972	16.842	17.296	17.045	19.272	101.599	54.239	91.847	101.604	7.866	5.868	9.366	22.096	-0.8	7.798	1.286
13/08/2013 11:50:58	2	2	23.1	00:05:38	0	18.564	18.51	18.604	16.441	17.066	17.205	16.854	19.399	101.598	55.189	91.686	101.604	7.939	6.099	9.747	22.404	-0.3	7.91	1.286
13/08/2013 11:56:42	2	3	38.5	00:05:38	0	18.56	18.505	18.614	16.342	17.699	17.641	17.208	19.528	101.604	53.396	92.004	101.604	7.812	5.861	9.54	21.925	-0.9	7.74	1.286
13/08/2013 12:02:27	2	4	53.9	00:05:38	0	18.566	18.503	18.647	16.777	17.652	17.703	17.432	19.637	101.606	53.571	91.949	101.604	7.825	6.18	9.603	22.018	-0.6	7.773	1.286
NORMALIZATION FACTOR																								
T _{amb}	[K]	273																						
P _{amb}	(kPa)	101.3																						
PILOT DATA SPECIFICATION																								
Name	p0.83																							
Velocity	(m/s)	2.51																						
Velocity	(m/s)	5.04																						
Velocity	(m/s)	10.08																						
Velocity	(m/s)	20.25																						
Velocity	(m/s)	37.53																						
DUCT AND GAS SPECIFICATION																								
Name	RECYCLING																							
Section	Rectangular																							
Size	(m)(m)	0.605 x																						
Area	(m²)	0.172																						
Port	(#)	2																						
Points	(#)	4																						
Density	(kg/m³)	1.286 (1.286; 1.286)																						
Carbon dioxide	(%)	0 (0.00; 0.000)																						
Oxygen	(%)	20.9 (20.900; 20.900)																						
Water vapor ratio	(%)	0 (0.000; 0.000)																						
Nozzle	(mm)	8																						
Turbulence factor	(ft)	1																						
DUCT FLOW RATE																								
Dry actual	(m³/s)	9718 (5551; 13139)																						
Moist actual	(m³/s)	9719 (5177; 10067)																						
Moist standard (T _{amb} , P _{amb})	(m³/s)	9132 (7687; 10212)																						
Dry standard (T _{amb} , P _{amb})	(m³/s)	9132 (7687; 10212)																						
AVERAGE VALUES																								
Total Points	(#)	8																						
Velocity	(m/s)	7.256 (4.146; 9.810)																						
Stack temperature	(°C)	18.4 (18.03; 18.64)																						
Stack Static Pressure	(kPa)	101.603 (101.578; 101.626)																						
Isokinetic Deviation	(%)	-0.5																						
Velocity at nozzle	(m/s)	7.216 (0.000; 10.054)																						
Probe temperature	(°C)	16.123 (13.293; 19.620)																						
Box temperature	(°C)	17.009 (13.128; 21.502)																						
Aux1 temperature	(°C)	17.194 (13.312; 21.123)																						
Aux2 temperature	(°C)	17.028 (14.413; 20.090)																						
Stack Differential Pitot Pressure	(Pa)	46.182 (14.935; 81.612)																						
Ambient Pressure	(kPa)	101.604 (101.604; 101.604)																						
SAMPLED VOLUMES																								
Elapsed time	(hh:mm:ss)	00:45:04																						
Total encoder impulses	(#)	21401																						
Standard Volume (T _{amb} , P _{amb})	(m³)	0.9144																						
Volume at idgn conditions	(m³)	1.0701																						
Gas meter temperature	(°C)	19.269 (18.899; 19.691)																						
Gas Meter Pressure	(kPa)	92.684 (87.594; 100.677)																						
SIDE STREAM																								
Elapsed time	(hh:mm:ss)	00:00:00																						
Flowrate	(m³/s)	0 (0.000; 0.000)																						
Volume	(m³)	0																						

For inspection purposes only.
 Consent of copyright owner required for any other use.

Title: <u>Determination of Total Particulates</u>			
Method:	EN 13284-1		
Client:	Recycling Village		
Log Sheet Complete by:	Mark McGarry	Uncertainty Data	
Test Date:	13/08/2013		
Laboratory Used:	RFS	Temperature at Pump	17.757 Deg C
Stack Name	Main Stack	Pressure at Pump	92.791 kPa
Test Time	09:42	Air Volume at Pump	0.9631 m ³
Moisture Content	0.82 %	Humidity at Pumps	0 %
Stack Flow Rate	8335 Nm ³ /hr	Filter Weight	0.8 mg
Volume of Air Sampled	0.828 Nm ³	Front End Weight	0.8 mg
Balance Calibration	Weight		
300.0	g		
500.0	g		
Inpinger Weights	Initial	Final	Difference
1	484.5	483.1	-1.4
2	466.1	465.8	-0.3
3	381	381.2	0.2
4	633.8	640.8	7
Volume of Air Sampled	0.828	Nm ³	5.5
Moisture Content (EN 14790)	0.82	%	
Leak Check Results	Result		% Leak
Before Blank	100	cc/min	0.4
After Blank	100	cc/min	0.4
Before Sample 1	100	cc/min	0.4
After Sample 1	100	cc/min	0.4
Average Flow Rate	25000	cc/min	0.4
Standard Maximum	500	cc/min	2%
Back Pressure	-0.5	bar	
Standard Criteria to be Met	Result	Standard Requirement	
Angle of Flow	<15 Degrees	<15 Degrees	
Negative Flow in the Stack	None	None	
Pitot Pressure Difference	>5Pa	>5Pa	
Ratio of Flow Measurement	<3:1	<3:1	
Pitot Tube Leak Check	Result		
Positive Pressure	Pass	-	
Negative Pressure	Pass	-	
Number of Ports	2	2	
Straight length before sample point	<5	> 5 Hydraulic Diameters	
Straight length after sample point	>5	> 5 Hydraulic Diameters from fan or bend / >2 from stack exit	
Sample Calculations			
Blank (Filter and Front Wash Combined)	0	mg	
Sample 1 (Filter and Front Combined)	1.6	mg	
Volume of Air Sampled	0.8348444	Nm ³	
Blank Result	0.00	mg/Nm ³	
Sample Result	1.92	mg/Nm ³	
Emission Limit Value	50	mg/Nm ³	
Blank as Percentage of ELV	0.0	%	Standard Requirement <10% ELV

Appendix III Uncertainty Calculations

Uncertainty calculation for EN 13284 Determination of low range mass concentration of dust, Manual Gravimetric Method									
Stack Name: Main Stack									
Limit value (ELV)	50	mg.m ⁻³		Reference oxygen		% by volume		Measurement Equation	
Measured concentration	1.92	mg.m ⁻³ (at reference conditions)						$c = \frac{m}{V} \cdot f_c$	
Measured Quantities	Symbol	Value	Standard uncertainty	Units	Uncertainty as percentage	Uncertainty at lv	Requirement of std		
Sampled Volume	V _s	0.9631	0.001	m ³		0.10	<=2%		
Sampled gas Temperature	T _s	290.757		uT m	2	0.69	<=1%		
Sampled gas Pressure	p _s	92.791		uP _s	1	1.08	<=1%		
Sampled gas Humidity	H _s	0		uH _s	1	1.00	<=1%		
Oxygen content	O _{2,m}			uO _{2,m}	0.3		<=5%		
Mass particulate	m	1.0		um	0.10		<=5%		
Note - Sampled gas humidity, temperature and pressure are values at the gas meter									
Leak	L	0.40				0.40	<=2%		
Uncollected Mass (Instack filter - no rinse)	UCM	0				0	<=10%		
Intermediate calculations									
Factor for std cond	f _s	0.86							
uncertainty components	symbol	sensitivity coeff		u (in units of fs)					
	p _s	0.009		0.009					
	H _s	0.009		0.009					
	T _s	0.003		0.006					
	ufs			0.014					
Corrected volume	V	0.83		uV	0.013	m ³			
Factor for O2 correction	f _c	1.00							
uncertainty components	symbol	sensitivity coeff		u					
	O _{2,m}	0.05		0.005					
Factor for O2 Correction	ufc	1.00		0.005					
							0.48		
Parameter	Value	Units	Sensitivity coeff	Uncertainty contribution	Uncertainty as %				
Corrected Volume (standard conditio	V	0.83	m ³	2.31	0.03	mg.m ³	1.63		
Mass	m	1.0	mg	1.20	0.19	mg.m ³	9.90		
Factor for O2 Correction	f _c	1.00		1.92	0.01	mg.m ³	0.48		
Leak	L	0.00	mg.m ³	1.00	0.00	mg.m ³	0.23		
Uncollected mass	UCM	0.00	mg	1.20	0.00	mg.m ³	0.00		
Combined measurement uncertainty							0.19		
Expanded uncertainty as percentage of measured value			20.10	% measured of value				expressed with a level of confidence of 95% (Using a coverage factor k=2)	
Expanded uncertainty in units of measurement			0.39	mg.m ⁻³					
Expanded uncertainty as percentage of limit value			0.77	% ELV					

For inspection purposes only.
 Consent of copyright owner required for any other use.