

ARP 4/5

<b>Table of BOD &amp; Suspended Solids of Final Effluent for April 2014</b>		
Date	BOD (mg/l)	Suspended Solids (mg/l)
Limit	25	35
01-Apr-14		
02-Apr-14		
03-Apr-14	4	
04-Apr-14		
05-Apr-14		
06-Apr-14		
07-Apr-14		1
08-Apr-14		
09-Apr-14		
10-Apr-14	4	
11-Apr-14		
12-Apr-14		
13-Apr-14		
14-Apr-14		8
15-Apr-14		
16-Apr-14	6	
17-Apr-14		
18-Apr-14		
19-Apr-14		
20-Apr-14		
21-Apr-14		
22-Apr-14		0
23-Apr-14	6	
24-Apr-14		
25-Apr-14		
26-Apr-14		
27-Apr-14		
28-Apr-14		4
29-Apr-14		
30-Apr-14	6	

*For inspection purposes only  
Consent of copyright owner required for any other use.*

ARP 4/7

Table of Total Nitrogen & COD of Final Effluent for April 2014		
Date	Total Nitrogen (mg/l N)	COD (mg/l )
Limit	15	125
01-Apr-14		12
02-Apr-14		10
03-Apr-14		11
04-Apr-14		19
05-Apr-14		22
06-Apr-14		23
07-Apr-14	7.5	25
08-Apr-14		31
09-Apr-14		12
10-Apr-14		14
11-Apr-14		14
12-Apr-14		29
13-Apr-14		18
14-Apr-14	7.4	27
15-Apr-14		26
16-Apr-14		16
17-Apr-14		27
18-Apr-14		9
19-Apr-14		16
20-Apr-14		2
21-Apr-14		6
22-Apr-14	7.6	19
23-Apr-14		24
24-Apr-14		24
25-Apr-14		25
26-Apr-14		25
27-Apr-14		17
28-Apr-14	8.1	37
29-Apr-14		21
30-Apr-14		35

For inspection purposes only.  
Consent of copyright owner required for any other use.