

ARP 4/5

Table of BOD & Suspended Solids of Final Effluent for February 2014		
Date	BOD (mg/l)	Suspended Solids (mg/l)
Limit	25	35
01-Feb-14		
02-Feb-14		
03-Feb-14		2
04-Feb-14		
05-Feb-14		
06-Feb-14	2	
07-Feb-14		
08-Feb-14		
09-Feb-14		
10-Feb-14		3
11-Feb-14		
12-Feb-14		
13-Feb-14	<2	
14-Feb-14		
15-Feb-14		
16-Feb-14		
17-Feb-14		2
18-Feb-14		
19-Feb-14		
20-Feb-14	4	
21-Feb-14		
22-Feb-14		
23-Feb-14		
24-Feb-14		2
25-Feb-14		
26-Feb-14		
27-Feb-14	7	
28-Feb-14		

For inspection purposes only
Consent of copyright owner required for any other use.

ARP 4/7

Table of Total Nitrogen & COD of Final Effluent for February 2014

Date	Total Nitrogen (mg/l N)	COD (mg/l)
Limit	15	125
01-Feb-14		12
02-Feb-14		13
03-Feb-14	3.6	14
04-Feb-14		13
05-Feb-14		4
06-Feb-14		11
07-Feb-14		6
08-Feb-14		6
09-Feb-14		8
10-Feb-14	2.1	8
11-Feb-14		3
12-Feb-14		2
13-Feb-14		1
14-Feb-14		3
15-Feb-14		10
16-Feb-14		4
17-Feb-14	5	1
18-Feb-14		9
19-Feb-14		7
20-Feb-14		18
21-Feb-14		2
22-Feb-14		10
23-Feb-14		6
24-Feb-14	8.8	16
25-Feb-14		12
26-Feb-14		13
27-Feb-14		17
28-Feb-14		4

For inspection purposes only.
Consent of copyright owner required for any other use.