

ARP 4/5

Table of BOD & Suspended Solids of Final Effluent for January 2014		
Date	BOD (mg/l)	Suspended Solids (mg/l)
Limit	25	35
01-Jan-14		
02-Jan-14	2	
03-Jan-14		
04-Jan-14		
05-Jan-14		
06-Jan-14		2
07-Jan-14		
08-Jan-14		
09-Jan-14	2	
10-Jan-14		
11-Jan-14		
12-Jan-14		
13-Jan-14		1
14-Jan-14		
15-Jan-14		
16-Jan-14	2	
17-Jan-14		
18-Jan-14		
19-Jan-14		5
20-Jan-14		
21-Jan-14		
22-Jan-14		
23-Jan-14	2	
24-Jan-14		
25-Jan-14		
26-Jan-14		
27-Jan-14		2
28-Jan-14		
29-Jan-14		
30-Jan-14	2	
31-Jan-14		

*For inspection purposes only
Consent of copyright owner required for any other use.*

ARP 4/7

Table of Total Nitrogen & COD of Final Effluent for January 2014		
Date	Total Nitrogen (mg/l N)	COD (mg/l)
Limit	15	125
01-Jan-14		8
02-Jan-14		9
03-Jan-14		18
04-Jan-14		25
05-Jan-14		19
06-Jan-14	6.1	7
07-Jan-14		16
08-Jan-14		12
09-Jan-14		13
10-Jan-14		7
11-Jan-14		9
12-Jan-14		10
13-Jan-14	3.2	7
14-Jan-14		13
15-Jan-14		15
16-Jan-14		15
17-Jan-14		38
18-Jan-14		17
19-Jan-14	7.6	16
20-Jan-14		17
21-Jan-14		12
22-Jan-14		14
23-Jan-14		14
24-Jan-14		17
25-Jan-14		13
26-Jan-14		10
27-Jan-14	2.3	14
28-Jan-14		5
29-Jan-14		9
30-Jan-14		6
31-Jan-14		15

For inspection purposes only.
Consent of copyright owner required for any other use.