

ARP 4/5

Table of BOD & Suspended Solids of Final Effluent for March 2014		
Date	BOD (mg/l)	Suspended Solids (mg/l)
Limit	25	35
01-Mar-14		
02-Mar-14		
03-Mar-14		2
04-Mar-14		
05-Mar-14		
06-Mar-14	<2	
07-Mar-14		
08-Mar-14		
09-Mar-14		
10-Mar-14		2
11-Mar-14		
12-Mar-14		
13-Mar-14	6	
14-Mar-14		
15-Mar-14		
16-Mar-14		
17-Mar-14		
18-Mar-14		10
19-Mar-14		
20-Mar-14	5	
21-Mar-14		
22-Mar-14		
23-Mar-14		
24-Mar-14		6
25-Mar-14		
26-Mar-14		
27-Mar-14	5	
28-Mar-14		
29-Mar-14		
30-Mar-14		
31-Mar-14		1

For inspection purposes only
Consent of copyright owner required for any other use.

ARP 4/7

Table of Total Nitrogen & COD of Final Effluent for March 2014		
Date	Total Nitrogen (mg/l N)	COD (mg/l)
Limit	15	125
01-Mar-14		9
02-Mar-14		11
03-Mar-14	3.9	10
04-Mar-14		8
05-Mar-14		8
06-Mar-14		11
07-Mar-14		22
08-Mar-14		14
09-Mar-14		14
10-Mar-14	5.9	12
11-Mar-14		4
12-Mar-14		7
13-Mar-14		13
14-Mar-14		18
15-Mar-14		20
16-Mar-14		19
17-Mar-14		17
18-Mar-14	10.5	33
19-Mar-14		62
20-Mar-14		27
21-Mar-14		20
22-Mar-14		19
23-Mar-14		25
24-Mar-14	6.1	25
25-Mar-14		21
26-Mar-14		13
27-Mar-14		21
28-Mar-14		72
29-Mar-14		66
30-Mar-14		51
31-Mar-14	3.6	14

For inspection purposes only.
Consent of copyright owner required for any other use.