

ARP 4/5

Table of BOD & Suspended Solids of Final Effluent for May 2014		
Date	BOD (mg/l)	Suspended Solids (mg/l)
Limit	25	35
01-May-14		
02-May-14		
03-May-14		
04-May-14		
05-May-14		
06-May-14		3
07-May-14		
08-May-14	18	
09-May-14		
10-May-14		
11-May-14		
12-May-14		3
13-May-14		
14-May-14		
15-May-14	5	
16-May-14		
17-May-14		
18-May-14		
19-May-14		6
20-May-14		
21-May-14		
22-May-14	2	
23-May-14		
24-May-14		
25-May-14		
26-May-14		16
27-May-14		
28-May-14		
29-May-14	2	
30-May-14		
31-May-14		

For inspection purposes only
Consent of copyright owner required for any other use.

ARP 4/7

Table of Total Nitrogen & COD of Final Effluent for May 2014		
Date	Total Nitrogen (mg/l N)	COD (mg/l)
Limit	15	125
01-May-14		22
02-May-14		23
03-May-14		25
04-May-14		20
05-May-14		26
06-May-14	6.3	31
07-May-14		80
08-May-14		32
09-May-14		21
10-May-14		22
11-May-14		22
12-May-14	2.1	22
13-May-14		16
14-May-14		17
15-May-14		18
16-May-14		8
17-May-14		19
18-May-14		32
19-May-14	7.6	19
20-May-14		18
21-May-14		10
22-May-14		16
23-May-14		8
24-May-14		6
25-May-14		5
26-May-14	7	12
27-May-14		16
28-May-14		10
29-May-14		19
30-May-14		22
31-May-14		20

For inspection purposes only.
Consent of copyright owner required for any other use.