



Headquarters
P.O. Box 3000
Johnstown Castle Estate
County Wexford
Ireland

**WASTE WATER DISCHARGE LICENCE
TECHNICAL AMENDMENT B**

Licence Register Number:	D0054-01
Licensee:	Irish Water
Agglomeration:	Cobh

Reasons for the Decision

The purpose of this Technical Amendment is to update the Glossary of Terms, Conditions and Schedules of the licence, as appropriate.

The Environmental Protection Agency (the Agency) is satisfied, on the basis of the information available, that subject to compliance with the conditions of licence Reg. No. D0054-01 granted on the 20/07/2010 (and amended on 27/09/2010), as well as any amendments noted herein any discharge from the activity will comply with and not contravene any of the requirements of Regulation 6(3) of the *Waste Water Discharge (Authorisation) Regulations, 2007*, as amended.

A screening for Appropriate Assessment was undertaken to assess, in view of best scientific knowledge and the conservation objectives of the site, if the activity, individually or in combination with other plans or projects is likely to have a significant effect on a European Site(s). In this context, for the reasons set out below, the activity is not directly connected with or necessary to the management of the site as a European Site and it can be excluded on the basis of objective scientific information, that the activity, individually or in combination with other plans or projects, will have a significant effect on a European site, and accordingly the Agency determined that an Appropriate Assessment of the activity is not required, for the following reasons; the proposed amendments will not result in a material change to the nature or volume of the discharge(s) from the agglomeration.

Technical Amendment

In pursuance of the powers conferred on it by Regulation 33(1)(c) of the *Waste Water Discharge (Authorisation) Regulations, 2007*, as amended, the Agency amends Licence Reg. No. D0054-01, granted to Irish Water, Colvill House, 24/26 Talbot Street, Dublin 1, by virtue of Section 17(4) of the Water Services (No. 2) Act 2013.

Henceforth, the licence shall be read in conjunction with Amendment A issued on 27/09/2010 and the amendments set out below.

This technical amendment is limited to the following Glossary of Terms, Conditions and Schedules of Licence Reg. No. D0054-01.

Amendments

Glossary of Terms

Amend the Glossary terms as follows:

Maintain	Keep equipment, plant and infrastructure in a fit state, including such regular inspection, servicing, calibration and repair as may be necessary to perform its function.
Sample(s)	Unless the context of this licence indicates to the contrary, the term sample(s) shall include measurements taken by electronic instruments.
SSRS	Small Streams Risk Score.
Standard Method	A relevant CEN, ISO, National, or other internationally recognized test procedure such as detailed in the current edition of "Standard Methods for the Examination of Water and Wastewater" (published jointly by A.P.H.A. / A.W.W.A. / W.E.F.), a documented and validated in-house procedure based on the above sources that will ensure the provision of data of an equivalent scientific quality, or an alternative method as may be agreed with the Agency.

Insert new Glossary terms as follows:

Competent Laboratory	A testing facility meeting the general management and technical requirements of EN ISO/IEC-17025 standard, or other equivalent standards accepted at international level and utilising methods of analysis, including laboratory, field, and on-line methods, which are validated and documented in accordance with the above standard(s) for the specific tests.
Environmental Pollution	Means, in relation to waste water discharges, the direct or indirect introduction, as a result of human activity, of waste water discharges, substances (including any explosive, liquid or gas) or polluting matter (including any poisonous or noxious matter) into waters which may endanger human health or harm the aquatic environment, and in particular— (a) create a risk to waters, sediment, plants or animals, (b) deleteriously interfere with the quality of aquatic ecosystems or terrestrial ecosystems directly depending on aquatic ecosystems including by— (i) rendering those or any other waters poisonous or injurious to fish, shellfish, spawning grounds or the food of any fish, or (ii) impairing the usefulness of the bed and soil of any

	waters as spawning grounds or impairing their capacity to produce the food of fish or shellfish, (c) impair or interfere with amenities and other legitimate uses of the water, or (d) result in the water failing to meet any environmental quality standards prescribed in regulations for the purpose of giving effect to the requirements of any Directive relating to the quality or use of water for the time being in force.
Priority Substances	Those substances or groups of substances, identified by the Commission in accordance with Article 16(2) of the Water Framework Directive and listed in Tables 11 and 12 of Schedule 6 of the European Communities Environmental Objectives (Surface Waters) Regulations, 2009 that have been prioritised for action by the setting of environmental quality standards at Community level.

Conditions of Licence

Delete Condition 1.1.2:

This licence shall be technically amended, as and when considered by the Agency, to ensure compliance with such environmental quality standard as may be prescribed for surface water classification of the receiving water body.

Amend Condition 1.3 as follows:

The discharge(s) to waters from the waste water works shall be restricted to those listed and described in *Schedule A: Discharges*, of this licence and shall be as set out in the licence application or as modified under Condition 1.6 of this licence and subject to the conditions of this licence.

Insert new Condition 3.6:

No discharge from the waste water works is permitted save under and in accordance with this licence.

Amend Condition 4.1 as follows:

- 4.1 The licensee shall carry out such sampling, analyses, measurements, examinations, maintenance and calibrations as set out below and in accordance with Schedule B: Monitoring, of this licence.
- 4.1.1 Analyses shall be undertaken by competent staff in accordance with documented operating procedures. Analysis for compliance purposes, including any sub-contracted analysis, shall be done by a competent laboratory.
 - 4.1.2 Such procedures shall be assessed for their suitability for the test matrix and performance characteristics shall be determined.
 - 4.1.3 Such procedures shall be subject to a programme of Analytical Quality Control, verified by a competent third party using control standards with evaluation of test responses.

Amend Condition 4.2 as follows:

- 4.2 The licensee shall ensure that:
- (i) Sampling and analysis for all parameters listed in the Schedules to this licence, and
 - (ii) Any reference measurement methods to calibrate automated measurement system

shall be carried out by an appropriate Standard Method.

Delete existing Condition 4.7 and replace it with the new Condition 4.7 as set out below:

The licensee shall ensure that a person in charge or a nominated deputy shall be available to meet with authorised person(s) of the Agency at all reasonable times and shall allow access to the waste water works or other premises that the Agency reasonably considers may contain information pertaining to a discharge from those works.

Insert new Condition 4.9:

Where such ambient monitoring results are available from any other statutory body, including the Agency, the licensee may submit those results in fulfillment of the requirements of *Schedule B.4 Ambient Monitoring* of this licence.

Replace Condition 6.1 to Condition 6.4 inclusive with the following new Condition 6.1:

The licensee shall notify the Agency's headquarters in Wexford, or to such other Agency office, as soon as practicable after the occurrence of any incident (as defined in this licence). This notification shall be in such format as specified in Guidance to Licensees/COA holders on the Notification, Management and Communication of Environmental Incidents issued by the Agency and as a minimum shall include the following: the date, time, location, details, nature, cause, extent and ranking of the incident, details on any vulnerable receptors, corrective action taken and plans to prevent a reoccurrence, and the steps taken to minimise any discharges and to carry out any necessary environmental clean-up. The following shall also be notified, as soon as practicable after the occurrence of any incident:

- Department of Agriculture, Food & the Marine in the case of discharges to receiving waters.

Amend Condition 6.7 as follows:

The licensee shall as a minimum keep the following documents at the headquarters of the licensee or such office as may be agreed by the Agency:

- (i) the licence application and all associated documentation;
- (ii) the licence(s) relating to the discharge(s) to waters from the waste water works;
- (iii) the previous year's AER;
- (iv) records of all risk assessments, sampling, analyses, measurements, examinations, calibrations and maintenance carried out in accordance with the requirements of this licence and guidance produced by the Agency;
- (v) relevant correspondence with the Agency;
- (vi) up to date drawings/plans showing the location of key process and environmental infrastructure, including monitoring locations and discharge points;

- (vii) up to date operational procedures for all monitoring and control equipment necessary to give effect to this licence.

This documentation shall be available to the Agency for inspection at all reasonable times and shall be submitted to the Agency, as required, in such a format as may be requested, including electronic submittal of the information or a summary of such information.

Schedules of the licence

Amend Schedule A.1. Primary Waste Water Discharge as follows:

EDEN Code	Licence Code	Discharge Location			Receiving water name	WFD Receiving water	To be Discontinued	
TPEFF0500D0054SW001	SW001	E	178243	N	65558	Cork Harbour	SW 060 0700	01/01/2015

Parameter	Emission Limit Value
	mg/l
cBOD	25
COD	125
Suspended Solids	35

Amend Schedule A.2. Secondary Waste Water Discharges as follows:

EDEN Code	Licence Code	Discharge Location			Receiving water name	
TPEFF0500D0054SW002	SW002	E	177547	N	66546	Cork Harbour
TPEFF0500D0054SW003	SW003	E	178593	N	65910	Cork Harbour
TPEFF0500D0054SW004	SW004	E	178699	N	66007	Cork Harbour
TPEFF0500D0054SW005	SW005	E	179676	N	66313	Cork Harbour
TPEFF0500D0054SW006	SW006	E	179807	N	66372	Cork Harbour
TPEFF0500D0054SW007	SW007	E	180015	N	66415	Cork Harbour
TPEFF0500D0054SW008	SW008	E	180439	N	66515	Cork Harbour
TPEFF0500D0054SW009	SW009	E	180518	N	66526	Cork Harbour
TPEFF0500D0054SW010	SW010	E	180602	N	66520	Cork Harbour
TPEFF0500D0054SW011	SW011	E	180795	N	66547	Cork Harbour
TPEFF0500D0054SW020	SW020	E	180178	N	66468	Cork Harbour

Parameter	Emission Limit Value
	mg/l
cBOD	25
COD	125
Suspended Solids	35

ca

Amend Schedule A.3. Discharges to be discontinued as follows:

EDEN Code	Licence Code	Discharge Location			Receiving water name	To be Discontinued
TPEFF0500D0054SW001	SW001	E	178243	N 65558	Cork Harbour	01/01/2015
TPEFF0500D0054SW002	SW002	E	177547	N 66546	Cork Harbour	01/01/2015
TPEFF0500D0054SW003	SW003	E	178593	N 65910	Cork Harbour	01/01/2015
TPEFF0500D0054SW004	SW004	E	178699	N 66007	Cork Harbour	01/01/2015
TPEFF0500D0054SW005	SW005	E	179676	N 66313	Cork Harbour	01/01/2015
TPEFF0500D0054SW006	SW006	E	179807	N 66372	Cork Harbour	01/01/2015
TPEFF0500D0054SW007	SW007	E	180015	N 66415	Cork Harbour	01/01/2015
TPEFF0500D0054SW008	SW008	E	180439	N 66515	Cork Harbour	01/01/2015
TPEFF0500D0054SW009	SW009	E	180518	N 66526	Cork Harbour	01/01/2015
TPEFF0500D0054SW010	SW010	E	180602	N 66520	Cork Harbour	01/01/2015
TPEFF0500D0054SW011	SW011	E	180795	N 66547	Cork Harbour	01/01/2015
TPEFF0500D0054SW012	SW012	E	178375	N 65605	Cork Harbour	01/01/2015
TPEFF0500D0054SW013	SW013	E	179466	N 66275	Cork Harbour	01/01/2015
TPEFF0500D0054SW014	SW014	E	180068	N 66442	Cork Harbour	01/01/2015
TPEFF0500D0054SW015	SW015	E	180281	N 66502	Cork Harbour	01/01/2015
TPEFF0500D0054SW016	SW016	E	178375	N 65605	Cork Harbour	01/01/2015
TPEFF0500D0054SW017	SW017	E	179466	N 66275	Cork Harbour	01/01/2015
TPEFF0500D0054SW018	SW018	E	180068	N 66442	Cork Harbour	01/01/2015
TPEFF0500D0054SW019	SW019	E	180281	N 66502	Cork Harbour	01/01/2015
TPEFF0500D0054SW020	SW020	E	180178	N 66468	Cork Harbour	01/01/2015

Amend Schedule A.4. Storm Water Overflows as follows:

A.4. Storm Water Overflows <small>Note 1</small>						
EDEN Code	Licence Code	Discharge Location			Receiving water name	To be Discontinued
TPEFF0500D0054SW016	SW016	E	178375	N 65605	Cork Harbour	01/01/2015
TPEFF0500D0054SW017	SW017	E	179466	N 66275	Cork Harbour	01/01/2015
TPEFF0500D0054SW018	SW018	E	180068	N 66442	Cork Harbour	01/01/2015
TPEFF0500D0054SW019	SW019	E	180281	N 66502	Cork Harbour	01/01/2015

Note 1: This discharge shall comply with the definition of a storm water overflow as set out in the DoECLG guidance document *Procedures and Criteria in relation to Storm Water Overflows*, 1995 and any other guidance as may be specified by the Agency.

This technical amendment shall be cited as Amendment B to Waste Water Discharge Licence Register No. D0054-01 dated 20/07/2010 and is to be read in conjunction with that licence and all previous amendments.

Sealed by the seal of the Agency on this the 25th day of June, 2014

**PRESENT when the seal of the Agency
was affixed hereto:**


Dr. Karen Creed, Authorised Person

