

Sonja Smith

Subject: FW: Buttevant WWTP Primary Discharge Coordinates Correction

-----Original Message-----

From: Anna Brosnan

Sent: 23 July 2014 16:20

To: Michelle Reddy

Cc: Ken Conroy; LA_biosullivan; Pat Britton; Donal Brennan; John Fitzgerald

Subject: Buttevant WWTP Primary Discharge Coordinates Correction

Hi Michelle,

Further to the pre-licence inspection at Buttevant WWTP this morning, it has come to my attention that the coordinates of the primary discharge in the waste water discharge licence application appear to be incorrect.

The original outfall pipework prior to the upgrade of the plant is still in place and this runs parallel to the River Awbeg, with the discharge to the river being approximately 220m from the WWTP boundary. It may have been envisaged at the time of the application that there was a possibility of a new (shorter) outfall being constructed during the upgrade but this was not the case it now seems. The correct approximate coordinates of the primary discharge location (to the middle of the river at bed level as discussed today) are as follows:

Easting: 154432

Northing: 108693

Please let me know if you have any queries on this.

Regards

Anna

Anna Brosnan

Wastewater Non-Infrastructure Above Ground SLA Lead - Southern Region

Uisce Éireann

Oifig Luimnigh

Irish Water

Limerick Office

*For inspection purposes only.
Consent of copyright owner required for any other use.*

This email has been scanned by the Symantec Email Security.cloud service.
For more information please visit <http://www.symanteccloud.com>
