

# Annual Environmental Report 2014

<b>Agglomeration Name:</b>	<b>Scotstown Village</b>
<b>Licence Register No.</b>	<b>D0494-01</b>



## Table of Contents

<b>Section 1. Executive Summary and Introduction to the 2014 AER</b>	<b>1</b>
1.1 Summary report on 2014	1
<b>Section 2. Monitoring Reports Summary</b>	<b>2</b>
2.1 Summary report on monthly influent monitoring	2
2.2 Discharges from the agglomeration	3
2.3 Ambient monitoring summary	5
2.4 Data collection and reporting requirements under the Urban Waste Water Treatment Directive	5
2.5 Pollutant Release and Transfer Register (PRTR) - report for previous year	5
<b>Section 3 Operational Reports Summary</b>	<b>6</b>
3.1 Treatment Efficiency Report	6
3.2 Treatment Capacity Report	6
3.3 Extent of Agglomeration Summary Report	6
3.4 Complaints Summary	7
3.5 Reported Incidents Summary	7
3.6 Sludge / Other inputs to the WWTP	8
<b>Section 4. Infrastructural Assessments and Programme of Improvements</b>	<b>9</b>
4.1 Storm water overflow identification and inspection report	9
4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.	9
<b>Section 5. Licence Specific Reports</b>	<b>11</b>
5.1 Priority Substances Assessment	12
5.2 Drinking Water Abstraction Point Risk Assessment.	12
5.3 Shellfish Impact Assessment Report.	12
5.4 Toxicity / Leachate Management	12
5.5 Toxicity of the Final Effluent Report	12
5.6 Pearl Mussel Measures Report	12
5.7 Habitats Impact Assessment Report	12
<b>Section 6. Certification and Sign Off</b>	<b>13</b>
<b>Section 7. Appendix</b>	<b>14</b>

## Section 1. Executive Summary and Introduction to the 2014 AER

### 1.1 Summary report on 2014

This Annual Environmental Report has been prepared for D0494-01, Scotstown Village, in County Monaghan in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified assessments are included as an appendix to the AER as follows:

- Storm water overflow assessment

The agglomeration is served by a wastewater treatment plant with a Design PE of 1,000. The treatment process includes the following:-

- preliminary treatment
- primary treatment
- secondary treatment - RBC
- chemical dosing for phosphorus removal

The final effluent from the Primary Discharge Point was non-compliant with the Emission Limit Value for Ortho-phosphate in 2014.

The following parameters exceeded the emission limit values in 2014:-

- Orthophosphate

144,000 kgs sludge (total weight sludge) were removed from the wastewater treatment plant in 2014 as liquid sludge. Sludge was transferred to Monaghan WWTP.

There were no major capital or operational changes undertaken in 2014.

An Annual Statement of Measures is included in **Appendix 7.1**.

## Section 2. Monitoring Reports Summary

### 2.1 Summary report on monthly influent monitoring

Table 2.1 - Influent Monitoring Summary

	BOD (mg/l)	COD (mg/l)	SS (mg/l)	TP (mg/l)	TN (mg/l)	Hydraulic Loading (m3/d)	Organic Loading (PE/day)
<b>Number of Samples</b>	5	6	6	5	6		
<b>Annual Max.</b>	1360	5130	640	9.5	59	401	1179
<b>Annual Mean</b>	404	1244	270	4	43	90	608

#### Significance of results

The annual mean hydraulic loading is less than the Treatment Plant Capacity as detailed further in Section 3.2.

The annual maximum organic loading is less than the Treatment Plant Capacity as detailed further in Section 3.2. The average BOD loading has doubled since 2013. It is unknown why this has occurred. There are no new industries on the network and no new housing developments.

## 2.2 Discharges from the agglomeration

Table 2.2 - Effluent Monitoring Summary

	pH	cBOD (mg/l)	COD (mg/l)	TSS (mg/l)	SS (mg/l)	Total P (mg/l)	Ortho P (mg/l)	Ammonia (mg/l)	Total N (mg/l)	Comment
<b>WWDL ELV (Schedule A)</b>	6 - 9	20	125	N/A	35	N/A	1	2	N/A	
<b>ELV with Condition 2 Interpretation included</b>	No allowable failures – No deviation allowed	1 allowable failure provided under 100% of ELV (40mg/l)	1 allowable failure provided under 100% of ELV (250mg/l)	N/A	1 allowable failure provided under 150% of ELV (87.5mg/l)	N/A	8 out of 10 consec. samples shall not exceed ELV. No individual result shall exceed ELV > 20% ( OrthoP 1.20mg/l)	8 out of 10 consec. samples shall not exceed ELV. No individual result shall exceed ELV > 20% (Ammonia 2.4mg/l)	N/A	
<b>Number of sample results</b>	7	7	7	N/A	7	N/A	7	7	N/A	
<b>Number of sample results above WWDL ELV</b>	0	0	0	N/A	0	N/A	3	0	N/A	
<b>Number of sample results above ELV with Condition 2 Interpretation included</b>	0	0	0	N/A	0	N/A	2	0	N/A	

<b>Annual Mean (for parameters where a mean ELV applies)</b>	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
<b>Overall Compliance (Pass/Fail)</b>	PASS	PASS	PASS	N/A	PASS	N/A	FAIL	PASS	N/A	

Significance of results

The WWTP was non-compliant with the ELV for Ortho-phosphate set in the wastewater discharge licence. There were 3 samples non-compliant with the ELVs in relation to orthophosphate. As per schedule B3 of the licence, one allowable exceedance is permitted each year. The non-compliance was due to a failure in the pumping system for ferric dosing. The impact on receiving waters is assessed further in Section 2.3.

### 2.3 Ambient monitoring summary

**Table 2.3 - Ambient Monitoring Report Summary**

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Current EQS Status	Does assessment of the ambient monitoring results indicate that the discharge is impacting on water quality?
Upstream monitoring point	261094E 336873N	RS03B010123	Good	n/a
Downstream monitoring point	E261322 N335999	RS03B010130	Good	No

The results for the upstream and downstream monitoring are included as in Appendix 7.2.

#### Significance of results

The WWTP was non-compliant with the ELV for Ortho-phosphate set in the wastewater discharge licence as detailed in Section 2.2.

The discharge from the wastewater treatment plant doesn't have an observable impact on the water quality status.

### 2.4 Data collection and reporting requirements under the Urban Waste Water Treatment Directive

The electronic submission of data was completed on a monthly basis to EPA through MDS (EDEN) in XML format

### 2.5 Pollutant Release and Transfer Register (PRTR) - report for previous year

A PRTR is not required as the agglomerations is less than 2000 p.e.

## Section 3 Operational Reports Summary

### 3.1 Treatment Efficiency Report

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:-

**Table 3.1 - Treatment Efficiency Report Summary**

	cBOD (kg/yr)	COD (kg/yr)	SS (kg/yr)	Total P (kg/yr)	Total N (kg/yr)	Comment
Influent mass loading (kg/year)	13316	41045	8923	128	1431	Ortho-p and Ammonia not measured on <b>influent</b> therefore not possible to calculate removal efficiency of these.
Effluent mass emission (kg/year)	67	599	185	16	883	
% Efficiency (% reduction of influent load)	99	99	98	91	33	

### 3.2 Treatment Capacity Report

**Table 3.2 - Treatment Capacity Report Summary**

Hydraulic Capacity – Design / As Constructed (dry weather flow) (m3/year)	24090
Hydraulic Capacity – Design / As Constructed (peak flow) (m3/year)	82855
Hydraulic Capacity – Current loading (m3/year)	33000
Hydraulic Capacity – Remaining (m3/year)	49855
Organic Capacity - Design / As Constructed (PE)	1000
Organic Capacity - Current loading (PE)	729
Organic Capacity – Remaining (PE)	271
Will the capacity be exceeded in the next three years? (Yes / No)	No

### 3.3 Extent of Agglomeration Summary Report

In this section Irish Water is required to report on the amount of urban waste water generated within the agglomeration. It does not include any waste water collected and treated in a private system and discharged to water under a Section 4 Licence issued under the Water Pollution Acts 1977 (as amended):



**Table 3.3 - Extent of Agglomeration Summary Report**

	<b>% of p.e. load generated in the agglomeration</b>
<b>Load generated in the agglomeration that is collected in the sewer network</b>	100%
<b>Load collected in the agglomeration that enters treatment plant</b>	100%
<b>Load collected in the sewer network but discharged without treatment</b>	0%

**Load generated in the agglomeration that is collected in the sewer network** is the total load generated and collected in the municipal network within the boundary of the agglomeration.

**Load collected in the agglomerations that enters treatment plant** is that portion of the previous figure which enters the waste water treatment plant

**Load collected but discharged without treatment** is that portion of the first figure which is discharged without treatment.

The data in Table 3.3 above is based on influent monitoring as detailed in Section 2.1 above.

### **3.4 Complaints Summary**

There were no complaints of an environmental nature related to the discharge to waters from the Scotstown WWTP in 2014.

### **3.5 Reported Incidents Summary**

A summary of reported incidents is included below.

**Table 3.5.1 - Summary of Incidents**

<b>Incident Type (e.g. Non-compliance, Emission, spillage, Emergency Overflow Activation)</b>	<b>Incident Description</b>	<b>Cause</b>	<b>No. of incidents</b>	<b>Corrective Action</b>	<b>Authorities Contacted Note 1</b>	<b>Reported to EPA (Yes/No)</b>	<b>Closed (Y/N)</b>
Exceedance	ELV OrthoP exceedance	Dosing	2	Pumps	No	Yes	Yes

Note 1: For shellfish waters notify the Marine Institute (MI) Sea Fisheries Protection Authority (SFPA) Food Safety Authority (FSAI) and An Bord Iascaigh Mhara (BIM). This should also include any other authorities that should be contacted arising from the findings of any Licence Specific Reports also e.g. Drinking Water Abstraction Impact Risk Assessment, Fresh Water Pearl Mussel Impact Assessments etc.

**Table 3.5.2 - Summary of Overall Incidents**

<b>Number of Incidents in 2014</b>	2
<b>Number of Incidents reported to the EPA via EDEN in 2014</b>	2
<b>Explanation of any discrepancies between the two numbers above</b>	N/A

Irish Water are in continuous communication with Local Authorities reiterating the requirement to report incidents to the EPA as per Waste Water Discharge Licence Requirements. Discussions in relation to this matter are also progressing at senior management level between Irish Water and the Local Authorities. In addition to this Incident Management training will also be provided to Local Authorities in 2015 to address concerns associated with incident classification, reporting requirements and incident notification.

### **3.6 Sludge / Other inputs to the WWTP**

‘Other inputs’ to the waste water treatment plant are summarised in Table 3.6 below.

**Table 3.6 - Other Inputs**

<b>Input type</b>	<b>m3/year</b>	<b>PE/year</b>	<b>% of load to WWTP</b>	<b>Is there a leachate/sludge acceptance procedure for the WWTP? (Y/N)</b>	<b>Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)</b>
Domestic /Septic Tank Sludge	0	0	0	N	N
Industrial / Commercial Sludge	0	0	0	N	N
Landfill Leachate (delivered by tanker)	0	0	0	N	N
Landfill Leachate (delivered by sewer network)	0	0	0	N	N
Other (specify)	0	0	0	N	N

**Notes:**

1. Other Inputs include; septic tank sludge, industrial /commercial sludge, landfill leachate and any other sludge that is collected and added to the treatment plant.
2. Sludge that is added to a dedicated sludge reception facility at a waste water treatment plant not included in Table 3.6. Only include sludge which is added to the waste water treatment process stream. Enter zero where there are no inputs

## Section 4. Infrastructural Assessments and Programme of Improvements

### 4.1 Storm water overflow identification and inspection report

The Storm Water Overflow Identification & Inspection report is included in Appendix 7.3. A summary of the significance and operation is included below.

**Table 4.1.1 - SWO Identification and Inspection Summary Report**

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow (High / Medium / Low)	Compliance with DoEHLG Criteria	No. of times activated in 2014 (No. of events)	Total volume discharged in 2014 (m3)	Total volume discharged in 2014 (P.E.)	Estimated /Measured data
SWO	261135E 336742N	Yes	Low	Compliant	0	Unknown	Unknown	E

**Table 4.1.2 - SWO Identification and Inspection Summary Report**

How much sewage was discharged via SWOs in the agglomeration in the year (m3/yr)?	Unknown
How much sewage was discharged via SWOs in the agglomeration in the year (p.e.)?	Unknown
What % of the total volume of sewage generated in the agglomeration was discharged via SWOs in the agglomeration in 2014?	Unknown
Is each SWO identified as non-compliant with <a href="#">DoEHLG Guidance</a> included in the Programme of Improvements?	N/A
The SWO assessment includes the requirements of Schedule A3 & C3	Appendix 7.3
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

### 4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.

There is no specified improvement works under schedule C of the discharge licence.

The Improvement Programme is included in Appendix 7.4.

The Improvement Programme report included in Appendix 7.4 addresses the **Specified Improvement Programmes** as detailed in Schedules A3 and C of the WWDL. It should details other improvements identified through assessments required under the licence

A summary of the status of any improvements identified by under Condition 5.2 is included below.

**Table 4.2.2 - Improvement Programme Summary**

Improvement Identifier	Improvement Description	Improvement Source	Progress (% completed)	Expected Completion Date	Comments
High inflows into the Scotstown WWTP during storm conditions/ periods of heavy rainfall	CCTV survey of network & remedial measures identified carried out	WWTP assessment (Condition 5.3).	0%	Unknown	The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis.
No record of SWO activating or measurement of flows	Install SWO measurement/recorder device to measure flows/record no. times it activates	Cond. 4.1 of this report	0%	Unknown	The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis.

**Improvements identified above also include measures taken to** prevent environmental damage anticipated following events or accidents/incidents associated with discharges or overflows from the waste water works and as such are considered to fulfil any Statement of Measures requirements. Refer also to Appendix 7.1 which summarises the Annual Statement of Measures.

**Table 4.2.3 - Sewer Integrity Risk Assessment Tool Summary**

The Improvement Programme should include an assessment of the integrity of the existing wastewater works for the following:	Risk Assessment Rating (High, Medium, Low)	Risk Assessment Score	Comment
Hydraulic Risk Assessment Score	medium	Unknown	SIRAT not used in this assessment
Environmental Risk Assessment Score	medium	Unknown	SIRAT not used in this assessment
Structural Risk Assessment Score	medium	Unknown	SIRAT not used in this assessment
Operation & Maintenance Risk Assessment Score	medium	Unknown	SIRAT not used in this assessment
Overall Risk Score for the agglomeration	medium	Unknown	SIRAT not used in this assessment

## Section 5. Licence Specific Reports

**Licence Specific Reports Summary Table**

Licence Specific Report	Required in 2014 AER or outstanding from previous AER	Included in 2014 AER	Reference to relevant section of AER (e.g. Appendix 2 Section4.
Priority Substances Assessment	Yes	Yes	Appendix 7.6
Drinking Water Abstraction Point Risk Assessment	No	No	N/A
Habitats Impact Assessment	No	No	N/A
Shellfish Impact Assessment	No	No	N/A
Pearl Mussel Report	No	No	N/A
Toxicity/Leachate Management	No	No	N/A
Toxicity of Final Effluent Report	No	No	N/A

**Licence Specific Reports Summary of Findings**

Licence Specific Report	Recommendations in Report	Summary of Recommendations in Report
Priority Substances Assessment	No	N/A
Drinking Water Abstraction Point Risk Assessment	N/A	N/A
Habitats Impact Assessment	N/A	N/A
Shellfish Impact Assessment	N/A	N/A
Pearl Mussel Report	N/A	N/A
Toxicity/Leachate Management	N/A	N/A
Toxicity of Final Effluent Report	N/A	N/A

### **.1 Priority Substances Assessment**

The Priority Substances Assessment report is included in Appendix 7.6. A summary of the findings of this report is included below.

**Table 5.1 - Priority Substance Assessment Summary**

	<i>Licensee self- assessment checks to determine whether all relevant information is included in the Assessment.</i>
<b>Does the assessment use the Desk Top Study Method or Screening Analysis to determine if the discharge contains the parameters in Appendix 1 of the EPA guidance</b>	Desk Top Study
<b>Does the assessment include a review of Trade inputs to the works?</b>	Yes
<b>Does the assessment include a review of other inputs to the works?</b>	Yes
<b>Does the report include an assessment of the significance of the results where a listed material is present in the discharge? (e.g. impact on the relevant EQS standard for the receiving water)</b>	Yes
<b>Does the assessment identify that priority substances may be impacting the receiving water?</b>	No
<b>Does the Improvement Programme for the agglomeration include the elimination / reduction of all priority substances identified as having an impact on receiving water quality?</b>	Yes

### **5.2 Drinking Water Abstraction Point Risk Assessment.**

The Drinking Water Abstraction Point Risk Assessment report is not required for Scotstown.

### **5.3 Shellfish Impact Assessment Report.**

The Shellfish Impact Assessment Report is not required for Scotstown.

### **5.4 Toxicity / Leachate Management**

The Toxicity / Leachate Management Assessment report is not required for Scotstown.

### **5.5 Toxicity of the Final Effluent Report**

The Toxicity of the Final Effluent Assessment report is not required for Scotstown.

### **5.6 Pearl Mussel Measures Report**

A sub-basin management plan in relation to Pearl Mussels is not required for Scotstown.

### **5.7 Habitats Impact Assessment Report**

The Habitats Impact Assessment Report is not required for Scotstown.

## Section 6. Certification and Sign Off

Table 6.1 - Summary of AER Contents


Does the AER include an executive summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a technical amendment / review of the licence?	No
List reason e.g. additional SWO identified <i>(insert lines as required)</i>	N/A
Is there a need to request/advise the EPA of any modifications to the existing WWDL? Refer to Condition 1.7 (changes to works/discharges) & Condition 4 (changes to monitoring location, frequency etc.)	No
List reason e.g. failure to complete specified works within dates specified in the licence, changes to monitoring requirements <i>(insert lines as required)</i>	N/A
Have these processes commenced? (i.e. Request for Technical Amendment / Licence Review / Change Request)	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER?	N/A
List outstanding reports <i>(insert lines as required)</i>	Sewer Integrity Risk Assessment

### Declaration by Irish Water

The AER contains the following;

- Introduction and background to 2014 AER
- Monitoring reports summary.
- Operational reports summary.
- Infrastructural Assessment and Programme of Improvements.
- Licence specific reports.
- Certification and Sign Off
- Appendices

I certify that to the best of my knowledge the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: 

Date: 15/04/2015

**Gerry Galvin**  
Chief Technical Advisor

## Section 7. Appendix

Appendix 7.1 - Annual Statement of Measures

Appendix 7.2 - Ambient monitoring summary

Appendix 7.3 - Storm water overflow identification and inspection report

Appendix 7.4 – Specified Improvement Programme

a) Specified Improvement Programme

b) Programme of Improvements

Appendix 7.6 - Priority substances assessment



## Appendix 7.1 - Annual Statement of Measures

Risk /Description of issue	Risk Score	Mitigation Measure to be taken	Outcome	Action	Date for Completion	Owner/ Contact Person
High inflows into the Scotstown WWTP during storm conditions/periods of heavy rainfall		CCTV survey of network & remedial measures identified carried out			The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis.	C McCrossan
No record of SWO activating or measurement or flows.		Install SWO measurement/recorder device to measure flows/record no. times it activates			The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis.	C McCrossan

## Appendix 7.2 - Ambient monitoring summary

Table 2.3		Upstream monitoring results												
Location	Flow M3/day	Location	Date of Sampling	Sample Type (C or G)	Temp	pH	cBOD mg/l	COD mg/l	Suspended Solids mg/l	Ortho Phosphorus (as P) mg/l	Ammonia (as N)	Total Nitrogen mg/l (as N)	Total Phosphorus mg/l (as P)	Dissolved Oxygen (DO)
Scotstown		Up Stream Of Works	25/02/2014	G	9.1	8	1			0.021	0.023			11.21
Scotstown		Up Stream Of Works	15/04/2014	G	10.1	8.4	1			0.025	0.021			9.8
Scotstown		Up Stream Of Works	17/06/2014	G	19.2	8.3	1			0.03	0.061			9.52
Scotstown		Up Stream Of Works	20/08/2014	G	12.3	8.1	1			0.02	0.017			11.11
Scotstown		Up Stream Of Works	22/10/2014	G	10.1	7.6	3			0.009	0.029			10.26
Scotstown		Up Stream Of Works	02/12/2014	G	7.5	8.4	1			0.035	0.046		0.05	9.24
<b>Average</b>					<b>11.38</b>	<b>8.13</b>	<b>1.33</b>			<b>0.023</b>	<b>0.033</b>			<b>10.190</b>

Table 2.4														
Downstream monitoring results														
Location	Flow M3/day	Location	Date of Sampling	Sample Type (C or G)	Temp	pH	cBOD mg/l	COD mg/l	Suspended Solids mg/l	Ortho Phosphorus (as P) mg/l	Ammonia (as N)	Total Nitrogen mg/l (as N)	Total Phosphorus mg/l (as P)	Dissolved Oxygen (DO)
Scotstown		Down Stream of Works	25/02/2014	G	8.9	8	1			0.026	0.029			11.14
Scotstown		Down Stream of Works	15/04/2014	G	10.4	8.5	1			0.016	0.043			9.6
Scotstown		Down Stream of Works	17/06/2014	G	17	8.2	1			0.026	0.065			9
Scotstown		Down Stream of Works	20/08/2014	G	12.6	7.9	1			0.029	0.03			11
Scotstown		Down Stream of Works	22/10/2014	G	9.4	7.6	2			0.016	0.034			10.21
Scotstown		Down Stream of Works	02/12/2014	G	7.5	8.4	1			0.037	0.046		0.06	9.3
<b>Average</b>					<b>10.97</b>	<b>8.10</b>	<b>1.17</b>			<b>0.025</b>	<b>0.041</b>			<b>10.042</b>

## Appendix 7.3 - Storm water overflow identification and inspection report

### Section 4. 'Assessment Criteria for Existing SWO's':

- (1) It does not cause visual/aesthetic impact or public complaints.
- (2) No analyses have been carried out on this SWO as it activates rarely, only in prolonged or severe storm conditions and there is no monitoring device on it. However, it is concluded that there would be minimal deterioration in water quality in the receiving water when it operates, as discharge would be diluted due to storm water inflows coinciding with high river flows, thus maximising the assimilative capacity of the receiving water.
- (3) It does not give rise to failure in meeting the requirements of national Regulations on foot of EU Directives as it is not a bathing water, nor a designated River.
- (4) It does not operate in dry weather.

### Section 5, 'Options following Assessment'

The 'use of storage' option is considered under this document as the SWO is from a storm tank.

### Section 7, 'Use of Storage'

The existing storm tank was not designed or sized for any specific storm return period or duration, as it is a modified primary settlement tank. The storm tank volume equates to approximately 84m<sup>3</sup>, the WWTP average flow figure for 2014 is 132m<sup>3</sup>, with a Dry Weather Flow (DFW) of 76m<sup>3</sup>. The capacity of the storm tank is 1.1 times the DWF of the plant.

### Appendix 1, Table 2:

#### A. 'Low Significance SWOs'

The Scotstown SWO is in the 'Low significance SWO' category.

#### Appendix 2, A. 'Low Significance SWOs'

The volume of the storm tank is assessed using Appendix 2, Table 3 of the DoECLG document as follows:

The dilution factor is the river at 95 percentile river flows relative to the dry weather flow to the plant calculated as follows:

WWTP DWF =	76m <sup>3</sup> /day = 0.000880m <sup>3</sup> /s
Blackwater River 95% flow =	0.09m <sup>3</sup> /s
Dilution Factor =	(0.09/0.000880) = 102

The storm tank volume required based on a dilution factor > 8 is 'None' (ref Table 3, Appendix 2, DoECLG document). As there is a storage tank employed at the WWTP, it is deemed to comply with this part of the document.

From the assessment of this SWO in relation to the 'Procedures and criteria in relation to Storm Water Overflows', 1995 document, it is concluded that the SWO complies with the document as assessed under section 4.1 of this document.

**SWO Identification and Inspection Summary Report Table A:**

<b>WWDL Name/Code for Storm Water Overflow</b>	SWO
<b>IGR</b>	261135E, 336742N
<b>Included in Schedule A4 of the WWDL</b>	Yes
<b>Compliance with DoEHLG Criteria</b>	Complies as assessed in Section 4.1 of this document
<b>No. of times activated in 2014</b>	0
<b>Total volume discharged (m3)</b>	Unknown
<b>Total volume discharged in 2014 (P.E.)</b>	Unknown
<b>Estimated/Measured Data</b>	Estimated

## Appendix 7.4 – Specified Improvement Programme

### a) Specified Improvement Programme

As per condition 5.1 of the licence, a programme of infrastructural improvements to maximise the efficiency and effectiveness of the waste water works shall be prepared and submitted:

The treatment capacity and removal efficiencies of the Scotstown WWTP are addressed in section 2.1 and 3.1 of this report. In the Scotstown discharge licence, under schedule C, there are no specified improvements. There are no planned improvement works for the Scotstown WWTP.

Under condition 5.2 (a) of the licence, the programme of infrastructural improvements shall include an assessment of the waste water treatment plant having regard to the effectiveness of the treatment provided by reference to the following:

(i) The existing level of treatment, capacity of treatment plant and associated equipment:

As addressed in section 2.1 and 3.1 of this report the existing level of treatment at the plant is considered generally adequate based on ELV compliance and removal efficiencies. There is adequate capacity at the treatment plant (ref section 2.1, Table 1.2).

(ii) The emission limit values specified in Schedule A: Discharges, of this licence:

There were three exceedances of ELVs in 2014 with two of them a reportable incident to the EPA with no identified cause and following results under ELV. No improvements are deemed necessary with regard to ELVs.

(iii) The designations of the receiving water body:

The receiving Blackwater River is not a designated Salmonid Water (under the European Communities (Quality of Salmonid Waters) Regulations, 1988) nor is it identified as sensitive water in terms of the Urban Waste Water Treatment Regulations 2001. The river is not designated as an SPA, SAC or NHA. The Blackwater Water River is in the Neagh Bann river basin district with overall status classified as 'Good' but deemed '1a- at risk' with overall objective to protect its status. The 'point risk source' and potential for impact from the Scotstown WWTP discharge on the river is categorised as 'not at risk', and the Blackwater Water Management Unit Action Plan (WMU) does not list the WWTP as impacting on the Blackwater River (Ref. WFD website & reports). Ambient monitoring results were assessed in section 2.3 of this report and it is concluded that there is no significant impact from the discharge of the Scotstown agglomeration on the receiving water quality.

(i) Water quality objective for the receiving water body:

This item is addressed in point no. 4.2 (iii) above.

(ii) The standards and volumetric limitations applied to any industrial waste water that is licensed to discharge to the waste water works:

There are no industries licensed to discharge to the waste water works.

Under condition 5.2 (b) of the licence, the programme of infrastructural improvements shall include an assessment of the integrity of the waste water works having regard to:

(i) Capacity of the waste water works:

There is adequate capacity at the treatment plant (ref section 2.1, Table 1.2).

(ii) Leaks from the waste water works:

There are no known leaks at the WWTP site.

(iii) Misconnections between foul sewers and surface water drainage network:

There are no known misconnections on the Scotstown network.

(iv) Infiltration by surface water/ground water:

Scotstown network is a combined system, during storm conditions/periods of extensive rainfall, inflows into the Scotstown WWTP increase greatly. It is unknown if there is infiltration by surface/ground water into the network. A CCTV survey of the network would identify any defects in the network and any remedial works required.

## b) Programme of Improvements

Under condition 5.2 (c) of the licence, the programme of infrastructural improvements shall include an assessment of all storm water overflows associated with the waste water works to determine the effectiveness of their operation and in particular identify improvements necessary to comply with the requirements of this licence:

There are no specified improvement works in the Scotstown discharge licence and no planned improvement works for the WWTP.

An assessment of the SWO from a storm tank at the WWTP in relation to the 'Procedures and criteria in relation to Storm Water Overflows', 1995 document, was addressed in section 4.1 of this report, it is concluded that the SWO complies with the document as assessed under section 4.1.

Condition 5.3 (a) and (b) of the licence, the programme of infrastructural improvements shall include a plan for implantation for each individual improvement identified:

There is no specified improvement works under schedule C of the discharge licence. One individual improvement identified for the Scotstown sewer network is to carry out a CCTV survey of the network to identify and carry out remedial works necessary on the network.

Improvement Summary Table

Improvement Identifier	Improvement Description	Improvement Source	Progress (% completed)	Expected Completion Date
High inflows into the Scotstown WWTP during storm conditions/periods of heavy rainfall	CCTV survey of network & remedial measures identified carried out	WWTP assessment (Condition 5.3)	0%	The improvement programme will be reviewed by Irish Water to assess the works required to comply with

				the licence condition on a prioritised basis.
No record of SWO activating or measurement or flows.	Install SWO measurement/recorder device to measure flows/record no. times it activates	Cond. 4.1 of this report	0%	The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis.



## Appendix 7.6 - Priority substances assessment

### Priority Substance Assessment

Under Schedule B.1 of the licence, there is a requirement that, Priority Substances that are identified by the licensee in the effluent after undertaking a 'risk based assessment in accordance with the Guidance on the screening for Priority Substances for Waste Water Discharge Licences', should be monitored at least annually, by the licensee.

A desktop study is undertaken as follows:

The Scotstown WWTP catchment area serves a small rural village comprising primarily of domestic dwellings, along with a school, church and local shops. There are no industrial inputs to the waste water works or section 16 licenced companies discharging to the WWTP, or disposal of same at the waste water works. It can therefore be concluded from this desktop overview that there is no further screening necessary or required for organic compounds or metals. Furthermore, in 2009 when the initial discharge licence application for Scotstown was compiled, monitoring of the influent and effluent discharges and upstream and downstream locations in the receiving Blackwater River was undertaken and analysed for dangerous substances and submitted with the application. There were no elevated levels of these compounds in the discharge as reported. It is therefore concluded that no further screening is required for Scotstown WWTP with regard to priority substances.