

Regional Inspectorate McCumiskey House, Richview, Clonskeagh Road, Dublin 14, Ireland

Cigireacht Réigiúnach, Teach Mhic Chumascaigh Dea-Radharc, Bóthar Cluain Sceach Baile Átha Cliath 14, Éire

T: +353 1 268 0100 F: +353 1 268 0199 E: info@epa.ie W: www.epa.ie LoCall: 1890 33 55 99

Mr Mark Johnston Water Services Monaghan County Council County Offices The Glen Monaghan

06 May 2011

D0435-01

re: Notice in accordance with Regulation 18(3)(b) of the Waste Water Discharge (Authorisation) Regulations 2007

Dear Mr Johnston

I refer to the above referenced application for a waste water discharge licence relating to agglomeration named Ballinode. Having examined the documentation submitted, I am to advise that the Agency is of the view that the documentation does not comply with Regulation 16 of the Waste Water Discharge (Authorisation) Regulations 2007.

You are therefore requested, in accordance with Regulation 18(3)(b) of the regulations, to take the steps to supply the information detailed below:

REGULATION 16 COMPLIANCE REQUIREMENTS

Section A: Non-technical Summary

• Update the non-technical summary to reflect the information provided in response to this notice.

Section B: General

• Provide details on how much of the current load to the waste water treatment plant (WWTP) is from a domestic source and how much is from a non-domestic source.

Section C: Infrastructure and Operation

- Provide details, if available, on the design discharge concentration for total phosphorus and ammonia as N for the existing WWTP (1,000 p.e.).
- Clarify whether the emergency overflow from the storm tank and the pump sump at the WWTP have been known to activate in the last 12 months. If so provide the reason for the activation, and give details of the frequency, duration and discharge volumes, where available.
- Clarify the location of the storm water overflow discharge point to the river and update any drawings accordingly.
- Assess the design criteria of the storm water overflows. Demonstrate (providing available evidence) whether all storm water overflows meet the design criteria established in 'Procedures and Criteria for Storm Water Overflows', published by the Dept. of the Environment, 1995. Clarify whether there are screens on all of the overflows and identify any SWOs that may be impacting on surface water quality. Where a storm water overflow does not comply with these guidelines, give details of any plans for improvement.
- Confirm the capacity of the storm tank (in terms of number of dry weather flows as well as volumetric capacity).
- Clarify how wastewater is collected in the agglomeration, for example combined or separate foul sewage drainage network.



Section D: Discharges to the Aquatic Environment

Provide date(s) when all the monitoring reported in Table D1(i)(b) and Table D.1(i)(c) was carried out

Section E: Monitoring

- Provide effluent, influent, upstream and downstream monitoring data from May 2009 to date.
- Confirm the hardness (as CaCO3) of the receiving water upstream and downstream of the primary discharge point to determine compliance with the European Communities Environmental Objectives (Surface Waters) Regulations 2009, S.I. No. 272 of 2009.

Section F: Existing Environment & Impact of the discharge(s)

- Demonstrate that the effluent discharge, via the primary discharge point, to the receiving water does not cause an exceedance of the European Communities Environmental Objectives (Surface Waters) Regulations 2009 for parameters including BOD, total ammonia and molybdate reactive phosphorus (MRP). If there is a breach of the relevant water quality standards, then review the need for a programme of improvements and submit the details accordingly.
- Determine if there is likely to be a significant impact from the waste water discharges from the Ballinode agglomeration on the relevant European Sites
- You are requested to use the EPA guidance note: Waste Water Discharge Licensing Appropriate
 Assessment when completing your determination. This guidance is available on the EPA website
 www.epa.ie (see Downloads\ Forms\ Licensing & Permitting\ Waste Water Discharge
 Authorisation). Each step of Stage 1 Screening should be completed and the results of each step
 recorded.
- If based on the above determination (Stage 1) there is likely to be a significant effect on a European site(s) then an Appropriate Assessment (Stage 2) must be carried out. Where it considered that an Appropriate Assessment is not required, provide a reasoned response.
- You should also refer to Circular L8/08 'Water Services Investment and Rural Water Programmes Protection of Natural Heritage and National Monuments' issued by the Department of the Environment, Heritage and Local Government to assist in this determination, in particular, the flow diagram in Appendix 1.

In the case where any drawings already submitted are subject to revision consequent on this request, a revised drawing should be prepared in each case. It is not sufficient to annotate the original drawing with a textual correction. Where such revised drawings are submitted, provide a list of drawing titles, drawing numbers and revision status, which correlates the revised drawings with the superseded versions.

Please supply the information in the form of a one original plus one copy within **eight** weeks of the date of this notice. In addition please submit one copy of the requested information in electronic searchable PDF format on a CD-ROM (no file to exceed 10MB) to the Agency. Please note that all maps/drawings should not exceed A3 in size.

Please note that the application's register number is D0435-01. Please direct all correspondence in relation to this matter to Administration, Environmental Licensing Programme, Office of Climate, Licensing & Resource Use, Environmental Protection Agency, Headquarters, PO Box 3000, Johnstown Castle Estate, County Wexford quoting the register number.

Yours sincerely,

Dennile (og 2)
Jennifer Cope
Inspector

Office of Climate, Licensing & Resource Use