

Station	Date of monitoring	Time	L <sub>Aeq</sub>	L <sub>A10</sub>	L <sub>A90</sub>	L <sub>Amax</sub>	Tonal or impulsive noise	Comments	Is site compliant with noise limits (day/evening night)?
N1	21/11/2014	10:45 - 12:15	60.2	61.7	51.2	61.7	No	Local level from Biofilter	Yes
N2	21/11/2014	13:52 - 14:22	58.5	59.8	50.3	59.8	No	Site noise, distant traffic	Yes
N3	21/11/2014	14:28 - 15:58	56	58.5	49.4	58.5	No	Local traffic, industrial noise	Yes
NSR	21/11/2014	09:14 - 10:34	63.5	65.2	55.2	65.2	No	Local traffic, no site noise	Yes

For inspection purposes only.  
Consent of copyright owner required for any other use.