



Typical Section Through Air Vent
Scale: 1:50

Proposed Polypipe Polystorm Modular Cell System
Scale: 1:50

<p>Notes:</p> <p>1) Proposed pipework shall be Polypipe Ridgidrain pipework and fittings u.n.o.</p> <p>2) Proposed drainage channel shall be the Aco MultiDrain M150D 20.0 with ductile iron Heelguard grating load class C250.</p> <p>3) Proposed hydrocarbon interceptor shall be a Class 1 by-pass separator ref. NSBP003 by Kingspan Klargestor</p> <p>4) The flow control shall be a hydrobrake by HRD Technologies: Head: 800mm Flow: 3L/Sec</p>	<p>5) Proposed attenuation structure shall be the Polypipe Polystorm modular cell ref. PSM1</p> <p>Legend:</p> <p>Pipework & Manhole </p> <p>Hydrocarbon Interceptor </p> <p>Drainage Channel </p>	<table border="1"> <tr> <td>C1</td> <td>05/08/16</td> <td>D.F.</td> <td>J.B.</td> <td>J.MacC.</td> </tr> <tr> <td colspan="5">Issued for Construction</td> </tr> <tr> <td>T1</td> <td>29/04/16</td> <td>J.M.</td> <td>J.B.</td> <td>J.MacC.</td> </tr> <tr> <td colspan="5">Issued for Tender</td> </tr> <tr> <td>Rev</td> <td>Date</td> <td>By</td> <td>Chkd</td> <td>Appd</td> </tr> </table>	C1	05/08/16	D.F.	J.B.	J.MacC.	Issued for Construction					T1	29/04/16	J.M.	J.B.	J.MacC.	Issued for Tender					Rev	Date	By	Chkd	Appd	<p>Client: Wyeth Nutritionals Ireland</p> <p>Project Title: New Car Park Project</p> <p>Drawing Title: Proposed Surface Water Drainage Layout</p>	<p>Scale at A1: 1:250</p> <p>Role: Site Infrastructure</p> <p>Suitability: Construction</p> <p>Arup Job No: 233421-03</p> <p>Name: C1</p> <p>C-000-007</p>
C1	05/08/16	D.F.	J.B.	J.MacC.																									
Issued for Construction																													
T1	29/04/16	J.M.	J.B.	J.MacC.																									
Issued for Tender																													
Rev	Date	By	Chkd	Appd																									