

Annual Environmental Report 2016

Agglomeration Name:	Glaslough
Licence Register No.	D0347-01



Contents

Section 1. Executive Summary and Introduction to the 2016 AER	2
1.1 Summary Report on 2016	3
Section 2. Monitoring Reports Summary	4
2.1 Summary report on monthly influent monitoring	4
2.2 Discharges from the agglomeration	5
2.3.1. Ambient Monitoring Summary	6
2.4 Data collection and reporting requirements under the UWWTD	6
2.5 Pollutant Release and Transfer Register (PRTR) - report for previous year	6
Section 3. Operational Reports Summary	7
3.1 Treatment Efficiency Report	7
3.2 Treatment Capacity Report	7
3.3 Extent of Agglomeration Summary Report	7
3.4 Complaints Summary	8
3.5 Reported Incidents Summary	9
3.6 Sludge / Other inputs to the WWTP	10
Section 4. Infrastructure Assessments and Programme of Improvements	11
4.1 Storm water overflow identification and inspection report	11
4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.	12
Section 5. Licence Specific Reports	15
Section 6. Certification and Sign Off	16
Section 7. Appendices	17
Appendix 7.1 – Statement of Measures / Improvement Programme	
Appendix 7.2 – Ambient Monitoring	
Appendix 7.3 – Sewer Integrity Risk Assessment 2016	

Section 1. Executive Summary and Introduction to the 2016 AER

1.1 Summary Report on 2016

This Annual Environmental Report has been prepared for **D0347-01, Glaslough**, in County **Monaghan**, in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified assessments are included as an appendix to the AER as follows:

- Sewer Integrity Risk Assessment in **Appendix 7.3**

The agglomeration is served by a wastewater treatment plant with a Plant Capacity PE of 1850. The treatment process includes the following:-

- Primary Treatment (Sludge Settlement Pond)
- Secondary Treatment (Wetland Treatment System)
- Nutrient Removal (Wetland Treatment System)

The final effluent from the Primary Discharge Point was non-compliant with the Emission Limit Values in 2016.

The following parameters exceeded the emission limit values in 2016:-

- Ortho P (mg/l)
- Ammonia NH₃ (mg/l)

0kgs sludge was removed from the wastewater treatment plant in 2016.

The following improvement works were undertaken in 2016:-
There were no major capital or operational changes in 2016

An Annual Statement of Measures is included in **Appendix 7.1**

Section 2. Monitoring Reports Summary

2.1 Summary report on monthly influent monitoring

Table 2.1 Influent Monitoring Summary

2.1.1 Monthly Influent Monitoring	BOD (mg / l)	COD (mg / l)	SS (mg / l)	TP (mg / l)	TN (mg / l)	Hydraulic Loading (m3/d)	Organic Loading (PE/Day)
Number of Samples	6	6	6	6	6		
Annual Max.	855.1	1690	310	9.8	50.7	441.6	1,696
Annual Mean	350.31	706.27	206.60	4.34	32.89	139.51	803.77

Other inputs in the form of sludge/leachate are added to the WWTP after the influent monitoring point and are therefore not represented by influent monitoring. Other inputs, where relevant, are detailed in Section 3.6.

Significance of results

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity as detailed further in Section 3.2

The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity as detailed further in Section 3.2. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliant with Emission Limit Values

The annual mean organic loading is less than the Treatment Plant Capacity as detailed further in Section 3.2.

The annual maximum organic loading is less than the Treatment Plant Capacity as detailed further in Section 3.2.

2.2 Discharges from the agglomeration

Table 2.2 - Effluent Monitoring

2.2.1 Effluent Monitoring Summary	BOD (mg/l)	COD (mg/l)	TSS (mg/l)	Ortho P (mg/l)	Ammonia NH3 (mg/l)	pH
WWDL ELV (Schedule A) where applicable	10.00	75.00	15.00	0.50	1.00	6 to 9
ELV with Condition 2 Interpretation included	20.00	150.00	37.50	0.60	2.00	No allowable Failures
Interim % Reduction (Schedule A)						
Number of sample results	7	7	7	7	7	
Number of sample results above WWDL ELV	0	0	0	7	4	
Number of sample results above ELV with Condition 2 Interpretation	0	0	0	7	4	
Annual Mean (for parameters where a mean ELV applies)						
Overall Compliance (Pass/Fail)	Pass	Pass	Pass	Fail	Fail	

Significance of results

The WWTP was non-compliant with the ELV's set in the wastewater discharge licence. There were 11 samples non-compliant with the ELVs in relation to Ortho P (mg/l), Ammonia NH3 (mg/l). There were 7 non-compliances for ortho p and 4 non-compliances for ammonia. The non-compliances are due to vegetation decay and die back in the wetland system. The impact on the receiving water is assessed further in section 2.3.

2.3.1. Ambient Monitoring Summary

Table 2.3. Ambient Monitoring Report Summary Table

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Bathing Water	Drinking Water	FWPM	Shellfish	Current WFD Status
Upstream Monitoring Point	272001E 342273N	RS03M010670					Poor
Downstream Monitoring Point	272357E 342273N	RS03M010680	No	No	No	No	Poor

The results for the upstream and downstream monitoring and/or additional monitoring data sets from Irish Water are included in Appendix 7.2.

Significance of results

- The WWTP was non-compliant with the ELV's set in the wastewater discharge licence as detailed in Section 2.2.
- The discharge from the wastewater treatment plant does have an observable negative impact on the water quality.
- The discharge from the WWTP doesn't have an observable negative impact on the Water Framework Directive status.
- Other potential causes of deterioration in water quality relevant to this area are unknown.

2.4 Data collection and reporting requirements under the UWWTD

The electronic submission of data was completed on 11/01/2017

2.5 Pollutant Release and Transfer Register (PRTR) - report for previous year

A PRTR is not required as the PE is < 2000

Section 3. Operational Reports Summary

3.1 Treatment Efficiency Report

	cBOD (kg/yr)	COD (kg/yr)	SS (kg/yr)	Total P (kg/yr)	Total N (kg/yr)
Influent mass loading (kg/year)	17,602	35,489	10,381	218	1,653
Effluent mass emission (kg/year)	149	2,137	354	102	396
% Efficiency (% reduction of influent load)	99%	94%	97%	53%	76%

3.2 Treatment Capacity Report

Table 3.2 - Treatment Capacity Report Summary

Hydraulic Capacity – Design / As Constructed (dry weather flow) (m3/day)	420
Hydraulic Capacity – Design / As Constructed (peak flow) (m3/day)	1,260
Hydraulic Capacity – Current loading (m3/day)	140
Hydraulic Capacity – Remaining (m3/day)	1,120
Organic Capacity - Design / As Constructed (PE)	1,850
Organic Capacity - Current loading (PE)	804
Organic Capacity – Remaining (PE)	1,046
Will the capacity be exceeded in the next three years? (Yes / No)	No
Is an upgrade or expansion of the WWTP proposed? (i.e. if on Minor Programme or CIP) (Yes/No)	No

3.3 Extent of Agglomeration Summary Report

In this section Irish Water is required to report on the amount of urban waste water generated within the agglomeration. It does not include any waste water collected and created in a private system and discharged to water under a Section 4 Licence issued under the Water Pollution Acts 1977 (as amended).

Table 3.3 - Extent of Agglomeration Summary Report

	% of P.E. load generated in the agglomeration	Estimated / Measured
Load generated in the agglomeration that is collected in the sewer network	100%	Estimated
Load collected in the agglomerations that enters treatment plant	100%	Estimated
Load collected in the sewer network but discharges without treatment (includes SWO, EO, and any discharges that are not treated)	Unknown	Estimated

Load generated in the agglomeration that is collected in the sewer network is the total load generated and collected in the municipal network within the boundary of the agglomeration.

Load collected in the agglomerations that enters treatment plant is that portion of the previous figure which enters the waste water treatment plant.

Load collected but discharged without treatment is that portion of the first figure which is discharged without treatment.

3.4 Complaints Summary

A summary of complaints of an environmental nature is included below.

Table 3.4 - Complaints Summary Table

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
0			

3.5 Reported Incidents Summary

A summary of reported incidents is included below.

Table 3.5.1 - Summary of Incidents

3.5.1 Incident Type (e.g. Non-compliance, Emission, spillage, pollution incident)	Incident Description	Cause	No. of Incidents	Recurring Incident (Yes/No)	Corrective Action	Authorities Contacted. Note 1	Reported to EPA (Yes/No)	Closed (Yes/No)
Non Compliance	INCI001987 Breach of ELV for Ammonia and Ortho P	Vegetation decay / die back in the wetland treatment system	8	Yes		IFI	Yes	No

Note 1: For shellfish waters notify the Marine Institute (MI) Sea Fisheries Protection Authority (SFPA) Food Safety Authority (FSAI) and An Bord Iascaigh Mhara (BIM). This should also include any other authorities that should be contacted arising from the findings of any Licence Specific Reports also e.g. Drinking Water Abstraction Impact Risk Assessment, Fresh Water Pearl Mussel Impact Assessments etc.

Table 3.5.2 - Summary of Overall Incidents

Number of Incidents in 2016	8
Number of Incidents reported to the EPA via EDEN in 2016	8
Explanation of any discrepancies between the two numbers above	N/A

3.6 Sludge / Other inputs to the WWTP

Other inputs to the waste water treatment plant are summarised in Table 3.6 below.

Table 3.6 - Other Inputs

Input Type	m3/year	P.E.	% of load to WWTP	Included in Influent Monitoring? (Y/N)	Is there a leachate/sludge acceptance procedure for the WWTP? (Y/N)	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Domestic /Septic Tank Sludge	0	0				
Industrial / Commercial Sludge	0	0				
Landfill Leachate (delivered by tanker)	0	0				
Landfill Leachate (delivered by sewer network)	0	0				
Other (specify)	0	0				

Section 4. Infrastructure Assessments and Programme of Improvements

4.1 Storm water overflow identification and inspection report

There are no Storm Water Overflow identified in the licence.

4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.

The Improvement Programme report included in Appendix 7.1 addresses the **Specified Improvement Programmes** as detailed in Schedules A3 and C of the WWDL. It should detail other improvements identified through assessments required under the licence.

Table 4.2.1 - Specified Improvement Programme Summary

Specified Improvement Programmes	Licence Schedule	Licence Completion Date	Date Expired	Status of Works	% Construction Work Completed	Licensee Timeframe for Completing the Work	Comments
None							

A summary of the status of any improvements identified by under Condition 5.2 is included below.

Table 4.2.2 - Improvement Programme Summary

Improvement Identifier / Name	Improvement Description	Improvement Source	Progress (% complete)	Expected Completion Date	Comments
To Improve Ortho P and ammonia results	Implement a return of activated wastewater to the head of the works, from cell pond 3 to pumping station at head of works	WWTP assessment (Condition 5.2)	100%		Project Complete
High Inflows into the WWTP during storm conditions/periods of heavy rainfall.	CCTV of network and establish where excess storm water ingress to collection network	WWTP assessment (Condition 5.2)			The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised

Replanting of cell 3	Excavate and remove Phragmites australis (common reed) from upper end of cell 3 and replant with glyceria maxima.	WWTP assessment (Condition 5.2)	100%		
	Interpond sampling programme to assess performance and determine actions required	Improved Operational Control			Planned 2017

Table 4.2.3 - Sewer Integrity Risk Assessment Tool Summary

The Improvement Programme should include an assessment of the integrity of the existing wastewater works for the following:	Risk Assessment Rating (High, Medium, Low)	Risk Assessment Score	Reference to relevant section of AER (e.g. Appendix 2 Section 4).	Specified improvements	Comment
Hydraulic Risk Assessment Score	High	120	Appendix 7.3 AER 2016		
Environmental Risk Assessment Score	Low	50	Appendix 7.3 AER 2016		
Structural Risk Assessment Score	High	140	Appendix 7.3 AER 2016		
Operation & Maintenance Risk Assessment Score	Low	40	Appendix 7.3 AER 2016		
Overall Risk Score for the agglomeration	High	350	Appendix 7.3 AER 2016		

Section 5. Licence Specific Reports

Licence Specific Reports Summary Table

Licence Specific Report	Never required by condition 5 in Licence	Required in this AER or outstanding from previous AER	Included in this AER / Remains outstanding	Reference to previous AER containing report or relevant section of this AER
Priority Substances Assessment	Not Required			
Drinking Water Abstraction Point Risk Assessment	Not Required			
Shellfish Impact Assessment	Not Required			
Pearl Mussel Report	Not Required			
Toxicity/Leachate Management	Not Required			
Toxicity of Final Effluent Report	Not Required			
Small Stream Risk Score Assessment	Not Required			
Habitats Impact Assessment	Not Required			

Licence Specific Reports Summary of Findings

Licence Specific Report	Recommendations in Report	Summary of Recommendations in Report
Priority Substances Assessment	No	
Drinking Water Abstraction Point Risk Assessment	No	
Shellfish Impact Assessment	No	
Pearl Mussel Report	No	
Toxicity/Leachate Management	No	
Toxicity of Final Effluent Report	No	
Small Stream Risk Score Assessment		
Habitats Impact Assessment	No	

Section 6. Certification and Sign Off

Table 6.1 - Summary of AER Contents

Does the AER include an executive summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a technical amendment / review of the licence?	Yes
List reason e.g. additional SWO identified	Request for increase of ELV for ortho P and Ammonia from the 1st of November to the 15th of March each year
Is there a need to request/advise the EPA of any modifications to the existing WWDL? Refer to Condition 1.7 (changes to works/discharges) & Condition 4 (changes to monitoring location, frequency etc.)	No
List reason e.g. failure to complete specified works within dates specified in the licence, changes to monitoring requirements	N/A
Have these processes commenced? (i.e. Request for Technical Amendment / Licence Review / Change Request)	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER?	Yes
Ensure the following reports are included	Sewer Integrity Risk Assessment 2016

Declaration by Irish Water

The AER contains the following:

- Introduction and background to 2016 AER.
- Monitoring Reports Summary.
- Operational Reports Summary.
- Infrastructural Assessment and Programme of Improvements.
- Licence specific reports
- Certification and Sign Off
- Appendices

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:  Date: 24/02/2017

Elizabeth Arnett
Head of Corporate Affairs and Environmental Regulation

Section 7. Appendices

Appendix 7.1 Statement of Measures / Specified Improvement Programme

1	Issue	Failure to meet ELV for Ammonia and Ortho P
	Mitigation Measure	Implement a return of activated wastewater to the head of the works from cell pond 3 to pumping station at head of works
	Status	Project complete 2015
2	Issue	Flooding from stormwater around pump station and compound area
	Mitigation Measure	Flood control measure along river bank/ storm water check valve
	Status	50% complete
3	Issue	High inflows into the WWTP during storm periods of heavy rainfall
	Mitigation Measure	CCTV of network and establish where excess storm water ingress to collection network
	Status	The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis.
4	Issue	Failure to meet ELV for Ammonia and ortho P
	Mitigation Measure	Upgrade of ICW / replanting
	Status	Complete September 2015
5	Issue	Failure to meet ELV for Ammonia and ortho P
	Mitigation Measure	Implement programme of monitoring between cells
	Status	Planned 2017

Appendix 7.2 Ambient Monitoring Results

Upstream Glaslough WWTP									
Sample Reference	Sample Date	Sample Method	Dissolved Oxygen mg/l	Temp° C	Ortho Phosphorus mg/l	Ammonia mg/l	pH units	BOD mg/l	Total Nitrogen mg/l
93047/003	03/02/16	grab	13.1	6.3	0.049	0.06	7.9	< 1	< 1
95137/003	05/04/16	grab	10.85	7.6	0.035	0.051	8.1	2.7	1.4
96179/003	04/05/16	grab	11.07	10.1	0.014	0.02	8.3	2.1	< 1
98622/003	06/07/16	grab	9.04	13.6	0.061	0.048	8.1	2.8	1.6
100088/003	16/08/16	grab	8.28	15.5	0.078	0.053	8.1	1.6	< 1
102138/001	05/10/16	grab	9.65	12.4	0.058	0.076	8.2	1.6	< 1
		Average	10.332	10.917	0.049	0.051	8.117	2.160	1.500
Downstream Glaslough WWTP									
Sample Reference	Sample Date	Sample Method	Dissolved Oxygen mg/l	Temp° C	Ortho Phosphorus mg/l	Ammonia mg/l	pH units	BOD mg/l	Total Nitrogen mg/l
93047/004	03/02/2016	grab	13.1	6.2	0.051	0.091	8	< 1	< 1
95137/004	05/04/2016	grab	10.68	7.5	0.043	0.048	8.1	2.8	1.3
96179/004	04/05/2016	grab	11.01	10.3	0.026	0.02	8.3	2.3	< 1
98622/004	06/07/2016	grab	9.14	13.8	0.079	0.066	8.1	2.6	1.7
100088/004	16/08/2016	grab	8.55	14.8	0.075	0.045	8.2	1.8	1.3
102138/002	05/10/2016	grab	9.62	12.4	0.066	0.083	8.3	1.8	1.6
		Average	10.350	10.833	0.057	0.059	8.167	2.260	1.475

Appendix 7.3 Sewer Integrity Risk Assessment 2016

Section 1.1 Agglomeration Details						
Name		Glaslough				
Licence Number		D0347-01				
Insert Name of Catchment if the Risk Assessment is for part of an agglomeration (only divide agglomeration where p.e. >5,000p.e. and where such division is warranted)		Glaslough				
Date Licence Issued		09/02/2011				
Current Date		23/11/2016				
Waste Water Works - Wastewater Treatment Plant Details		Unit	Year 2015	Year 2016	Year 2017	Year 2018
1.1	Is there an existing WWTP in operation?		Yes	Yes	Yes	Yes
Section 1.2 BOD Loading & Population Equivalent						
1.2	Average Daily Influent Flow or Average Total Flow in system (If no measured data exists, insert estimated figure)	l/day, measured	137000	139500		
1.3	Average Daily Influent BOD or Average BOD Load from area served (If no measured data exists, insert estimated figure)	mg/l, measured	316.62	350.31		
1.4	Total BOD Load	kg/day	43.37694	48.868245	0	0
1.5	Average Population Equivalent (@0.06kg/person/day)	p.e.	723	814	0	0
1.6	Estimated (existing) Non-Domestic Load	p.e.	0	0		
1.7	Estimated Domestic Load	p.e.	723	814	0	0
1.8	Occupancy Rate for the Agglomeration	pop/house	2.7	2.1		
1.9	Estimated Number of Connected Properties	houses	268	388	0	0
1.10	Number of properties within the agglomeration when compared with CSO Data or An Post Geodirectory	houses	142	142		
Section 1.3 Hydraulic Details						
1.11	Average Dry Weather Flow arriving at WWTP OR Total Average DWF in system (If no measured data exists insert estimated figure)	l/s, measured	2.04	1.395833333		
1.12	Estimated 3DWF	l/sec	6.12	4.19	0.00	0.00
1.13	Annual Average Peak Flow to WWTP or discharging from whole system if there is no existing WWTP	l/s, measured	9.75	9.3		
1.14	This Annual Average Peak as Multiples of Dry Weather Flow (Peaking Factor)	Nr	4.78	6.66	0.00	0.00
1.15	Highest Peak Flow Recorded (Insert UNKNOWN if no records exist)	l/s	Unknown	9.75		
1.16	Does this Peak Flow (multiple of DWF) cause hydraulic capacity problems within the network ?	---	No	No	Yes	Yes
1.17	Total Rainfall for Previous Year	mm	1269	891		
1.18	Comparison - Mean Annual Rainfall for the agglomeration	mm	1007	1006.9		
1.18.1	Define the Weather Station Used		Ballyhaise	Ballyhaise		
1.19	If Storm Water Storage is available at the Wastewater Treatment plant, what is the volume of the storm tank ?	m ³	0	0		
1.20	Is the capacity of the storm tank sufficient to capture and retain all overflows to the tank ?	---	Yes	Yes	No	No
1.21	Total monthly average volume of Storm Water Stored or Returned for Treatment within the Waste Water Treatment Plant	m ³ per month	NA	NA		
1.22	If the answer to 1.20 above is No, What is the estimated frequency of Overflows from the Storm Tank ? (N/A if no overflow)		N/A	N/A	1 to 2 times per month	< 1 per month
Waste Water Works - Sewer Network Details		Unit	2015	2016	2017	2018
Section 1.4 Waste Water Works - Gravity Sewer Details						
1.23	What database is used to maintain records of the sewer network		Hard Copy Drawings only	Hard Copy Drawings only	SUS 2002	SUS 2003
1.23.1	If other or combination of the above please describe	Describe				
1.24	Total length of sewers (use drop down menus to define whether these figures are estimated or measured)	km Estimated	0.44	0.44	0.00	0.00
1.24.1	Total length of sewers > 450mm Diameter	km Estimated	0.00	0.00		
1.24.2	Total length of sewers > 300mm but ≤ 450mm in Diameter	km Estimated	0.00	0.00		
1.24.3	Total length of sewers > 225mm but ≤ 300mm in Diameter	km Measured	0.00	0.00		
1.24.4	Total length of sewers ≤ 225mm in Diameter	km Estimated	0.44	0.44		
1.24.5	Other	km Estimated	2.37	2.37		
1.25	Pipeline Material					
1.25.1	What portion of the sewer network consists of Concrete Pipes	% Estimated	0%	0%		
1.25.2	What portion of the sewer network consists of Plastic Pipes	% Estimated	0%	0%		
1.25.3	What portion of the sewer network consists of Clay materials	% Estimated	0%	0%		
1.25.4	What portion of the sewer network consists of Brick Type Sewers	% Estimated	0%	0%		
1.25.5	What portion of the sewer network consists of Other Materials	% Estimated	100%	100%		
1.26	Total number of Storm Water Overflows	Nr	0	0		

1.27	What Screening or other mechanical devices are employed at the storm water overflows					
1.28	Water Quality at the receiving waters					
1.28.1	Where the receiving water is a river - indicate the EPA Biological Rating of the Receiving Water for each SWO below (Particularly if there is more than one receiving water within the agglomeration)					
1.28.2	Where the receiving water is a coastal water indicate the Status of the Receiving Water for each SWO below (Particularly if there is more than one receiving water within the agglomeration)					
1.28.3	With reference to the SWO's detailed above define if the receiving waters are sensitive in accordance with the Urban Wastewater Treatment Regulations as amended.					
1.28.4	With reference to the SWO's detailed above define are the receiving waters Protected Areas (designated or awaiting designation)					
1.28.5	With reference to the SWO's detailed above define do the receiving waters have any other designations.					
	Section 1.5 Waste Water Works - Pumping Stations					
1.29	Number of Pumping Stations (operated by the Local Authority)	Nr	1	1		
1.30	Total Length of Rising Mains (operated by the Local Authority)	km	178.6	178.6		
1.31	Rising Main Material					
1.31.1	What portion of the rising mains consists of ductile iron pipes	% Measured	Unknown	Unknown		
1.31.2	What portion of the rising mains consists of plastic pipes	% Measured	Unknown	Unknown		
1.31.3	What portion of the rising mains consists of other materials	% Estimated	Unknown	Unknown		
1.32	Discharge Capacity of the Pump Set (s) at normal duty point					
	At Pump Station 1 at E2271719, N341666		Unknown	Unknown		
1.33	What percentage of the pumping stations have recorded flow data (i.e. if all pumping stations have flow meters on the rising mains then this would read 100%)	%	Unknown	Unknown		
1.34	Available Storage Capacity at Pump Stations (include pump sump and any storm water/emergency overflow tanks)					
	At Pump Station 1 at E2271719, N341666	m ³	Unknown	Unknown		
1.35	Total Number of " Licensed Secondary Discharge Points and Stormwater Overflows " at pumping stations	Nr	Unknown	Unknown		
1.36	Total Number of " Emergency Overflow Points " at pumping stations	Nr	Unknown	Unknown		
1.37	What Screening or other mechanical devices are employed at the secondary discharge points or emergency overflows ?					
	At Pump Station 1 at E2271719, N341666	Describe	Unknown	Unknown		
1.38	Water Quality at the receiving waters at each pumping station location					
1.38.1	Where the receiving water is a river - indicate the EPA Biological Rating of the Receiving Water for each secondary discharge point or emergency overflow at each pumping station (Particularly if there is more than one receiving water within the agglomeration)					

	At Pump Station 1 at E2271719, N341666	Describe	Unknown	Unknown		
1.38.2	Where the receiving water is a coastal water indicate the Status of the Receiving Water for each secondary discharge point or emergency overflow at each pumping station (Particularly if there is more than one receiving water within the agglomeration)					
	At Pump Station 1 at E2271719, N341666	Describe	Unknown	Unknown		
1.38.3	With reference to the pumping stations, for each secondary discharge point or emergency overflow detailed above, define if the receiving waters are sensitive in accordance with the Urban Wastewater Treatment Regulations as amended.					
	At Pump Station 1 at E2271719, N341666		Unknown	Unknown		
1.38.4	With reference to the pumping stations, for each secondary discharge point or emergency overflow detailed above, are the receiving waters Protected Areas (designated or awaiting designation) .					
	At Pump Station 1 at E2271718, N341662 well upstream in network	Designation	Unknown	Unknown		
	At Pump Station 2 at E271718, N341662	Designation	Unknown	Unknown		
1.38.5	With reference to the pumping stations, for each secondary discharge point or emergency overflow detailed above, do the receiving waters have any other designations.					
	At Pump Station 1 at E2271719, N341666	Designation	Unknown	Unknown		
1.39	Estimated Number of Private Pumping Stations within the agglomeration (not operated by the Local Authority)	Nr	0	0		
	Section 1.6 Reporting					
	Section 1.6.1 Reported Number of Sewer Related Complaints (‘Complaint’ as defined in the Discharge Licence)					
1.40	Number of Reported Complaints	Nr	0			
1.41	Number of Reported Complaints which have been rectified	Nr	0			
	Section 1.6.2 Reported/Recorded/Estimated Number of Secondary Discharges					
1.42	Number of Reported Secondary Discharges	Nr	0			
1.43	Number of Recorded Secondary Discharges	Nr	0			
1.44	Estimated Total Number of Secondary Discharges	Nr	0	0	0	0
	Section 1.6.3 Reported/Recorded/Estimated Number of Emergency Overflow Discharges from Pumping Stations					
1.45	Number of Reported Emergency Overflow Discharges	Nr	0			
1.46	Number of Recorded Emergency Overflow Discharges	Nr	0			
1.47	Estimated Total Number of Emergency Overflow Discharges	Nr	0	0	0	0
	Section 1.7 Operational Staff					
1.48	In the four boxes below, describe the extent of operation staff employed by the Local Authority to maintain and operate the sewer network and pumping stations <i>(The individual personnel shall not be named, only grade and level of training needs to be provided)</i>					
1.48.1	Caretaker 3 is responsible for the maintenance and operation of the Glaslough network and WWTP. This Caretaker is also responsible for the Emyvale and Carrickroe agglomerations.					
1.48.2	Caretaker operates under the supervision of a Line Manager Technician					
1.48.3	The Line Manager Technician is supervised by the Senior Executive Engineer					
1.48.4						
	Waste Water Works - Investment Details	Unit	2015	2016	2017	2018

	Section 1.8 Capital Investment works carried out since most recent report (including works not included on WSIP Programme or not WSIP funded)					
1.49	Sewers Upgraded or Replaced	m	0			
1.50	Sewers Rehabilitated	m	0			
1.51	Manholes Rehabilitated	Nr	0			
1.52	Local Repairs	Nr	0			
1.53	Total Length of sewers Upgraded, Replaced or Rehabilitated	m	0	0	0	0
1.54	Pumping Stations Operated by Local Authority Upgraded or Repaired	Nr	0			
1.55	WWTW operated by Local Authority Upgraded or Replaced	Nr	0			
1.56	In the following two cells describe the actual Capital Investment undertaken in the reporting period.					
1.56.1	ICW to be upgraded - 2015 AER, Appendix 7.1					
1.56.2						
	Section 1.9 Licence Specified Improvements Works					
1.57	2015 AER, Appendix 7.3					
	Section 1.10 Other Updates Since Last Report					
1.58						
1.59						
1.60						
1.61						
1.62						

Section 2.1 Hydraulic Risk Assessment

Query	Description	Prompt	Risk Score	Short Commentary by the Local Authority	Comment or Action to be Taken
2.1	Has a Hydraulic Performance Assessment been undertaken for the Sewer Network (e.g., Computer Model or other Engineering Design or Design Review) ?	No	40	Identified, therefore a	If the answer is No assess the need and cost benefit of developing a computer model or engineering design assessment of the Sewer Network and complete Query 2.12. If the answer is Yes proceed to Queries 2.1.1 to 2.1.4 inclusive
2.1.1	If Answer to Query 2.1 is Yes, what % of the Network is covered by the hydraulic assessment ?	N/A	0		The % coverage of the Network by the Hydraulic Assessment can be estimated by the area assessed against the area served by the Network. ENTER "N/A" IF COMPUTER MODEL or DESIGN DOES NOT EXIST. DO NOT LEAVE BLANK OR ENTER "0".
2.1.2	How many years has it been since the completion of the hydraulic assessment ?	N/A	0		Select N/A response if no design assessment or design exists.
2.1.3	Are the outcomes of the Hydraulic Assessment being implemented ?	N/A	0		Select N/A response if no design assessment or design exists.
2.1.4	How many years has it been since the outcomes of the hydraulic assessment have been implemented ?	N/A	0		Select N/A response if no hydraulic performance assessment or design exists. For ongoing works select "less than 5".
2.2	Has a Dynamic Computer Model been used to Assess the Hydraulic Performance of the Sewer Network ?	No	10		Computer Model means a Hydroworks/Infoworks Model, Micro-Drainage Model or equivalent.
2.3	Has a Manhole Survey been undertaken in accordance with WRc Documentation "Model Contract Document for Manhole Location Surveys and the Production of Record Maps" ?	No	10		If the answer is No assess the need and cost benefit of undertaking a Manhole Survey and complete Query 2.12. If the answer is Yes proceed to Query 2.2.1
2.3.1	If yes, how many years has it been since the survey was undertaken or updated?	N/A	0		Select N/A if no Manhole Survey has been undertaken. Enter N/A value for Confidence Grade if Prompt Box is "N/A"
2.4	Has a Flow Survey been undertaken in accordance with WRc Documentation "A Guide to Short Term Flow Surveys of Sewer Systems" and "Contract Documents for Short Term Sewer Flows" ?	No	20		If the answer is No assess the need and cost benefit of undertaking a Flow Monitoring Survey and complete Query 2.12. If answer is Yes Proceed to Query 2.5
2.5	What was this Flow Survey Information Used for ?				
2.5.1	To Determine the extent of Problematic Sewer Catchments	No	0		Select N/A if no Flow Survey has been undertaken.
2.5.2	To Verify a Computer or Mathematical Model of the Network	No	0		Select N/A if no Flow Survey has been undertaken.
2.6	Have Performance Criteria been developed to determine the short, medium or long term capacity of the sewer network ?	No	10		If the answer is No assess the Future Needs of the Sewer Network and complete Query 2.12. If the answer is Yes proceed to Query 2.8
2.7	How many flood events resulting from surcharge in the network have occurred in the past 3 years?	None	0		Flood events in this context means water/sewage backing up from the Network causing flooding of properties or causing disruption of traffic
2.8	Are there deficiencies in performance criteria within the sewer network ?	No	0		If the answer is No , Proceed to Query 2.10 and complete Query 2.12. If the answer is Yes proceed to Query 2.9
2.9	Have the causes of these deficiencies in the Performance Criteria been identified and rectified ?	No	10		If the answer is No , consider further examination of the hydraulic model (if available) and complete Query 2.12. If the answer is Yes proceed to Query 2.10
2.10	Can the Hydraulic Assessment (defined in Query 2.1 above) be used to determine the benefit of reducing the contributory Impermeable Areas or extent of surface water contributions	No	10		If the answer is No , consider further development of the Hydraulic Assessment (or model if available) and complete Query 2.12. If the answer is Yes proceed to Query 2.11
2.11	Has an Impermeable Area Survey been carried out for the agglomeration or parts of the agglomeration ?	No	10		If the answer is No , consider the need and cost benefit of undertaking an Impermeable Survey for parts of the agglomeration which are under hydraulic pressure and complete Query 2.12.
Total Risk Assessment Score (RAS)			120		
2.12	Prepare Assessment of Needs & Sewer Upgrade Implementation Plan	In the AER Attach Assessment of Needs and Rehabilitation Implementation Plan as separate documents			
2.13	In the AER provide Summary of Proposed Works or Direction to be taken to improve hydraulic efficiency				

Section 3.1 Environmental Risk Assessment					
Query	Description	Prompt	Risk Score	Short Commentary by the Local Authority	Comment or Action to be Taken
3.1	<u>What Environmental or Discharge Quality Data is available with regard to the sewer network ?</u>	largely anecdotal	20		Select N/A if no discharges, secondary discharges or overflows from network; if discharges do exist complete Query 3.12
3.1.1	<u>Do trade effluents discharge to the sewer network?</u>	No	0		If the answer is No , proceed to Query 3.1.2. If the answer is Yes , Proceed to Query 3.2
3.1.2	<u>Are there Storm Water Overflows within the network ?</u>	No	0		If the answer is No , proceed to Query 3.1.3. If the answer is Yes , Proceed to Query 3.3
3.1.3	<u>Are there Secondary Discharges within the network (excluding Emergency Overflows at Pump Stations)?</u>	No	0		If the answer is No , proceed to Query 3.1.4.
3.1.4	<u>Is there any evidence that exfiltration is occurring from the network ?</u>	No	0		If the answer is No , does all wastewater enter a wastewater treatment plant (insert summary details in the AER)? If Yes , Proceed to Query 3.6
3.2	<u>If Answer to Query 3.1.1 is "Yes", what % of trade effluents have a licence to Discharge to the Public Sewer ?</u>	N/A	0		Select N/A if answer to Query 3.1.1 is No . If not all trade effluents are licenced, Local Authority should consider issuing and controlling such discharges under the appropriate Legislation.
3.2.1	<u>Are all licenced trade Discharges compliant with their relevant licence and associated conditions.</u>	N/A	0		Answer N/A if none of the trade effluents are licenced. Answer No if this information is unknown. If the answer is Unknown or No , consider issuing a direction to the relevant Licencee. If the answer is Yes , no further action is needed.
3.2.2	<u>If Answer to Query 3.2.1 is "No", state what % of Trade Discharges are NOT compliant with their relevant licence and associated conditions (where that non-compliance led to enforcement action)</u>	N/A	0		Select N/A if answer to Query 3.2.1 is Yes . If N/A is selected as answer to Query 3.2.2
3.3	<u>In accordance with the DoEHLG paper "Procedures & Criteria in relation to Storm Water Overflows", what % of storm water overflows in the system have been classified for their significance?</u>	N/A	0		If the answer is No , consider a review of each discharge within the sewer network complete and Query 3.11. If the answer is Yes , proceed to Query 3.6
3.4	<u>Have samples from any Secondary Discharges within the system been analysed ?</u>	N/A	0		Select N/A if no secondary discharges in system. If the answer to Query 3.4 is No , consider examining the quality of each secondary discharge within the sewer network complete Query 3.11. If the answer is Yes , proceed to Query 3.5
3.5	<u>What percentage of discharges from the system are known to cause environmental pollution of the receiving waters ?</u>	< 10%	10		If the answer is greater than 50% then detail, in the AER, the Improvement Programme necessary to reduce this percentage.
3.6	<u>In relation to possible exfiltration has a risk analysis of ground water contamination or pollution been undertaken ?</u>	No	20		Select N/A if answer to Query 3.1.4 is No . If the answer is No , consider undertaking ground water risk analysis and complete Query 3.12 If the answer is Yes , proceed to Query 3.6
3.6.1	<u>If Answer to Query 3.6 is "Yes", have any groundwater aquifers been identified in the area of the Network and/or Discharge Points?</u>	No	0		Select N/A if no risk analysis of groundwater contamination has been undertaken.
3.6.2	<u>If Answer to Query 3.6.1 is "Yes", state the classification of groundwater aquifer identified in the area?</u>	N/A	0		Select N/A if no risk analysis of groundwater contamination has been undertaken.
3.6.3	<u>In relation to Query 3.6.1, is the aquifer used as a source for Public, Private or Group Water Supply Schemes?</u>	N/A	0		Select N/A if no risk analysis of groundwater contamination has been undertaken.
3.7	<u>Has an Impact Assessment of each Storm Water Overflow been undertaken in accordance with the DoEHLG paper "Procedures & Criteria in relation to Storm Water Overflows" including setting performance criteria?</u>	N/A	0		If the answer is No , consider assessing the risk category of the receiving waters. If the answer is Yes , proceed to Query 3.8 and provide summary details of the assessment in the AER.
3.8	<u>What percentage of storm water overflows comply with the performance criteria referred to in Query 3.7?</u>	N/A	0		Select N/A if answer to Query 3.7 is No or if there are no SWOs in system. (Risk Score is locked at 0 if no SWOs in system is stated in Agglomeration Details)
3.9	<u>Have the causes of these Capacity Deficiencies (storm water overflows & Secondary Discharges) been identified ?</u>	N/A	0		Select N/A if answer to Query 3.7 is No or if there are no SWOs in system. If the answer to Query 3.9 is No , consider further examination of the environmental model, see legislative model.
Total Risk Assessment Score (RAS)			50		
3.10	<u>Prepare Assessment of Needs & Sewer Upgrade Implementation Plan</u>	In the AER Attach Assessment of Needs and Rehabilitation Implementation Plan as separate documents			
3.11	Provide Summary Details (in the AER) of records upstream and downstream of licenced discharges with regard to Environmental Performance of the network. These details can be included as part of the AER submitted for the agglomeration.				

Section 4.1 Structural Risk Assessment

Query	Description	Prompt	Risk Score	Short Commentary by the Local Authority	Comment or Action to be Taken
4.1	Has a CCTV Survey been undertaken in accordance with WRc Documentation "Model Contract Document for Sewer Condition Inspections" and "Manual of Sewer Condition Classification" ?	No	10		If the answer is No assess the need and benefit of undertaking CCTV Survey. If Yes Proceed to Query 4.2
4.1.1	How many years has it been since the completion of the CCTV Survey?	N/A	0		If no CCTV has been undertaken, select "N/A" response
4.2	What was this CCTV Survey Information Used for?	N/A	10		Select N/A if answer to Query 4.1 is NO.
4.3	Has the CCTV Survey been used to Assess the Structural Condition of the Sewer Network or targeted sections of the Sewer Network?	No	5		If no CCTV has been undertaken, select "No" response. If the answer is No assess the need and benefit of undertaking an assessment of the Structural Condition of the Sewer Network. If the answer is Yes proceed to Q
4.4	Have Performance Criteria been developed to determine the short, medium or long term structural condition of the sewer network ?	No	5		If the answer is No , enter "unknown" in response to Queries 4.4.1 to 4.4.5; consider assessing the Future Needs of the Sewer Network. If the answer is Yes proceed to Queries 4
4.4.1	What % of the Total Sewer Length contains Collapsed or Imminent Collapse of Sewers (Grade 5)	unknown	30		Insert Percentage of Overall Network Length; If a sewer length contains a Grade 5 collapse, include the total length of that sewer in calculating the %. If information is not available type "Unknown" into Prompt Box
4.4.2	What % of Total Sewer Length contains Sewers Likely to Collapse (Grade 4)	unknown	25		Insert Percentage of Overall Network Length; If a sewer length contains a Grade 4 condition, include the total length of that sewer in calculating the %. If information is not available type "Unknown" into Prompt Box
4.4.3	What % of Total Sewer Length contains sewers with Further Possible Deterioration (Grade 3)	unknown	10		Insert Percentage of Overall Network Length; If a sewer length contains a Grade 3 deterioration, include the total length of that sewer in calculating the %. If information is not available type "Unknown" into Prompt Box
4.4.4	What % of Total Sewer Length contains sewers with Minimal Collapse (Grade 2)	unknown	5		Insert Percentage of Overall Network Length; If a sewer length contains a Grade 2 feature, include the total length of that sewer in calculating the %. If information is not available type "Unknown" into Prompt Box
4.4.5	What % of Total Sewer Length contains sewers of Acceptable Structural Condition (Grade 1)	unknown	5		Insert Percentage of Overall Network Length. If information is not available type "Unknown" into Prompt Box
If all % lengths are known, Check Total Length = 100%			75		If answers to Queries 4.4.1, 4.4.2 or 4.4.3 are above a set level, the RAS for Query 4 is automatically set at the maximum of 140.
4.5	What % of the deficiencies, as detailed in Items 4.4.1, 4.4.2 and 4.4.3, have been rectified ?	N/A	35		Select N/A if answer to Query 4.4 is No . If the answer is No , Proceed to Query 4.6 If the answer is Yes , what monitoring is in place to ensure continued acceptance of structural condition? Proceed to Query 4.7
4.6	Have the causes of the Structural Deficiencies (Grades 3, 4 and 5) been identified or is there a Preventative Maintenance Programme in place?	N/A	0		If the answer is No , consider further examination of the sewer network, the structural loading conditions, gradients and possible H ₂ S Formation. If Yes completed Query 4.7
Total Risk Assessment Score (RAS)			140		
4.7	Prepare Assessment of Needs & Sewer Rehabilitation Implementation Plan	In the AER Attach Assessment of Needs and Rehabilitation Implementation Plan as separate documents			

Section 5.1 O&M Risk Assessment

Query	Description	Prompt	Risk Score	Short Commentary by the Local Authority	Comment or Action to be Taken
5.1	<u>Are complaints of an environmental nature recorded and held in a central database?</u>	Yes	0		Consider setting up Central Database for Complaints
5.2	<u>Is there an emergency response procedure in place?</u>	No	20		Consider setting up target response times for dealing with Complaints
5.3	<u>What has been the highest frequency of flooding in the network due to hydraulic inadequacy, over the past 5 years?</u>	None	0		Refers to flooding from the Network only, not natural flooding from rivers/streams/high tides. Select the highest number of events in any 12 month period.
5.4	<u>What has been the highest frequency of flooding in the network due to operational causes over the past 5 years?</u>	None	0		Refers to flooding from the Network only, not natural flooding from rivers/streams/high tides. Select the highest number of events in any 12 month period.
5.5	<u>What has been the highest frequency of surcharging of critical sewers in the network, over the past 5 years?</u>	None	0		Select the highest number of events in any 12 month period.
5.6	<u>What has been the highest frequency of reportable incidents in the network, over the past 5 years?</u>	None	0		Select the highest number of events in any 12 month period.
5.7	<u>What has been the highest frequency of reportable incidents due to discharges, for whatever reason, from Pumping Station Emergency Overflows in the network, over the past 5 years?</u>	None	0		Select the highest number of events at any given Pumping Station in any 12 month period.
5.8	<u>What has been the highest frequency of blockages in sewers in the network over the past 5 years?</u>	unknown	20		Select the highest number of events per km of sewer network in any 12 month period.
5.9	<u>What has been the highest frequency of collapses in sewers in the network over the past 5 years?</u>	None	0		Select the highest number of events in any 12 month period.
5.10	<u>What has been the highest frequency of bursts in rising mains in the network over the past 5 years?</u>	None	0		Select the highest number of events in any 12 month period.
Total Risk Assessment Score (RAS)			40		
5.11	<u>Prepare Up Dated Operational and Maintenance Plan</u>				

Section 6.1 Summary of Risk Assessment Scores

Element	Risk Assessment Score	Risk Category	% Risk Score	Maximum Risk Score
Section 2.1 Hydraulic Risk Assessment	120	High Risk	80%	150
Section 3.1 Environmental Risk Assessment	50	Low Risk	10%	500
Section 4.1 Structural Risk Assessment	140	High Risk	93%	150
Section 5.1 O&M Risk Assessment	40	Low Risk	20%	200
Total RAS for Network	350	High Risk	35%	1000

If the total RAS is greater than 750, or if any of the individual RASs are greater than 75% of the Maximum Available Score, the Risk category for the Network is graded "High Risk"