



**OFFICE OF CLIMATE,
LICENSING, RESOURCES &
RESEARCH**

LICENSING PROGRAMME MEMORANDUM

To: Frank Clinton, Programme Manager

From: Michael Martin, Inspector

**ENVIRONMENTAL
LICENSING
PROGRAMME**

Date: 28TH November 2014

RE: Clerical Amendment to Waste Water Discharge Licence number
D0454-01 for the Rockcorry Agglomeration.

Introduction

A Waste Water Discharge Licence was first granted for the Rockcorry agglomeration by the Environmental Protection Agency on the 22nd January 2014. Reg No. D0454-01.

Reason for Clerical Amendment

The reason for the Clerical Amendment is to correct a typographical error that occurred in the final licence document. Change the ELV for pH from 9 to 6-9 in *Schedule A.2: Secondary Waste Water Discharge(s) & Monitoring*.

Recommendation

I recommend that the licence amendment be approved as set out in the attached recommended Clerical Amendment. Such an amendment does not result in the relevant requirements of Regulation 6(3) of the *Waste Water Discharge (Authorisation) Regulations 2007*, (as amended) ceasing to be satisfied.

Signed:

Michael Martin
Inspector
OCLRR - Environmental Licensing Programme