



Headquarters  
P.O. Box 3000  
Johnstown Castle Estate  
County Wexford  
Ireland

## WASTE WATER DISCHARGE LICENCE

### CLERICAL AMENDMENT A

<b>Licence Register Number:</b>	D0454-01
<b>Licensee:</b>	Irish Water
<b>Agglomeration:</b>	Rockcorry

## ***Reasons for the Decision***

The Environmental Protection Agency (the Agency) is satisfied, on the basis of the information available, that subject to compliance with the conditions of licence Reg. No. D0454-01 granted on the 22<sup>nd</sup> January 2014 as well as any amendments noted herein any discharge from the activity will comply with and not contravene any of the requirements of Regulation 6(3) of the Waste Water Discharge (Authorisation) Regulations, 2007, as amended.

## ***Clerical Amendment***

In pursuance of the powers conferred on it by Regulation 33(1)(c) of the Waste Water Discharge (Authorisation) Regulations, 2007, as amended, the Agency amends Licence Reg. No. D0454-01 granted to Irish Water.

Henceforth, the licence shall be read in conjunction with the amendments set out below.

This clerical amendment is limited to Schedule A.2 of Licence Reg. No. D0454-01.

## Amendment

Replace:

### A.2: Secondary Waste Water Discharge(s) & Monitoring

A.2.1 Secondary Waste Water Discharge(s)					
EDEN Code	Licence Code	Discharge Location	Monitoring Location	Receiving Water Name	WFD Code Receiving Water
TPEFF2400D0454SW002	SW002	E 264462 N 318874	E 264467 N 318876	Drumlona River	IE_NW_36_237

Discharge Emission Limit Values and Monitoring							
Discharges					Monitoring		
1	2	3	4	5	6	7	8
Parameter	Units	Interim ELV	ELV	ELV Commencement Date	Monitoring Frequency	Sampling Method	Analysis Method / Technique
Flow	m <sup>3</sup> /24 hours	-	-	-	Continuous	Online	Online Flow Probe Meter with Recorder
pH	pH units	-	9	-	Daily	Composite	pH Meter and recorder
cBOD	mg/l	-	10	-	Bi-monthly	Composite	Standard Method
COD	mg/l	-	100	-	Bi-monthly	Composite	Standard Method
Suspended Solids	mg/l	-	35	-	Bi-monthly	Composite	Standard Method
Ammonia (as N)	mg/l	6	1	31/12/2019	Bi-monthly	Composite	Standard Method
Orthophosphate (as P)	mg/l	1.5	0.7	31/12/2019	Bi-monthly	Composite	Standard Method

With:

**A.2: Secondary Waste Water Discharge(s) & Monitoring**

A.2.1 Secondary Waste Water Discharge(s)					
EDEN Code	Licence Code	Discharge Location	Monitoring Location	Receiving Water Name	WFD Code Receiving Water
TPEFF2400D0454SW002	SW002	E 264462 N 318874	E 264467 N 318876	Drumlona River	IE_NW_36_237

Discharge Emission Limit Values and Monitoring							
1	Discharges				Monitoring		
	2	3	4	5	6	7	8
Parameter	Units	Interim ELV	ELV	ELV Commencement Date	Monitoring Frequency	Sampling Method	Analysis Method/Technique
Flow	m <sup>3</sup> /24 hours	-	-	-	Continuous	Online	Online Flow Probe Meter with Recorder
pH	pH units	-	6-9	-	Daily	Composite	pH Meter and recorder
cBOD	mg/l	-	10	-	Bi-monthly	Composite	Standard Method
COD	mg/l	-	100	-	Bi-monthly	Composite	Standard Method
Suspended Solids	mg/l	-	35	-	Bi-monthly	Composite	Standard Method
Ammonia (as N)	mg/l	6	1	31/12/2019	Bi-monthly	Composite	Standard Method
Orthophosphate (as P)	mg/l	1.5	0.7	31/12/2019	Bi-monthly	Composite	Standard Method

This clerical amendment shall be cited as Clerical Amendment A to Waste Water Discharge Licence Register No. D0454-01 dated 22<sup>nd</sup> January 2014 and is to be read in conjunction with that licence.

**Sealed by the seal of the Agency on this the xx day of xx, xxxx**

**PRESENT when the seal of the Agency  
was affixed hereto:**

\_\_\_\_\_  
xxxxxxxxx  
Authorised Person

