

***Extract from the Minutes of the 978<sup>th</sup> Licensing Meeting of the Agency was held on 15 October 2019, in EPA Headquarters, Johnstown Castle Estate, County Wexford***

1. The 978<sup>th</sup> Licensing Meeting of the Agency was held on 15 October 2019, in EPA Headquarters, Johnstown Castle Estate, County Wexford.

Directors Present: L Burke (Chair);  
G O’Leary, M Crowe, M Lehane & E Cotter.

6. **Objection to a Proposed Determination of an Application for an Industrial Emissions Licence**

*Licensee:* **Starrus Eco Holdings Limited**  
**Rathdrinagh**  
**Beauparc**  
**Navan**  
**County Meath**

*Register of Licence No:* **W0140-05**

The Directors considered the following documentation: Proposed Determination issued on 20 February 2019; one First-Party objection; and the Report and Recommendations of the Technical Committee, Office of Environmental Sustainability.

A copy of the licence application was available electronically.

Anne Lucey and Marie O’Connor gave verbal presentations.

### **Technical Committee Report**

The Directors noted the Technical Committee Report and approved the recommendations of the Technical Committee with the following amendment:

#### ***Conditions***

**3.12** Replace the existing condition to read as follows:

##### **Storm Water Management**

- 3.12.1 Storm water management infrastructure shall be provided and maintained at the installation during any construction works, operation, closure and decommissioning of the installation. As a minimum, the infrastructure shall be capable of the following:-
  - a) the prevention of discharge of contaminated water, process effluent and/or leachate into surface water drains and courses; and
  - b) the collection/diversion of run-off arising from paved areas.
- 3.12.2 All storm water generated, except in the vicinity of Building 4, shall be diverted to the Integrated Constructed Wetland prior to discharge from SW1.
- 3.12.3 The soak pit or percolation area for the treatment of storm water arising in the vicinity of Building 4 shall be designed, built and maintained to satisfy the criteria set out in the UK Building Research Establishment, Soakaway Design, Digest 365 of 2007, or equivalent as agreed by the Agency.
- 3.12.4 The licensee shall provide shut-off valves on discharge lines to surface water.

Following discussion, the Directors decided to grant a licence, as modified, to Starrus Eco Holdings Limited, for their installation located at, Rathdrinagh, Beauparc, Navan, County Meath, Register of Licence No W0140-05, subject to the conditions as set out in the licence.