



Headquarters
P.O. Box 3000
Johnstown Castle Estate
County Wexford
Ireland

WASTE WATER DISCHARGE LICENCE CLERICAL AMENDMENT A

Licence Register Number:	D0545-01
Licensee:	Irish Water
Company Registration Number:	530363
Agglomeration:	Durrus

Reasons for the Decision

The Environmental Protection Agency (the Agency) is satisfied, on the basis of the information available, that subject to compliance with the conditions of Licence Reg. No. D0545-01 granted on 9 January 2019 as well as any amendments noted herein any discharge from the activity will comply with and not contravene any of the requirements of Regulation 6(3) of the Waste Water Discharge (Authorisation) Regulations 2007 as amended.

Clerical Amendment

In pursuance of the powers conferred on it by Regulation 33(1)(a) of the Waste Water Discharge (Authorisation) Regulations 2007 as amended, the Agency amends Licence Reg. No. D0545-01, granted to Irish Water, Colvill House, 24/26 Talbot Street, Dublin 1.

Henceforth, the licence shall be read in conjunction with the amendment set out below.

This Clerical Amendment is limited to the following schedules of Licence Reg. No. D0545-01.

Amendments

Amend Schedule A.1 Primary Waste Water Discharge & Monitoring, of the licence to read as follows:

A.1: Primary Waste Water Discharge & Monitoring

A.1.1 Primary Waste Water Discharge(s)					
EDEN Code	Licence Code	Discharge Location	Monitoring Location	Receiving Water Name	WFD Code Receiving Water
TPEFF3900D0545SW001	SW001	E 094437 N 041831	To be agreed by the Agency as per Condition 4.18	Four Mile Water	IE_SW_21F020500

Discharge Emission Limit Values and Monitoring							
Parameter	Units	Discharges			Monitoring		
		Interim ELV (or Interim % Reduction)	ELV (or % Reduction)	ELV Commencement Date ^{Note 1}	Monitoring Frequency	Sampling Method	Analysis Method / Technique
Flow Rate	<i>m³/24 hours</i>	-	-	-	Continuous	Online	Online Flow Probe Meter with Recorder
pH	<i>pH units</i>	-	6-9	-	Daily	Continuous	pH Meter and recorder
BOD, 5 days with Inhibition (Carbonaceous BOD)	<i>mg/l</i>	-	25	-	bi-monthly	Composite	Standard Method
COD-Cr	<i>mg/l</i>	-	125	-	bi-monthly	Composite	Standard Method
Suspended Solids	<i>mg/l</i>	-	35	-	bi-monthly	Composite	Standard Method
ortho-Phosphate (as P) - unspecified	<i>mg/l</i>	-	9	-	bi-monthly	Composite	Standard Method
Faecal coliforms	<i>cfu/100ml</i>	-	-	-	Biannually	Grab	Standard Method
E. Coli	<i>cfu/100ml</i>	-	-	-	Biannually	Grab	Standard Method
Enterococci (Intestinal)	<i>cfu/100ml</i>	-	-	-	Biannually	Grab	Standard Method
Visual Inspection	<i>Descriptive</i>	-	-	-	Daily	Grab	Standard Method
Temperature	<i>°C</i>	-	-	-	Daily	Online	On Line Temperature probe

Note 1 Where no ELV Commencement Date is specified, the ELV shall apply from date of grant of licence.

Amend Schedule A.3 Storm Water Overflows, of the licence to read as follows:

A.3: Storm Water Overflows

A.3.1 Storm Water Overflows					
EDEN Code	Licence Code	Discharge Location	Storm Water Overflow Location	Name of Receiving Water	WFD Code Receiving Water
TPEFF3900D0545SW002	SW002	E 094437 N 041831	To be agreed by the Agency as per Condition 4.18	Four Mile Water	IE_SW_21F020500

This Clerical Amendment shall be cited as Amendment A to Waste Water Discharge Licence Register No. D0545-01 dated 9 January 2019 and is to be read in conjunction with that licence.

Sealed by the seal of the Agency on this the ** day of ****, 2020**

PRESENT when the seal of the Agency was affixed hereto:

, Authorised Person