



Headquarters
P.O. Box 3000
Johnstown Castle Estate
County Wexford
Ireland

WASTE WATER DISCHARGE LICENCE CLERICAL AMENDMENT A

Licence Register Number:	D0294-02
Licensee:	Irish Water
Company Registration Number:	530363
Agglomeration:	Courtmacsherry and Timoleague

Reasons for the Decision

The Environmental Protection Agency (the Agency) is satisfied, on the basis of the information available, that subject to compliance with the conditions of Licence Reg. No. D0294-02 granted on the 12th April 2018, as well as any amendments noted herein any discharge from the activity will comply with and not contravene any of the requirements of Regulation 6(3) of the Waste Water Discharge (Authorisation) Regulations 2007 as amended.

Clerical Amendment

In pursuance of the powers conferred on it by Regulation 33(1)(a), of the Waste Water Discharge (Authorisation) Regulations 2007 as amended, the Agency amends Licence Reg. No. D0294-02, granted to Irish Water, Colvill House, 24/26 Talbot Street, Dublin 1.

Henceforth, the licence shall be read in conjunction with the amendment set out below.

This clerical amendment is limited to the following Schedules of Licence Reg. No. D0294-02.

Schedules of the licence

Replace Schedule A.1: Primary Waste Water Discharge & Monitoring of the licence to read as follows

A.1: Primary Waste Water Discharge & Monitoring

A.1.1 Primary Waste Water Discharge(s)					
EDEN Code	Licence Code	Discharge Location	Monitoring Location	Receiving Water Name	WFD Code Receiving Water
TPEFF0500D0294SW001	SW001	E 150732 N 42818	E 150566 N 42741	Argideen Estuary	IE_SW_090_0200

Discharge Emission Limit Values and Monitoring							
Parameter	Units	Discharges			Monitoring		
		Interim ELV (or Interim % Reduction)	ELV (or % Reduction)	ELV Commencement Date ^{Note 1}	Monitoring Frequency	Sampling Method	Analysis Method / Technique
Flow Rate	<i>m³/24 hours</i>	-	-	-	Continuous	Online	Online Flow Probe Meter with Recorder
BOD, 5 days with Inhibition (Carbonaceous BOD)	<i>mg/l</i>	-	25	-	Bi-monthly	Composite	Standard Method
COD-Cr	<i>mg/l</i>	-	125	-	Bi-monthly	Composite	Standard Method
Suspended Solids	<i>mg/l</i>	-	35	-	Bi-monthly	Composite	Standard Method
Total Oxidised Nitrogen (as N)	<i>mg/l</i>	-	15	01/01/2020	Bi-monthly	Composite	Standard Method
Ammonia-Total (as N)	<i>mg/l</i>	-	10	01/01/2020	Bi-monthly	Composite	Standard Method
Ortho-Phosphate (as P) - unspecified	<i>mg/l</i>	-	8	01/01/2020	Bi-monthly	Composite	Standard Method
Faecal coliforms	<i>cfu/100ml</i>	-	-	-	Biannually	Grab	Standard Method
E. Coli	<i>cfu/100ml</i>	-	-	-	Biannually	Grab	Standard Method
Enterococci (Intestinal)	<i>cfu/100ml</i>	-	-	-	Biannually	Grab	Standard Method
Visual Inspection	<i>Descriptive</i>	-	-	-	Daily	Grab	Standard Method

Note 1 Where no ELV Commencement Date is specified, the ELV shall apply from date of grant of licence.

Replace Schedule A.2: Secondary Waste Water Discharge(s) & Monitoring, of the licence to read as follows

A.2: Secondary Waste Water Discharge(s) & Monitoring

A.2.1 Secondary Waste Water Discharge(s)					
EDEN Code	Licence Code	Discharge Location	Monitoring Location	Receiving Water Name	WFD Code Receiving Water
TPEFF0500D0294SW006	SW006	E 150106 N 42711	To be agreed by the Agency	Argideen Estuary	IE_SW_090_0200
TPEFF0500D0294SW007	SW007	E 147200 N 43523	To be agreed by the Agency	Argideen Estuary	IE_SW_090_0200
TPEFF0500D0294SW008	SW008	E 147132 N 43496	To be agreed by the Agency	Argideen Estuary	IE_SW_090_0200
TPEFF0500D0294SW009	SW009	E 147141 N 43507	To be agreed by the Agency	Argideen Estuary	IE_SW_090_0200
TPEFF0500D0294SW010	SW010	E 147209 N 43702	To be agreed by the Agency	Argideen Estuary	IE_SW_090_0200
TPEFF0500D0294SW011	SW011	E 147176 N 43789	To be agreed by the Agency	Argideen Estuary	IE_SW_090_0200

Discharge Emission Limit Values and Monitoring							
Parameter	Units	Discharges			Monitoring		
		Interim ELV (or Interim % Reduction)	ELV (or % Reduction)	ELV Commencement Date ^{Note 1}	Monitoring Frequency	Sampling Method	Analysis Method / Technique
Flow Rate	<i>m³/24 hours</i>	-	-	-	Continuous	Online	Online Flow Probe Meter with Recorder
BOD, 5 days with Inhibition (Carbonaceous BOD)	<i>mg/l</i>	-	25	-	Bi-monthly	Composite	Standard Method
COD-Cr	<i>mg/l</i>	-	125	-	Bi-monthly	Composite	Standard Method
Suspended Solids	<i>mg/l</i>	-	35	-	Bi-monthly	Composite	Standard Method
Visual Inspection	<i>Descriptive</i>	-	-	-	Weekly	Grab	Standard Method

Note 1 Where no ELV Commencement Date is specified, the ELV shall apply from date of grant of licence.

Replace Schedule A.3: Storm Water Overflows, of the licence to read as follows

A.3: Storm Water Overflows

A.3.1 Storm Water Overflows					
EDEN Code	Licence Code	Discharge Location	Storm Water Overflow Location	Name of Receiving Water	WFD Code Receiving Water
TPEFF0500D0294SW002	SW002	E 150732 N 42818	To be confirmed by licensee	Argideen Estuary	IE_SW_090_0200
TPEFF0500D0294SW003	SW003	E 151498 N 42565	To be confirmed by licensee	Argideen Estuary	IE_SW_090_0200
TPEFF0500D0294SW004	SW004	E 150038 N 42674	To be confirmed by licensee	Argideen Estuary	IE_SW_090_0200
TPEFF0500D0294SW005	SW005	E 147090 N 43460	To be confirmed by licensee	Argideen Estuary	IE_SW_090_0200

This clerical amendment shall be cited as Amendment A to Waste Water Discharge Licence Register No. D0294-02 dated April 12th 2018 and is to be read in conjunction with that licence.

Sealed by the seal of the Agency on this the** day of ****, 20XX**

PRESENT when the seal of the Agency was affixed hereto:

, Authorised Person