Waste Water Discharge Authorisation (WWDA) Examination Report Part 1 Inspector's Name Date of examination Agglomeration Name Authorisation Reg No Receiving Waterbody Name and WFD Code 27th July 2010

Part 2

An examination has been carried of the WWDA and relevant information. The following action is recommended:

	Tick one
No Further Action	
Amend the WWDA	
Review the WWDA	Х
The conclusion of the examination is as follows:	
	Tick one
the state of the s	

	Tick one
It is considered that the WWDA satisfies the environmental	
requirements of the WWDA 2007 regulations as amended.	
It is considered that the WWDA does not satisfy the environmental	Х
requirements of the WWDA 2007 regulations as amended.	

The reasons for this conclusion and recommendation are summarised as follows:

- 1. The licence was granted over 3 years ago.
- 2. There has been a material change in the content or extent of the discharge to which the licence relates, as a result of additional storm water overflows since the grant of the licence.
- 3. Planning permission has been granted for development works associated with the licence
- 4. The agglomeration is included in Irish Water's investment plan.
- 5. Non-compliance with:

Final Decision Issue Date

- Upgrade of the waste water treatment plant and ancillary works, as set out in Schedule C: Specified Improvement Programme, by 22/12/2015;
- Upgrade of the storm water tank at the waste water treatment plant, as set out in Schedule C: Specified Improvement Programme, by 22/12/2015;
- Emission limit values in Schedule A: Discharges and Discharge Monitoring.