

## Waste Water Discharge Authorisation (WWDA) Examination Report

### Part 1

Inspector's Name	Christine Murphy
Date of examination	30 <sup>th</sup> June 2021
Agglomeration Name	Mallow
Authorisation Reg No	D0052-01
Receiving Waterbody Name and WFD Code	Blackwater (Munster)_140 IE_SW_18B021720
Final Decision Issue Date	18/12/2012

### Part 2

An examination has been carried of the WWDA and relevant information. The following action is recommended:

	Tick one
No Further Action	
Amend the WWDA	
Review the WWDA	✓

The conclusion of the examination is as follows:

	Tick one
It is considered that the WWDA <b>satisfies</b> the environmental requirements of the WWDA 2007 regulations as amended.	
It is considered that the WWDA <b>does not satisfy</b> the environmental requirements of the WWDA 2007 regulations as amended.	✓

The reasons for this conclusion and recommendation are summarised as follows:

1. The licence was granted over 3 years ago.
2. Planning permission has been granted for proposed development works associated with the licence.
3. The agglomeration is included in Irish Water's investment plan.
4. Non-compliance with:
  - Upgrade of the sewerage network, as set out in Schedule C: Specified Improvement Programme, by 01/06/2016;
  - Installation of a pumping station overflow holding tank, as set out in Schedule C: Specified Improvement Programme, by 01/06/2016; and
  - Discontinuation of storm water overflow discharges, as set out in Schedule C: Specified Improvement Programme, of this licence, by 01/06/2016.