

Waste Water Discharge Authorisation (WWDA) Examination Report

Part 1

Inspector's Name	Christine Murphy
Date of examination	28 th June 2021
Agglomeration Name	Dripsey
Authorisation Reg No	D0426-01
Receiving Waterbody Name and WFD Code	DRIPSEY_020 - IE_SW_19D060400
Final Decision Issue Date	30 th July 2012

Part 2

An examination has been carried of the WWDA and relevant information. The following action is recommended:

	Tick one
No Further Action	
Amend the WWDA	
Review the WWDA	X

The conclusion of the examination is as follows:

	Tick one
It is considered that the WWDA satisfies the environmental requirements of the WWDA 2007 regulations as amended.	
It is considered that the WWDA does not satisfy the environmental requirements of the WWDA 2007 regulations as amended.	X

The reasons for this conclusion and recommendation are summarised as follows:

1. The licence was granted over 3 years ago.
2. Planning permission has been granted for proposed development works associated with the licence.
3. Non- compliance with completion of the improvements (infiltration programme/remediation) as set out in Schedule C: Specified Improvement Programme, of this licence, by 31/12/2014.