

Appendix 3

Water Quality Results

*For inspection purposes only.
Consent of copyright owner required for any other use.*



2017 (September) Sample Analysis carried out by GWS

Sample Id	Sample Description
6341J01	T10:05AM; NEW INN GWS
Potassium - mg/l	3.11
Clostridium Perfringens - cfu/100ml	0
Magnesium - mg/l	5.08
Manganese - ug/l	<20
Sodium - mg/l	5.08
Ammonium - mg/l NH4	0.05
Nickel - ug/l	<20
Nitrite - mg/l NO2	<0.03
Nitrate - mg/l NO3	13.02
P Orthophosphate - mg/l P	0.04
Dissolved Oxygen - mg/l O2	8.75
Lead - ug/l	<20
pH - pH units	6.9
Silica - mg/l	7.2
Sulphate - mg/l SO4	19.78
Strontium - ug/l	<10
Total Coliforms - MPN/100ml	15
Total Organic Carbon - mg/l	2.9
Turbidity - NTU	<0.02
Zinc - ug/l	24

For inspection purposes only.
 Consent of copyright owner required for any other use.

2012-2017 Check Monitoring Results from DBO Operator, Coffey Water, contained in Monthly Status Reports

Sample Description	Date	Test Name	Result	Units
Raw Water 15211 - 348	03/10/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 350	07/11/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 352	03/12/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 354	15/01/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 356	04/02/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 358	05/03/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 360	02/04/2014	Clostridium Perfringens in Water	3	cfu/100ml
Raw Water 15211 - 362	07/05/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 364	11/06/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 366	17/07/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 368	07/08/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 370	11/09/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 372	15/10/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 374	19/11/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 376	02/12/2014	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 378	27/01/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 380	11/02/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 382	04/03/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 384	09/04/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 386	13/05/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 388	04/06/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 390	02/07/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 392	12/08/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 394	09/09/2015	Clostridium Perfringens in Water	0	cfu/100ml

Raw Water 15211 - 396	08/10/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 398	25/11/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 400	09/12/2015	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 402	20/01/2016	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 404	10/02/2016	Clostridium Perfringens in Water	3	cfu/100ml
Raw Water 15211 - 406	15/03/2016	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 408	06/04/2016	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 410	12/05/2016	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 412	09/06/2016	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 414	14/07/2016	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 440	09/08/2017	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 319	14/08/2012	Clostridium Perfringens in Water	1	cfu/100ml
Raw Water 15211- 321	12/09/2012	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 321	20/08/2012	Clostridium Perfringens in Water	1	cfu/100ml
Raw Water 15211- 323	02/10/2012	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 326	01/11/2012	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 328	06/12/2012	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 330	08/01/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 332	06/02/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 334	05/03/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 336	09/04/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 338	08/05/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 340	05/06/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 342	10/07/2013	Clostridium Perfringens in Water	1	cfu/100ml
Raw Water 15211- 344	01/08/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 346	10/09/2013	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211- 436	15/06/2017	Clostridium Perfringens in Water	2	cfu/100ml

Consent for use is restricted to purposes only. No consent for any other use.

Raw Water 15211-416	11/08/2016	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211-418	15/09/2016	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211-420	12/10/2016	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211-422	09/11/2016	Clostridium Perfringens in Water	1	cfu/100ml
Raw Water 15211-424	02/12/2016	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211-426	13/01/2017	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211-428	15/02/2017	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211-430	20/03/2017	Clostridium Perfringens in Water	3	cfu/100ml
Raw Water 15211-432	06/04/2017	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211-434	10/05/2017	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211-438	12/07/2017	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 413	09/06/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 415	14/07/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-419	15/09/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-439	12/07/2017	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 325	05/10/2012	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 349	03/10/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 351	07/11/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 353	03/12/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 355	15/01/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 357	04/02/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 359	05/03/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 361	02/04/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 363	07/05/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 365	11/06/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 367	17/07/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 369	07/08/2014	Clostridium Perfringens in Water	0	cfu/100ml

Consent is required for any other use.

Treated Water 15211 - 371	11/09/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 373	15/10/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 375	19/11/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 377	02/12/2014	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 379	27/01/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 381	11/02/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 383	04/03/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 385	09/04/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 387	13/05/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 389	04/06/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 391	02/07/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 393	12/08/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 395	09/09/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 399	25/11/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 401	09/12/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 403	20/01/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 405	10/02/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 407	15/03/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 409	06/04/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 411	12/05/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211 - 441	09/08/2017	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 320	14/08/2012	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 322	12/09/2012	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 322	20/08/2012	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 324	02/10/2012	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 327	01/11/2012	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 329	06/12/2012	Clostridium Perfringens in Water	0	cfu/100ml

Consent to publish this report for research purposes only. Not for distribution or use for any other use.

Treated Water 15211- 331	08/01/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 333	06/02/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 335	05/03/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 337	09/04/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 339	08/05/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 341	05/06/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 343	10/07/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 345	01/08/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 347	10/09/2013	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 397	08/10/2015	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211- 437	15/06/2017	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-417	11/08/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-421	12/10/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-423	09/11/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-425	02/12/2016	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-427	13/01/2017	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-429	15/02/2017	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-430	22/02/2017	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-431	20/03/2017	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-433	06/04/2017	Clostridium Perfringens in Water	0	cfu/100ml
Treated Water 15211-435	10/05/2017	Clostridium Perfringens in Water	0	cfu/100ml
Raw Water 15211 - 348	03/10/2013	Colilert (Ecoli)	8	MPN/100ml
Raw Water 15211 - 350	07/11/2013	Colilert (Ecoli)	8	MPN/100ml
Raw Water 15211 - 352	03/12/2013	Colilert (Ecoli)	34	MPN/100ml
Raw Water 15211 - 354	15/01/2014	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 356	04/02/2014	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 358	05/03/2014	Colilert (Ecoli)	6	MPN/100ml

Raw Water 15211 - 360	02/04/2014	Colilert (Ecoli)	9	MPN/100ml
Raw Water 15211 - 362	07/05/2014	Colilert (Ecoli)	8	MPN/100ml
Raw Water 15211 - 364	11/06/2014	Colilert (Ecoli)	5	MPN/100ml
Raw Water 15211 - 366	17/07/2014	Colilert (Ecoli)	3	MPN/100ml
Raw Water 15211 - 368	07/08/2014	Colilert (Ecoli)	1	MPN/100ml
Raw Water 15211 - 370	11/09/2014	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 372	15/10/2014	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 374	19/11/2014	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 376	02/12/2014	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 378	27/01/2015	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 380	11/02/2015	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 382	04/03/2015	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 384	09/04/2015	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 386	13/05/2015	Colilert (Ecoli)	1	MPN/100ml
Raw Water 15211 - 388	04/06/2015	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 390	02/07/2015	Colilert (Ecoli)	3	MPN/100ml
Raw Water 15211 - 392	12/08/2015	Colilert (Ecoli)	2	MPN/100ml
Raw Water 15211 - 394	09/09/2015	Colilert (Ecoli)	2	MPN/100ml
Raw Water 15211 - 396	08/10/2015	Colilert (Ecoli)	2	MPN/100ml
Raw Water 15211 - 398	25/11/2015	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 400	09/12/2015	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 402	20/01/2016	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 404	10/02/2016	Colilert (Ecoli)	1	MPN/100ml
Raw Water 15211 - 406	15/03/2016	Colilert (Ecoli)	2	MPN/100ml
Raw Water 15211 - 408	06/04/2016	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 410	12/05/2016	Colilert (Ecoli)	1	MPN/100ml
Raw Water 15211 - 412	09/06/2016	Colilert (Ecoli)	0	MPN/100ml

Content not for inspection purposes only.
 Copyright owner required for any other use.

Raw Water 15211 - 414	14/07/2016	Colilert (Ecoli)	1	MPN/100ml
Raw Water 15211 - 440	09/08/2017	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211- 319	14/08/2012	Colilert (Ecoli)	165	MPN/100ml
Raw Water 15211- 321	12/09/2012	Colilert (Ecoli)	>201	MPN/100ml
Raw Water 15211- 321	20/08/2012	Colilert (Ecoli)	1	MPN/100ml
Raw Water 15211- 323	02/10/2012	Colilert (Ecoli)	9	MPN/100ml
Raw Water 15211- 326	01/11/2012	Colilert (Ecoli)	1	MPN/100ml
Raw Water 15211- 328	06/12/2012	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211- 330	08/01/2013	Colilert (Ecoli)	66	MPN/100ml
Raw Water 15211- 332	06/02/2013	Colilert (Ecoli)	2	MPN/100ml
Raw Water 15211- 334	05/03/2013	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211- 336	09/04/2013	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211- 338	08/05/2013	Colilert (Ecoli)	4	MPN/100ml
Raw Water 15211- 340	05/06/2013	Colilert (Ecoli)	165	MPN/100ml
Raw Water 15211- 342	10/07/2013	Colilert (Ecoli)	29	MPN/100ml
Raw Water 15211- 344	01/08/2013	Colilert (Ecoli)	10	MPN/100ml
Raw Water 15211- 346	10/09/2013	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211- 436	15/06/2017	Colilert (Ecoli)	3	MPN/100ml
Raw Water 15211-416	11/08/2016	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211-418	15/09/2016	Colilert (Ecoli)	3	MPN/100ml
Raw Water 15211-420	12/10/2016	Colilert (Ecoli)	1	MPN/100ml
Raw Water 15211-422	09/11/2016	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211-424	02/12/2016	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211-426	13/01/2017	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211-428	15/02/2017	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211-430	20/03/2017	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211-432	06/04/2017	Colilert (Ecoli)	0	MPN/100ml

Content not for inspection purposes only.
 Copyright owner required for any other use.

Raw Water 15211-434	10/05/2017	Colilert (Ecoli)	1	MPN/100ml
Raw Water 15211-438	12/07/2017	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 413	09/06/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 415	14/07/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-419	15/09/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-439	12/07/2017	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 325	05/10/2012	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 349	03/10/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 351	07/11/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 353	03/12/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 355	15/01/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 357	04/02/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 359	05/03/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 361	02/04/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 363	07/05/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 365	11/06/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 367	17/07/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 369	07/08/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 371	11/09/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 373	15/10/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 375	19/11/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 377	02/12/2014	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 379	27/01/2015	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 381	11/02/2015	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 383	04/03/2015	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 385	09/04/2015	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 387	13/05/2015	Colilert (Ecoli)	0	MPN/100ml

Content not for inspection purposes only.
 Consent to publish required for any other use.

Treated Water 15211 - 389	04/06/2015	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 391	02/07/2015	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 393	12/08/2015	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 395	09/09/2015	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 399	25/11/2015	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 401	09/12/2015	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 403	20/01/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 405	10/02/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 407	15/03/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 409	06/04/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 411	12/05/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211 - 441	09/08/2017	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 322	12/09/2012	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 322	20/08/2012	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 324	02/10/2012	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 327	01/11/2012	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 329	06/12/2012	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 331	08/01/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 333	06/02/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 335	05/03/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 337	09/04/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 339	08/05/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 341	05/06/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 343	10/07/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 345	01/08/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 347	10/09/2013	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211- 397	08/10/2015	Colilert (Ecoli)	0	MPN/100ml

Content not for inspection purposes only.
 Consent to publish required for any other use.

Treated Water 15211- 437	15/06/2017	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-417	11/08/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-421	12/10/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-423	09/11/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-425	02/12/2016	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-427	13/01/2017	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-429	15/02/2017	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-430	22/02/2017	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-431	20/03/2017	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-433	06/04/2017	Colilert (Ecoli)	0	MPN/100ml
Treated Water 15211-435	10/05/2017	Colilert (Ecoli)	0	MPN/100ml
Raw Water 15211 - 348	03/10/2013	Colilert (Total Coliforms)	109	MPN/100ml
Raw Water 15211 - 350	07/11/2013	Colilert (Total Coliforms)	165	MPN/100ml
Raw Water 15211 - 352	03/12/2013	Colilert (Total Coliforms)	101	MPN/100ml
Raw Water 15211 - 354	15/01/2014	Colilert (Total Coliforms)	12	MPN/100ml
Raw Water 15211 - 356	04/02/2014	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211 - 358	05/03/2014	Colilert (Total Coliforms)	34	MPN/100ml
Raw Water 15211 - 360	02/04/2014	Colilert (Total Coliforms)	21	MPN/100ml
Raw Water 15211 - 362	07/05/2014	Colilert (Total Coliforms)	12	MPN/100ml
Raw Water 15211 - 364	11/06/2014	Colilert (Total Coliforms)	41	MPN/100ml
Raw Water 15211 - 366	17/07/2014	Colilert (Total Coliforms)	9	MPN/100ml
Raw Water 15211 - 368	07/08/2014	Colilert (Total Coliforms)	6	MPN/100ml
Raw Water 15211 - 370	11/09/2014	Colilert (Total Coliforms)	1	MPN/100ml
Raw Water 15211 - 372	15/10/2014	Colilert (Total Coliforms)	6	MPN/100ml
Raw Water 15211 - 374	19/11/2014	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211 - 376	02/12/2014	Colilert (Total Coliforms)	10	MPN/100ml
Raw Water 15211 - 378	27/01/2015	Colilert (Total Coliforms)	1	MPN/100ml

Consent to publish information for public purposes only.
 Consent to publish information required for any other use.

Raw Water 15211 - 380	11/02/2015	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211 - 382	04/03/2015	Colilert (Total Coliforms)	9	MPN/100ml
Raw Water 15211 - 384	09/04/2015	Colilert (Total Coliforms)	10	MPN/100ml
Raw Water 15211 - 386	13/05/2015	Colilert (Total Coliforms)	5	MPN/100ml
Raw Water 15211 - 388	04/06/2015	Colilert (Total Coliforms)	1	MPN/100ml
Raw Water 15211 - 390	02/07/2015	Colilert (Total Coliforms)	6	MPN/100ml
Raw Water 15211 - 392	12/08/2015	Colilert (Total Coliforms)	2	MPN/100ml
Raw Water 15211 - 394	09/09/2015	Colilert (Total Coliforms)	12	MPN/100ml
Raw Water 15211 - 396	08/10/2015	Colilert (Total Coliforms)	4	MPN/100ml
Raw Water 15211 - 398	25/11/2015	Colilert (Total Coliforms)	3	MPN/100ml
Raw Water 15211 - 400	09/12/2015	Colilert (Total Coliforms)	3	MPN/100ml
Raw Water 15211 - 402	20/01/2016	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211 - 404	10/02/2016	Colilert (Total Coliforms)	2	MPN/100ml
Raw Water 15211 - 406	15/03/2016	Colilert (Total Coliforms)	2	MPN/100ml
Raw Water 15211 - 408	06/04/2016	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211 - 410	12/05/2016	Colilert (Total Coliforms)	3	MPN/100ml
Raw Water 15211 - 412	09/06/2016	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211 - 414	14/07/2016	Colilert (Total Coliforms)	5	MPN/100ml
Raw Water 15211 - 440	09/08/2017	Colilert (Total Coliforms)	1	MPN/100ml
Raw Water 15211- 319	14/08/2012	Colilert (Total Coliforms)	>201	MPN/100ml
Raw Water 15211- 321	12/09/2012	Colilert (Total Coliforms)	>201	MPN/100ml
Raw Water 15211- 321	20/08/2012	Colilert (Total Coliforms)	22	MPN/100ml
Raw Water 15211- 323	02/10/2012	Colilert (Total Coliforms)	66	MPN/100ml
Raw Water 15211- 326	01/11/2012	Colilert (Total Coliforms)	9	MPN/100ml
Raw Water 15211- 328	06/12/2012	Colilert (Total Coliforms)	1	MPN/100ml
Raw Water 15211- 330	08/01/2013	Colilert (Total Coliforms)	165	MPN/100ml
Raw Water 15211- 332	06/02/2013	Colilert (Total Coliforms)	4	MPN/100ml

Consent to publish information for public purposes only.
 Consent to publish information is required for any other use.

Raw Water 15211- 334	05/03/2013	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211- 336	09/04/2013	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211- 338	08/05/2013	Colilert (Total Coliforms)	74	MPN/100ml
Raw Water 15211- 340	05/06/2013	Colilert (Total Coliforms)	201	MPN/100ml
Raw Water 15211- 342	10/07/2013	Colilert (Total Coliforms)	165	MPN/100ml
Raw Water 15211- 344	01/08/2013	Colilert (Total Coliforms)	145	MPN/100ml
Raw Water 15211- 346	10/09/2013	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211- 436	15/06/2017	Colilert (Total Coliforms)	18	MPN/100ml
Raw Water 15211-416	11/08/2016	Colilert (Total Coliforms)	4	MPN/100ml
Raw Water 15211-418	15/09/2016	Colilert (Total Coliforms)	24	MPN/100ml
Raw Water 15211-420	12/10/2016	Colilert (Total Coliforms)	3	MPN/100ml
Raw Water 15211-422	09/11/2016	Colilert (Total Coliforms)	3	MPN/100ml
Raw Water 15211-424	02/12/2016	Colilert (Total Coliforms)	4	MPN/100ml
Raw Water 15211-426	13/01/2017	Colilert (Total Coliforms)	48	MPN/100ml
Raw Water 15211-428	15/02/2017	Colilert (Total Coliforms)	3	MPN/100ml
Raw Water 15211-430	20/03/2017	Colilert (Total Coliforms)	3	MPN/100ml
Raw Water 15211-432	06/04/2017	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211-434	10/05/2017	Colilert (Total Coliforms)	1	MPN/100ml
Raw Water 15211-438	12/07/2017	Colilert (Total Coliforms)	1	MPN/100ml
Treated Water 15211 - 413	09/06/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 415	14/07/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-419	15/09/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-439	12/07/2017	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 325	05/10/2012	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 349	03/10/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 351	07/11/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 353	03/12/2013	Colilert (Total Coliforms)	0	MPN/100ml

Consent to publish information for public purposes only.
 Consent to publish information required for any other use.

Treated Water 15211 - 355	15/01/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 357	04/02/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 359	05/03/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 361	02/04/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 363	07/05/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 365	11/06/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 367	17/07/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 369	07/08/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 371	11/09/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 373	15/10/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 375	19/11/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 377	02/12/2014	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 379	27/01/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 381	11/02/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 383	04/03/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 385	09/04/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 387	13/05/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 389	04/06/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 391	02/07/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 393	12/08/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 395	09/09/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 399	25/11/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 401	09/12/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 403	20/01/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 405	10/02/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 407	15/03/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 409	06/04/2016	Colilert (Total Coliforms)	0	MPN/100ml

Consent to publish information for public purposes only.
 Consent to publish information is required for any other use.

Treated Water 15211 - 411	12/05/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211 - 441	09/08/2017	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 322	12/09/2012	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 322	20/08/2012	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 327	01/11/2012	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 329	06/12/2012	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 331	08/01/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 333	06/02/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 335	05/03/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 337	09/04/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 339	08/05/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 341	05/06/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 343	10/07/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 345	01/08/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 347	10/09/2013	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 397	08/10/2015	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211- 437	15/06/2017	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-417	11/08/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-421	12/10/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-423	09/11/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-425	02/12/2016	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-427	13/01/2017	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-430	22/02/2017	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-431	20/03/2017	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-433	06/04/2017	Colilert (Total Coliforms)	0	MPN/100ml
Treated Water 15211-435	10/05/2017	Colilert (Total Coliforms)	0	MPN/100ml
Raw Water 15211 - 348	03/10/2013	Colour	9.6	mg/l Pt Co

Consent to publish this information for public purposes only.
 Consent to publish this information is required for any other use.

Raw Water 15211 - 350	07/11/2013	Colour	10.1	mg/l Pt Co
Raw Water 15211 - 352	03/12/2013	Colour	7.5	mg/l Pt Co
Raw Water 15211 - 354	15/01/2014	Colour	4.1	mg/l Pt Co
Raw Water 15211 - 356	04/02/2014	Colour	4.7	mg/l Pt Co
Raw Water 15211 - 358	05/03/2014	Colour	<4	mg/l Pt Co
Raw Water 15211 - 360	02/04/2014	Colour	<4	mg/l Pt Co
Raw Water 15211 - 362	07/05/2014	Colour	<4	mg/l Pt Co
Raw Water 15211 - 364	11/06/2014	Colour	7	mg/l Pt Co
Raw Water 15211 - 366	17/07/2014	Colour	6.1	mg/l Pt Co
Raw Water 15211 - 368	07/08/2014	Colour	6.7	mg/l Pt Co
Raw Water 15211 - 370	11/09/2014	Colour	9.2	mg/l Pt Co
Raw Water 15211 - 372	15/10/2014	Colour	10.8	mg/l Pt Co
Raw Water 15211 - 374	19/11/2014	Colour	6.7	mg/l Pt Co
Raw Water 15211 - 376	02/12/2014	Colour	5.4	mg/l Pt Co
Raw Water 15211 - 378	27/01/2015	Colour	5	mg/l Pt Co
Raw Water 15211 - 380	11/02/2015	Colour	4.7	mg/l Pt Co
Raw Water 15211 - 382	04/03/2015	Colour	5.9	mg/l Pt Co
Raw Water 15211 - 384	09/04/2015	Colour	4.6	mg/l Pt Co
Raw Water 15211 - 386	13/05/2015	Colour	<4	mg/l Pt Co
Raw Water 15211 - 388	04/06/2015	Colour	5.7	mg/l Pt Co
Raw Water 15211 - 390	02/07/2015	Colour	8.4	mg/l Pt Co
Raw Water 15211 - 392	12/08/2015	Colour	7.7	mg/l Pt Co
Raw Water 15211 - 394	09/09/2015	Colour	5.8	mg/l Pt Co
Raw Water 15211 - 396	08/10/2015	Colour	7.7	mg/l Pt Co
Raw Water 15211 - 398	25/11/2015	Colour	4.6	mg/l Pt Co
Raw Water 15211 - 400	09/12/2015	Colour	<4	mg/l Pt Co
Raw Water 15211 - 402	20/01/2016	Colour	<4	mg/l Pt Co

Consent of copy right owner required for any other use.

Raw Water 15211 - 404	10/02/2016	Colour	6.3	mg/l Pt Co
Raw Water 15211 - 406	15/03/2016	Colour	4.9	mg/l Pt Co
Raw Water 15211 - 408	06/04/2016	Colour	<4	mg/l Pt Co
Raw Water 15211 - 410	12/05/2016	Colour	<4	mg/l Pt Co
Raw Water 15211 - 412	09/06/2016	Colour	<4	mg/l Pt Co
Raw Water 15211 - 414	14/07/2016	Colour	7.8	mg/l Pt Co
Raw Water 15211- 319	14/08/2012	Colour	6.8	mg/l Pt Co
Raw Water 15211- 321	12/09/2012	Colour	4.8	mg/l Pt Co
Raw Water 15211- 323	02/10/2012	Colour	7.5	mg/l Pt Co
Raw Water 15211- 326	01/11/2012	Colour	5.5	mg/l Pt Co
Raw Water 15211- 328	06/12/2012	Colour	5.2	mg/l Pt Co
Raw Water 15211- 330	08/01/2013	Colour	<4	mg/l Pt Co
Raw Water 15211- 332	06/02/2013	Colour	7.3	mg/l Pt Co
Raw Water 15211- 334	05/03/2013	Colour	4.4	mg/l Pt Co
Raw Water 15211- 336	09/04/2013	Colour	4.4	mg/l Pt Co
Raw Water 15211- 338	08/05/2013	Colour	5.9	mg/l Pt Co
Raw Water 15211- 340	05/06/2013	Colour	5	mg/l Pt Co
Raw Water 15211- 342	10/07/2013	Colour	8.5	mg/l Pt Co
Raw Water 15211- 344	01/08/2013	Colour	7.7	mg/l Pt Co
Raw Water 15211- 346	10/09/2013	Colour	8.3	mg/l Pt Co
Raw Water 15211-418	15/09/2016	Colour	5.7	mg/l Pt Co
Raw Water 15211-420	12/10/2016	Colour	<4	mg/l Pt Co
Raw Water 15211-422	09/11/2016	Colour	6.9	mg/l Pt Co
Treated Water 15211 - 413	09/06/2016	Colour	<4	mg/l Pt Co
Treated Water 15211 - 415	14/07/2016	Colour	<4	mg/l Pt Co
Treated Water 15211-419	15/09/2016	Colour	<4	mg/l Pt Co
Treated Water 15211 - 349	03/10/2013	Colour	8	mg/l Pt Co

Consent is for inspection purposes only. No right of copy or reuse required for any other use.

Treated Water 15211 - 351	07/11/2013	Colour	8.2	mg/l Pt Co
Treated Water 15211 - 353	03/12/2013	Colour	4.9	mg/l Pt Co
Treated Water 15211 - 355	15/01/2014	Colour	<4	mg/l Pt Co
Treated Water 15211 - 357	04/02/2014	Colour	<4	mg/l Pt Co
Treated Water 15211 - 359	05/03/2014	Colour	<4	mg/l Pt Co
Treated Water 15211 - 361	02/04/2014	Colour	<4	mg/l Pt Co
Treated Water 15211 - 363	07/05/2014	Colour	<4	mg/l Pt Co
Treated Water 15211 - 365	11/06/2014	Colour	12.8	mg/l Pt Co
Treated Water 15211 - 367	17/07/2014	Colour	4.8	mg/l Pt Co
Treated Water 15211 - 369	07/08/2014	Colour	5.6	mg/l Pt Co
Treated Water 15211 - 371	11/09/2014	Colour	<4	mg/l Pt Co
Treated Water 15211 - 373	15/10/2014	Colour	5.9	mg/l Pt Co
Treated Water 15211 - 375	19/11/2014	Colour	4.6	mg/l Pt Co
Treated Water 15211 - 377	02/12/2014	Colour	<4	mg/l Pt Co
Treated Water 15211 - 379	27/01/2015	Colour	<4	mg/l Pt Co
Treated Water 15211 - 381	11/02/2015	Colour	<4	mg/l Pt Co
Treated Water 15211 - 383	04/03/2015	Colour	<4	mg/l Pt Co
Treated Water 15211 - 385	09/04/2015	Colour	<4	mg/l Pt Co
Treated Water 15211 - 387	13/05/2015	Colour	<4	mg/l Pt Co
Treated Water 15211 - 389	04/06/2015	Colour	7.1	mg/l Pt Co
Treated Water 15211 - 391	02/07/2015	Colour	<4	mg/l Pt Co
Treated Water 15211 - 393	12/08/2015	Colour	<4	mg/l Pt Co
Treated Water 15211 - 395	09/09/2015	Colour	5.1	mg/l Pt Co
Treated Water 15211 - 399	25/11/2015	Colour	<4	mg/l Pt Co
Treated Water 15211 - 401	09/12/2015	Colour	<4	mg/l Pt Co
Treated Water 15211 - 403	20/01/2016	Colour	<4	mg/l Pt Co
Treated Water 15211 - 405	10/02/2016	Colour	<4	mg/l Pt Co

Consent for inspection purposes only. No copy right owner required for any other use.

Treated Water 15211 - 407	15/03/2016	Colour	<4	mg/l Pt Co
Treated Water 15211 - 409	06/04/2016	Colour	<4	mg/l Pt Co
Treated Water 15211 - 411	12/05/2016	Colour	<4	mg/l Pt Co
Treated Water 15211- 320	14/08/2012	Colour	<4	mg/l Pt Co
Treated Water 15211- 322	12/09/2012	Colour	<4	mg/l Pt Co
Treated Water 15211- 324	02/10/2012	Colour	<4	mg/l Pt Co
Treated Water 15211- 327	01/11/2012	Colour	<4	mg/l Pt Co
Treated Water 15211- 329	06/12/2012	Colour	<4	mg/l Pt Co
Treated Water 15211- 331	08/01/2013	Colour	<4	mg/l Pt Co
Treated Water 15211- 333	06/02/2013	Colour	<4	mg/l Pt Co
Treated Water 15211- 335	05/03/2013	Colour	<4	mg/l Pt Co
Treated Water 15211- 337	09/04/2013	Colour	<4	mg/l Pt Co
Treated Water 15211- 339	08/05/2013	Colour	4	mg/l Pt Co
Treated Water 15211- 341	05/06/2013	Colour	<4	mg/l Pt Co
Treated Water 15211- 343	10/07/2013	Colour	5.6	mg/l Pt Co
Treated Water 15211- 345	01/08/2013	Colour	6.3	mg/l Pt Co
Treated Water 15211- 347	10/09/2013	Colour	6.6	mg/l Pt Co
Treated Water 15211- 397	08/10/2015	Colour	<4	mg/l Pt Co
Treated Water 15211-421	12/10/2016	Colour	<4	mg/l Pt Co
Treated Water 15211-423	09/11/2016	Colour	<4	mg/l Pt Co
Raw Water 15211 - 440	09/08/2017	Colour, apparent	6	mg/l Pt Co
Raw Water 15211- 436	15/06/2017	Colour, apparent	10.4	mg/l Pt Co
Raw Water 15211-416	11/08/2016	Colour, apparent	<4	mg/l Pt Co
Raw Water 15211-424	02/12/2016	Colour, apparent	6.2	mg/l Pt Co
Raw Water 15211-426	13/01/2017	Colour, apparent	5.6	mg/l Pt Co
Raw Water 15211-428	15/02/2017	Colour, apparent	6.5	mg/l Pt Co
Raw Water 15211-430	20/03/2017	Colour, apparent	<4	mg/l Pt Co

Consent of copy right owner required for any other use.

Raw Water 15211-432	06/04/2017	Colour, apparent	<4	mg/l Pt Co
Raw Water 15211-434	10/05/2017	Colour, apparent	5.8	mg/l Pt Co
Raw Water 15211-438	12/07/2017	Colour, apparent	<4	mg/l Pt Co
Treated Water 15211-439	12/07/2017	Colour, apparent	<4	mg/l Pt Co
Treated Water 15211 - 441	09/08/2017	Colour, apparent	4.2	mg/l Pt Co
Treated Water 15211- 437	15/06/2017	Colour, apparent	<4	mg/l Pt Co
Treated Water 15211-417	11/08/2016	Colour, apparent	<4	mg/l Pt Co
Treated Water 15211-425	02/12/2016	Colour, apparent	<4	mg/l Pt Co
Treated Water 15211-427	13/01/2017	Colour, apparent	<4	mg/l Pt Co
Treated Water 15211-429	15/02/2017	Colour, apparent	5	mg/l Pt Co
Treated Water 15211-431	20/03/2017	Colour, apparent	<4	mg/l Pt Co
Treated Water 15211-433	06/04/2017	Colour, apparent	<4	mg/l Pt Co
Treated Water 15211-435	10/05/2017	Colour, apparent	4.2	mg/l Pt Co
Raw Water 15211 - 348	03/10/2013	DOC	3.47	mg/l
Treated Water 15211 - 349	03/10/2013	DOC	4.35	mg/l
Raw Water 15211 - 348	03/10/2013	pH	7.1	pH Units
Raw Water 15211 - 350	07/11/2013	pH	7	pH Units
Raw Water 15211 - 352	03/12/2013	pH	6.8	pH Units
Raw Water 15211 - 354	15/01/2014	pH	6.8	pH Units
Raw Water 15211 - 356	04/02/2014	pH	6.8	pH Units
Raw Water 15211 - 358	05/03/2014	pH	6.7	pH Units
Raw Water 15211 - 360	02/04/2014	pH	7	pH Units
Raw Water 15211 - 362	07/05/2014	pH	7	pH Units
Raw Water 15211 - 364	11/06/2014	pH	7	pH Units
Raw Water 15211 - 366	17/07/2014	pH	7.1	pH Units
Raw Water 15211 - 368	07/08/2014	pH	7.2	pH Units
Raw Water 15211 - 370	11/09/2014	pH	7	pH Units

Consent of copyright owner required for any other use.

Raw Water 15211 - 372	15/10/2014	pH	7.1	pH Units
Raw Water 15211 - 374	19/11/2014	pH	7.1	pH Units
Raw Water 15211 - 376	02/12/2014	pH	7.6	pH Units
Raw Water 15211 - 378	27/01/2015	pH	6.9	pH Units
Raw Water 15211 - 380	11/02/2015	pH	6.9	pH Units
Raw Water 15211 - 382	04/03/2015	pH	7.1	pH Units
Raw Water 15211 - 384	09/04/2015	pH	6.8	pH Units
Raw Water 15211 - 386	13/05/2015	pH	6.8	pH Units
Raw Water 15211 - 388	04/06/2015	pH	7.1	pH Units
Raw Water 15211 - 390	02/07/2015	pH	6.9	pH Units
Raw Water 15211 - 392	12/08/2015	pH	7	pH Units
Raw Water 15211 - 394	09/09/2015	pH	6.9	pH Units
Raw Water 15211 - 396	08/10/2015	pH	6.9	pH Units
Raw Water 15211 - 398	25/11/2015	pH	6.9	pH Units
Raw Water 15211 - 400	09/12/2015	pH	7	pH Units
Raw Water 15211 - 402	20/01/2016	pH	6.9	pH Units
Raw Water 15211 - 404	10/02/2016	pH	7	pH Units
Raw Water 15211 - 406	15/03/2016	pH	7	pH Units
Raw Water 15211 - 408	06/04/2016	pH	6.9	pH Units
Raw Water 15211 - 410	12/05/2016	pH	7	pH Units
Raw Water 15211 - 412	09/06/2016	pH	7.6	pH Units
Raw Water 15211 - 414	14/07/2016	pH	7	pH Units
Raw Water 15211 - 440	09/08/2017	pH	7.1	pH Units
Raw Water 15211- 319	14/08/2012	pH	7.2	pH Units
Raw Water 15211- 321	12/09/2012	pH	6.9	pH Units
Raw Water 15211- 323	02/10/2012	pH	7	pH Units
Raw Water 15211- 326	01/11/2012	pH	7	pH Units

Consent of copyright owner required for any other use.

Raw Water 15211- 328	06/12/2012	pH	7.1	pH Units
Raw Water 15211- 330	08/01/2013	pH	7	pH Units
Raw Water 15211- 332	06/02/2013	pH	7.1	pH Units
Raw Water 15211- 334	05/03/2013	pH	7.1	pH Units
Raw Water 15211- 336	09/04/2013	pH	7.3	pH Units
Raw Water 15211- 338	08/05/2013	pH	7.1	pH Units
Raw Water 15211- 340	05/06/2013	pH	7.1	pH Units
Raw Water 15211- 342	10/07/2013	pH	7	pH Units
Raw Water 15211- 344	01/08/2013	pH	6.8	pH Units
Raw Water 15211- 346	10/09/2013	pH	7.2	pH Units
Raw Water 15211- 436	15/06/2017	pH	6.9	pH Units
Raw Water 15211-416	11/08/2016	pH	6.9	pH Units
Raw Water 15211-418	15/09/2016	pH	7	pH Units
Raw Water 15211-420	12/10/2016	pH	7.1	pH Units
Raw Water 15211-422	09/11/2016	pH	7	pH Units
Raw Water 15211-424	02/12/2016	pH	7	pH Units
Raw Water 15211-426	13/01/2017	pH	7	pH Units
Raw Water 15211-428	15/02/2017	pH	7	pH Units
Raw Water 15211-430	20/03/2017	pH	7	pH Units
Raw Water 15211-432	06/04/2017	pH	7	pH Units
Raw Water 15211-434	10/05/2017	pH	6.8	pH Units
Raw Water 15211-438	12/07/2017	pH	6.9	pH Units
Treated Water 15211 - 413	09/06/2016	pH	7	pH Units
Treated Water 15211 - 415	14/07/2016	pH	7	pH Units
Treated Water 15211-419	15/09/2016	pH	7	pH Units
Treated Water 15211-439	12/07/2017	pH	6.9	pH Units
Treated Water 15211 - 349	03/10/2013	pH	7	pH Units

Consent of copyright owner required for any other use.

Treated Water 15211 - 351	07/11/2013	pH	6.8	pH Units
Treated Water 15211 - 353	03/12/2013	pH	6.7	pH Units
Treated Water 15211 - 355	15/01/2014	pH	6.8	pH Units
Treated Water 15211 - 357	04/02/2014	pH	6.8	pH Units
Treated Water 15211 - 359	05/03/2014	pH	6.7	pH Units
Treated Water 15211 - 361	02/04/2014	pH	6.9	pH Units
Treated Water 15211 - 363	07/05/2014	pH	7	pH Units
Treated Water 15211 - 365	11/06/2014	pH	7.1	pH Units
Treated Water 15211 - 367	17/07/2014	pH	7	pH Units
Treated Water 15211 - 369	07/08/2014	pH	7.1	pH Units
Treated Water 15211 - 371	11/09/2014	pH	7	pH Units
Treated Water 15211 - 373	15/10/2014	pH	7.1	pH Units
Treated Water 15211 - 375	19/11/2014	pH	7.2	pH Units
Treated Water 15211 - 377	02/12/2014	pH	7.6	pH Units
Treated Water 15211 - 379	27/01/2015	pH	7	pH Units
Treated Water 15211 - 381	11/02/2015	pH	7	pH Units
Treated Water 15211 - 383	04/03/2015	pH	7	pH Units
Treated Water 15211 - 385	09/04/2015	pH	6.8	pH Units
Treated Water 15211 - 387	13/05/2015	pH	6.8	pH Units
Treated Water 15211 - 389	04/06/2015	pH	7.1	pH Units
Treated Water 15211 - 391	02/07/2015	pH	7	pH Units
Treated Water 15211 - 393	12/08/2015	pH	7	pH Units
Treated Water 15211 - 395	09/09/2015	pH	7	pH Units
Treated Water 15211 - 399	25/11/2015	pH	7	pH Units
Treated Water 15211 - 401	09/12/2015	pH	7	pH Units
Treated Water 15211 - 403	20/01/2016	pH	6.9	pH Units
Treated Water 15211 - 405	10/02/2016	pH	6.9	pH Units

Consent of copyright owner required for any other use.

Treated Water 15211 - 407	15/03/2016	pH	6.9	pH Units
Treated Water 15211 - 409	06/04/2016	pH	6.9	pH Units
Treated Water 15211 - 411	12/05/2016	pH	6.9	pH Units
Treated Water 15211 - 441	09/08/2017	pH	7.1	pH Units
Treated Water 15211- 320	14/08/2012	pH	7	pH Units
Treated Water 15211- 322	12/09/2012	pH	6.9	pH Units
Treated Water 15211- 324	02/10/2012	pH	6.9	pH Units
Treated Water 15211- 327	01/11/2012	pH	7	pH Units
Treated Water 15211- 329	06/12/2012	pH	7	pH Units
Treated Water 15211- 331	08/01/2013	pH	7	pH Units
Treated Water 15211- 333	06/02/2013	pH	7	pH Units
Treated Water 15211- 335	05/03/2013	pH	7	pH Units
Treated Water 15211- 337	09/04/2013	pH	7.1	pH Units
Treated Water 15211- 339	08/05/2013	pH	7	pH Units
Treated Water 15211- 341	05/06/2013	pH	7	pH Units
Treated Water 15211- 343	10/07/2013	pH	7	pH Units
Treated Water 15211- 345	01/08/2013	pH	6.8	pH Units
Treated Water 15211- 347	10/09/2013	pH	7.1	pH Units
Treated Water 15211- 397	08/10/2015	pH	7	pH Units
Treated Water 15211- 437	15/06/2017	pH	7	pH Units
Treated Water 15211-417	11/08/2016	pH	6.9	pH Units
Treated Water 15211-421	12/10/2016	pH	7.1	pH Units
Treated Water 15211-423	09/11/2016	pH	7	pH Units
Treated Water 15211-425	02/12/2016	pH	6.8	pH Units
Treated Water 15211-427	13/01/2017	pH	7	pH Units
Treated Water 15211-429	15/02/2017	pH	7	pH Units
Treated Water 15211-431	20/03/2017	pH	7	pH Units

Consent of copyright owner required for any other use.

Treated Water 15211-433	06/04/2017	pH	7	pH Units
Treated Water 15211-435	10/05/2017	pH	6.8	pH Units
Raw Water 15211 - 348	03/10/2013	TOC	4.41	mg/L
Treated Water 15211 - 349	03/10/2013	TOC	5.69	mg/L
Raw Water 15211 - 348	03/10/2013	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 350	07/11/2013	Turbidity	0.3	N.T.U.
Raw Water 15211 - 352	03/12/2013	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 354	15/01/2014	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 356	04/02/2014	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 358	05/03/2014	Turbidity	0.3	N.T.U.
Raw Water 15211 - 360	02/04/2014	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 362	07/05/2014	Turbidity	0.4	N.T.U.
Raw Water 15211 - 364	11/06/2014	Turbidity	1	N.T.U.
Raw Water 15211 - 366	17/07/2014	Turbidity	0.2	N.T.U.
Raw Water 15211 - 368	07/08/2014	Turbidity	0.3	N.T.U.
Raw Water 15211 - 370	11/09/2014	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 372	15/10/2014	Turbidity	0.3	N.T.U.
Raw Water 15211 - 374	19/11/2014	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 376	02/12/2014	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 378	27/01/2015	Turbidity	0.2	N.T.U.
Raw Water 15211 - 380	11/02/2015	Turbidity	0.4	N.T.U.
Raw Water 15211 - 382	04/03/2015	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 384	09/04/2015	Turbidity	0.2	N.T.U.
Raw Water 15211 - 386	13/05/2015	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 388	04/06/2015	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 390	02/07/2015	Turbidity	0.2	N.T.U.
Raw Water 15211 - 392	12/08/2015	Turbidity	0.4	N.T.U.

Consent for inspection purposes only. No consent of copyright owner required for any other use.

Raw Water 15211 - 394	09/09/2015	Turbidity	0.3	N.T.U.
Raw Water 15211 - 396	08/10/2015	Turbidity	0.2	N.T.U.
Raw Water 15211 - 398	25/11/2015	Turbidity	0.2	N.T.U.
Raw Water 15211 - 400	09/12/2015	Turbidity	0.2	N.T.U.
Raw Water 15211 - 402	20/01/2016	Turbidity	0.6	N.T.U.
Raw Water 15211 - 404	10/02/2016	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 406	15/03/2016	Turbidity	0.3	N.T.U.
Raw Water 15211 - 408	06/04/2016	Turbidity	0.4	N.T.U.
Raw Water 15211 - 410	12/05/2016	Turbidity	0.3	N.T.U.
Raw Water 15211 - 412	09/06/2016	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 414	14/07/2016	Turbidity	<0.2	N.T.U.
Raw Water 15211 - 440	09/08/2017	Turbidity	<0.2	N.T.U.
Raw Water 15211- 319	14/08/2012	Turbidity	0.3	N.T.U.
Raw Water 15211- 321	12/09/2012	Turbidity	<0.2	N.T.U.
Raw Water 15211- 323	02/10/2012	Turbidity	<0.2	N.T.U.
Raw Water 15211- 326	01/11/2012	Turbidity	<0.2	N.T.U.
Raw Water 15211- 328	06/12/2012	Turbidity	0.2	N.T.U.
Raw Water 15211- 330	08/01/2013	Turbidity	<0.2	N.T.U.
Raw Water 15211- 332	06/02/2013	Turbidity	<0.2	N.T.U.
Raw Water 15211- 334	05/03/2013	Turbidity	<0.2	N.T.U.
Raw Water 15211- 336	09/04/2013	Turbidity	<0.2	N.T.U.
Raw Water 15211- 338	08/05/2013	Turbidity	<0.2	N.T.U.
Raw Water 15211- 340	05/06/2013	Turbidity	0.2	N.T.U.
Raw Water 15211- 342	10/07/2013	Turbidity	<0.2	N.T.U.
Raw Water 15211- 344	01/08/2013	Turbidity	0.7	N.T.U.
Raw Water 15211- 346	10/09/2013	Turbidity	0.4	N.T.U.
Raw Water 15211- 436	15/06/2017	Turbidity	0.5	N.T.U.

Consent for inspection purposes only. Consent of copyright owner required for any other use.

Raw Water 15211-416	11/08/2016	Turbidity	0.2	N.T.U.
Raw Water 15211-418	15/09/2016	Turbidity	0.6	N.T.U.
Raw Water 15211-420	12/10/2016	Turbidity	<0.2	N.T.U.
Raw Water 15211-422	09/11/2016	Turbidity	0.6	N.T.U.
Raw Water 15211-424	02/12/2016	Turbidity	0.2	N.T.U.
Raw Water 15211-426	13/01/2017	Turbidity	0.3	N.T.U.
Raw Water 15211-428	15/02/2017	Turbidity	0.5	N.T.U.
Raw Water 15211-430	20/03/2017	Turbidity	0.2	N.T.U.
Raw Water 15211-432	06/04/2017	Turbidity	0.2	N.T.U.
Raw Water 15211-434	10/05/2017	Turbidity	0.4	N.T.U.
Raw Water 15211-438	12/07/2017	Turbidity	0.2	N.T.U.
Treated Water 15211 - 413	09/06/2016	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 415	14/07/2016	Turbidity	<0.2	N.T.U.
Treated Water 15211-419	15/09/2016	Turbidity	0.2	N.T.U.
Treated Water 15211-439	12/07/2017	Turbidity	0.2	N.T.U.
Treated Water 15211 - 349	03/10/2013	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 351	07/11/2013	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 353	03/12/2013	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 355	15/01/2014	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 357	04/02/2014	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 359	05/03/2014	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 361	02/04/2014	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 363	07/05/2014	Turbidity	0.3	N.T.U.
Treated Water 15211 - 365	11/06/2014	Turbidity	0.08	N.T.U.
Treated Water 15211 - 367	17/07/2014	Turbidity	0.2	N.T.U.
Treated Water 15211 - 369	07/08/2014	Turbidity	0.2	N.T.U.
Treated Water 15211 - 371	11/09/2014	Turbidity	<0.2	N.T.U.

Consent is for inspection purposes only. Consent of plant owner required for any other use.

Treated Water 15211 - 373	15/10/2014	Turbidity	0.2	N.T.U.
Treated Water 15211 - 375	19/11/2014	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 377	02/12/2014	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 379	27/01/2015	Turbidity	0.2	N.T.U.
Treated Water 15211 - 381	11/02/2015	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 383	04/03/2015	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 385	09/04/2015	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 387	13/05/2015	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 389	04/06/2015	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 391	02/07/2015	Turbidity	0.2	N.T.U.
Treated Water 15211 - 393	12/08/2015	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 395	09/09/2015	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 399	25/11/2015	Turbidity	0.2	N.T.U.
Treated Water 15211 - 401	09/12/2015	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 403	20/01/2016	Turbidity	0.6	N.T.U.
Treated Water 15211 - 405	10/02/2016	Turbidity	<0.2	N.T.U.
Treated Water 15211 - 407	15/03/2016	Turbidity	0.3	N.T.U.
Treated Water 15211 - 409	06/04/2016	Turbidity	0.3	N.T.U.
Treated Water 15211 - 411	12/05/2016	Turbidity	0.2	N.T.U.
Treated Water 15211 - 441	09/08/2017	Turbidity	<0.2	N.T.U.
Treated Water 15211- 320	14/08/2012	Turbidity	0.2	N.T.U.
Treated Water 15211- 322	12/09/2012	Turbidity	<0.2	N.T.U.
Treated Water 15211- 324	02/10/2012	Turbidity	<0.2	N.T.U.
Treated Water 15211- 327	01/11/2012	Turbidity	<0.2	N.T.U.
Treated Water 15211- 329	06/12/2012	Turbidity	0.2	N.T.U.
Treated Water 15211- 331	08/01/2013	Turbidity	<0.2	N.T.U.
Treated Water 15211- 333	06/02/2013	Turbidity	<0.2	N.T.U.

Consent for inspection purposes only. No consent of copyright owner required for any other use.

Treated Water 15211- 335	05/03/2013	Turbidity	<0.2	N.T.U.
Treated Water 15211- 337	09/04/2013	Turbidity	<0.2	N.T.U.
Treated Water 15211- 339	08/05/2013	Turbidity	<0.2	N.T.U.
Treated Water 15211- 341	05/06/2013	Turbidity	<0.2	N.T.U.
Treated Water 15211- 343	10/07/2013	Turbidity	<0.2	N.T.U.
Treated Water 15211- 345	01/08/2013	Turbidity	0.4	N.T.U.
Treated Water 15211- 347	10/09/2013	Turbidity	0.3	N.T.U.
Treated Water 15211- 397	08/10/2015	Turbidity	<0.2	N.T.U.
Treated Water 15211- 437	15/06/2017	Turbidity	0.3	N.T.U.
Treated Water 15211-417	11/08/2016	Turbidity	<0.2	N.T.U.
Treated Water 15211-421	12/10/2016	Turbidity	<0.2	N.T.U.
Treated Water 15211-423	09/11/2016	Turbidity	0.2	N.T.U.
Treated Water 15211-425	02/12/2016	Turbidity	<0.2	N.T.U.
Treated Water 15211-427	13/01/2017	Turbidity	0.3	N.T.U.
Treated Water 15211-429	15/02/2017	Turbidity	0.4	N.T.U.
Treated Water 15211-431	20/03/2017	Turbidity	0.2	N.T.U.
Treated Water 15211-433	06/04/2017	Turbidity	<0.2	N.T.U.
Treated Water 15211-435	10/05/2017	Turbidity	0.2	N.T.U.
Raw Water 15211 - 348	03/10/2013	UV Absorption (UVA) @ 254nm	0.148	
Treated Water 15211 - 349	03/10/2013	UV Absorption (UVA) @ 254nm	0.136	
Raw Water 15211 - 348	03/10/2013	UV Transmission (UVT) @ 254nm	71.2	%
Raw Water 15211 - 354	15/01/2014	UV Transmission (UVT) @ 254nm	85.8	%
Treated Water 15211 - 349	03/10/2013	UV Transmission (UVT) @ 254nm	73.2	%
Treated Water 15211 - 355	15/01/2014	UV Transmission (UVT) @ 254nm	88.7	%
Treated Water 15211 - 407	15/03/2016	UV Transmission (UVT) @ 254nm	90.6	%
Treated Water 15211 - 409	06/04/2016	UV Transmission (UVT) @ 254nm	89.9	%