

## Eve O'Sullivan

---

**From:** Suzanne Wylde  
**Sent:** 02 October 2018 12:04  
**To:** Sheelagh Flanagan  
**Subject:** Technical Amendment for Courtmacsherry and Timoleague discharge licence (D0294-02)

Morning Sheelagh,

Thank you for the request for technical amendment to waste water discharge licence D0294-02 for the Courtmacsherry and Timoleague agglomeration.

Please provide the following information to allow for an informed decision in respect of the requested technical amendment:

- Dissolved Inorganic Nitrogen (DIN) is the sum of the concentrations of Total Oxidised Nitrogen and Ammonia. The proposed limit of 50mg/l DIN, as an annual average, allows for considerably more ammonia to be discharged than is currently allowed for in the licence. Please provide details of the modelling scenarios that were used to determine that 50mg/l of DIN, as an annual average, would not have any untoward impact on the receiving waterbody.

**Regards,**  
**Suzanne Wylde**  
Inspector

Office of Environmental Sustainability  
Environmental Licensing Programme  
Environmental Protection Agency  
Johnstown Castle Estate  
Co. Wexford

Tel: +353-53-9170791 Fax: +353-53-9160699



Please consider the environment before printing this email.