



Electronic Copy

Mr. Jonathan Storey
On behalf of SSE Generation Ireland Limited

06 December 2021

Reg. No.: P0606-04

Regulation 13(1) of the EPA (Industrial Emission) (Licensing) Regulations 2013 as amended, in respect of a licence review from SSE Generation Ireland Limited for an installation located at SSE Generation Ireland Limited (Great Island), Great Island Generating Station, Campile, New Ross, County Wexford.

Dear Mr. Storey,

I refer to your Industrial Emissions licence review, which was received by the EPA on 29 September 2020.

I am to advise that in accordance with the provisions of the relevant legislation, you are requested to supply the following additional information within **four weeks of the date of this notice** so that the EPA may complete a comprehensive assessment of the review:

- Please define an output load or operational parameters for when the dry low NOx (DLN) operation is effective and a justification for this selection.
- Please provide a profile of NOx emissions from start-up to full load for the turbine operating on natural gas.

In addition to the above please also provide an updated non-technical summary to reflect the information provided in your reply.

Your response to this request is to be submitted via EDEN. Guidance on how to use this portal is available on the EPA website at [IE Licence application guidance | Environmental Protection Agency \(epa.ie\)](#)

It should be noted that where there is failure to comply with the above requirements within four weeks of the date of this notice, the EPA may proceed with its consideration of this application in the absence of the information requested.

Yours faithfully,

Environmental Licensing Programme
Office of Environmental Sustainability
Tel: 053 - 9160600