

**Amazon Data Services Ireland Limited**

# **Industrial Cooling Systems BAT Reference Document**

**Attachment-4-7-4**

*For inspection purposes only.  
Consent of copyright owner required for any other use.*

---

**Prepared by AWN Consulting**

**Licence Application Ref: LA007495**

---

## Conclusions on BAT from the ICS BAT Reference Document (extracts)

The full and complete ICS BAT reference document (December 2001) is available at the EIPPC Bureau website: <http://eippcb.jrc.ec.europa.eu/reference/>.

<b>SCOPE OF BEST AVAILABLE TECHNIQUES (BAT)</b>
<p><u>The following industrial cooling systems or configurations are covered in this BREF document:</u></p> <ul style="list-style-type: none"> <li>• Once-through cooling systems (with or without cooling tower)</li> <li>• Open recirculating cooling systems (wet cooling towers)</li> <li>• Closed circuit cooling systems                             <ul style="list-style-type: none"> <li>– air-cooled cooling systems</li> </ul> </li> <li>• Closed circuit wet cooling systems</li> <li>• Combined wet/dry (hybrid) cooling systems                             <ul style="list-style-type: none"> <li>– open hybrid cooling towers</li> <li>– closed circuit hybrid tower</li> </ul> </li> </ul> <p><u>The particular processes and activities at the installation that come within the scope of the conclusions on BAT from the ICS reference document (BREF) are:</u></p> <ul style="list-style-type: none"> <li>• Air Cooling via Air Handling Units (AHUs) which will be located in each data hall and will typically operate on Free Cooling Code (air cooling) with Evaporative Cooling (wet cooling) mode used during peak ambient temperatures.</li> <li>• Office air conditioning is provided by a Variable Refrigerant Flow (VRF) system which is not covered under the scope of this document as this uses refrigerant rather than air and/or water cooling.</li> </ul>

<b>Conclusions on BAT</b>	<b>Applicability assessment and description of the technique.</b>	<b>Schedule for implementation</b>
<b>Integrated Heat Management:</b>		
<p><b>BAT 1.</b>                      BAT for all installations is an integrated approach to reduce the environmental impact of industrial cooling systems maintaining the balance between both the direct and indirect impacts. In other words, the effect of an emission reduction has to be balanced against the potential change in the overall energy efficiency. There is currently no minimum ratio in terms of the environmental benefits and the possible loss in overall energy efficiency that can be used as a benchmark to arrive at techniques that can be considered BAT. Nevertheless, this concept can be used to compare alternatives (Chapter 3.2 and Annex II).</p>	<p><b>Applicable</b> - Cooling is required for each data hall within the Data Storage facility and is provided via free air coolers during normal operations.</p> <p>Wet cooling (evaporative) mode is only used during peak ambient temperatures i.e. in other than normal operations. During wet cooling mode, there is not a significant discharge as this water will be consumed in the evaporative process, and any remaining water will be recirculated.</p>	<p>In place</p>

	<p>The data servers themselves are the best available technology and some heat generation is unavoidable due to the nature of the technology.</p> <p>Alternative technologies are considered on an ongoing basis by the Operator as a part of each of its designs based on many factors including technical feasibility, environmental impact, efficiency, security, reliability and cost.</p> <p>The Operator is committed to continually assessing and improving this technology particularly with respect to minimising power consumption and reducing heat losses.</p>	
<p><b>BAT 2.</b> Reduction of the level of heat discharge by optimization of internal/external heat reuse. In a greenfield situation, assessment of the required heat capacity can only be BAT if it is the outcome of maximum use of the internal and external available and applicable options for reuse of excess heat.</p> <p>In an existing installation, optimizing internal and external reuse and reducing the amount and level of heat to be discharged must also precede any change to the potential capacity of the applied cooling system. Increasing the efficiency of an existing cooling system by improving systems operation must be evaluated against an increase of efficiency by technological measures through retrofit or technological change. In general and for large existing cooling systems, the improvement of the systems operation is considered to be more cost effective than the application of new or improved technology and can therefore be regarded as BAT.</p>	<p><b>Applicable</b> - The waste heat from the data storage facilities will be removed continually by motorised fans in the AHU system.</p> <p>The cooling systems include Air Handling Units (AHUs) fitted with airside condensers to utilise outdoor air to cool the space. Additional cooling to this is provided by evaporative means with water recycling utilised.</p> <p>The waste heat from the data storage facilities will be removed continually by motorised fans in the AHU system.</p> <p>Waste heat from the office spaces is re-used within the development as part of the fresh air ventilation system. Energy efficient Heat Recover Units recover the waste heat and use it to pre-heat the incoming air thereby</p>	<p>In place</p>

	<p>reducing the overall energy consumption of the heating system.</p> <p>Energy efficiency measures have been implemented as outlined in the BREF assessment for Energy Efficiency.</p>	
<p><b>BAT 3. Cooling system and process requirements:</b></p> <p>a) A change in cooling technology to reduce the environmental impact can only be considered BAT if the efficiency of cooling is maintained at the same level or, even better, at an increased level. See table 4.1' <i>Examples of process requirements and BAT</i>'.</p> <p>b) Hazardous process substances, which involve a high environmental risk to the aquatic environment in case of leakage, should be cooled by means of indirect cooling systems to prevent an uncontrollable situation.</p> <p>c) A change in cooling technology to reduce the environmental impact can only be considered BAT if the efficiency of cooling is maintained at the same level or, even better, at an increased level.</p>	<p><b>Applicable</b> – The facility has been designed to ensure minimal waste heat is produced.</p> <p>The selection of the cooling system has taken into account process requirements.</p> <p>Dry air cooling is suitable for the data storage facilities during normal conditions and cooling towers are not required.</p> <p>Water cooling of the data hall AHU units using evaporative cooling is only undertaken when conditions are too high where the heat recovery from the outside air is no longer achievable without some form of additional cooling from the evaporative process</p> <p>No hazardous substances to be cooled.</p> <p>This is a new facility, and an efficient cooling system has been designed.</p>	<p>In place</p>
<p><b>BAT 4. Cooling system and site requirements:</b></p> <p>For temperature-sensitive processes it is BAT to select the site with the required availability of cooling water. See table 4.2 <i>Examples of site characteristics and BAT</i>.</p> <p><b>Table 4.2: Examples of site characteristics and BAT</b></p>	<p><b>Applicable.</b></p> <p>Climate: Wet and dry bulb variation has been considered; the Irish climate is suitable.</p> <p>Space: The building and cooling system has been designed concurrently. There is sufficient space to access and maintain units.</p>	<p>In place</p>

Characteristics of site	Criteria	Primary BAT approach	Remarks	Reference		
Climate	Required design temperature	Assess variation in wet and dry bulb T	With high dry bulb T dry air cooling generally has lower Energy efficiency	Section 1.4.3	<p>Surface water availability: Not required. There is sufficient water available provided by Irish Water.</p> <p>Sensitivity of receiving waterbody: No discharge of wastewater to water.</p> <p>Groundwater availability: Not required. There is sufficient water available provided by Irish Water.</p> <p>Coastal area: Not applicable. No discharge of wastewater to water.</p> <p>Site specific requirements: Not applicable.</p>	
Space	Restricted surface on-site	(Pre-assembled) Roof type constructions	Limits to size and weight of the cooling system	Section 1.4.2		
Surface water availability	Restricted availability	Recirculating systems	Wet, dry or hybrid feasible	Section 2.3 and 3.3		
Sensitivity of receiving water body for thermal loads	Meet capacity to accommodate thermal load	<ul style="list-style-type: none"> <li>- Optimise level of heat reuse</li> <li>- Use recirculating systems</li> <li>- Site selection (new cooling system)</li> </ul>		Section 1.1		
Restricted availability of groundwater	Minimisation of groundwater use	Air cooling if no adequate alternative water source is available	Accept energy penalty	Section 3.3		
Coastal area	Large capacity > 10 MW <sub>a</sub>	Once-through systems	Avoid mixing of local thermal plume near intake point, e.g. by deep water extraction below mixing zone using temperature stratification	Section 1.2.1 / Section 3.2 /Annex XI.3		
Specific site requirements	In case of obligation for plume reduction and reduced tower height	Apply hybrid cooling system	Accept energy penalty	Ch. 2		
<b>Application of BAT in industrial cooling systems:</b>						
<p><b>BAT 5.</b>                      For <b>new cooling installations</b> it is BAT to start identifying reduction measures in the design phase, applying equipment with low energy requiring requirement and by choosing the appropriate material for equipment in contact with the process substance and/or the cooling water.</p>					<p><b>Applicable</b> - The cooling system employed for the data halls has been designed with low energy usage in mind. This is addressed further below.</p> <p>The direct energy consumption in the server rooms will be monitored and minimised by: the use of efficient equipment (AHUs), and the use of BMS (Building Management System), and Electrical Power Management System (EPMS) controls to minimise running speed at all times.</p>	In place

Content of copyright owner required for any other use. For inspection purposes only.

	<p>Appropriate material(s) have been considered and designed in for the equipment in contact with the cooling water.</p>	
<p><b>BAT 6.</b> For <b>existing installations</b>, technological measures can be BAT under certain circumstances. Generally, a change in technology is cost-intensive where overall efficiency must be maintained. Cost evaluation should then compare investment costs of the change versus the change in operational costs and validate the reduction effect versus other environmental consequences. For existing wet cooling systems where focus is largely on measures to reduce water use and emissions of chemicals to surface water BAT is operational rather than technological.</p>	<p><b>Not Applicable</b> – this is a new installation.</p>	<p>N/A</p>
<p><b>Reduction of energy consumption</b></p>		
<p><b>BAT 7.</b> It is BAT in the design phase of a cooling system:</p> <ul style="list-style-type: none"> <li>• To reduce resistance to water and airflow</li> <li>• To apply high efficiency/low energy equipment</li> <li>• To reduce the amount of energy demanding equipment (Annex XI.8.1)</li> <li>• To apply optimised cooling water treatment in once-through systems and wet cooling towers to keep surfaces clean and avoid scaling, fouling and corrosion.</li> </ul> <p>For each individual case a combination of the above-mentioned factors should lead to the lowest attainable energy consumption to operate a cooling system.</p>	<p><b>Applicable</b> - The direct energy consumption in the data storage facilities will be minimised by the use of efficient equipment (i.e. AHUs), and the use of BMS (Building Management System) controls to minimise running speed at all times.</p> <p>Water pipes, air ducts, etc are designed to be of a size to reduce resistance to water and airflow. Dead legs in the existing system are currently being addressed and ADSIL are working to remove them.</p> <p>Heating and cooling pipes are insulated to prevent losses throughout the system and to improve efficiency; or where this is not the case in existing buildings, ADSIL is working towards getting these installed where required.</p> <p>Appropriate material has been designed in for the equipment in contact with the warm air and cooling water. Ducts are galvanised steel.</p>	<p>In place</p>

	Pipes are PVC and copper at most sites however this does vary across the cluster.																																				
<p><b>BAT 8.</b> In terms of the overall energy efficiency of an installation, the use of a once-through systems is BAT, in particular for processes requiring large cooling capacities (e.g. &gt; 10 MWth). Table 4.3 BAT for increasing overall energy efficiency.</p> <table border="1" data-bbox="212 571 981 1259"> <thead> <tr> <th>Relevance</th> <th>Criterion</th> <th>Primary BAT approach</th> <th>Remarks</th> <th>Reference</th> </tr> </thead> <tbody> <tr> <td>Large cooling capacity</td> <td>Overall energy efficiency</td> <td>Select site for once-through option</td> <td>See text above table</td> <td>Section 3.2</td> </tr> <tr> <td>All systems</td> <td>Overall energy efficiency</td> <td>Apply option for variable operation</td> <td>Identify required cooling range</td> <td>Section 1.4</td> </tr> <tr> <td>All systems</td> <td>Variable operation</td> <td>Modulation of air/ water flow</td> <td>Avoid instability cavitation in system (corrosion and erosion)</td> <td></td> </tr> <tr> <td>All wet systems</td> <td>Clean circuit/ exchanger surfaces</td> <td>Optimised water treatment and pipe surface treatment</td> <td>Requires adequate monitoring</td> <td>Section 3.4</td> </tr> <tr> <td>Once-through systems</td> <td>Maintain cooling efficiency</td> <td>Avoid recirculation of warm water plume in rivers and minimise it in estuaries and on marine sites</td> <td></td> <td>Annex XII</td> </tr> <tr> <td>All cooling towers</td> <td>Reduce specific energy consumption</td> <td>Apply pumping heads and fans with reduced energy consumption</td> <td></td> <td></td> </tr> </tbody> </table>	Relevance	Criterion	Primary BAT approach	Remarks	Reference	Large cooling capacity	Overall energy efficiency	Select site for once-through option	See text above table	Section 3.2	All systems	Overall energy efficiency	Apply option for variable operation	Identify required cooling range	Section 1.4	All systems	Variable operation	Modulation of air/ water flow	Avoid instability cavitation in system (corrosion and erosion)		All wet systems	Clean circuit/ exchanger surfaces	Optimised water treatment and pipe surface treatment	Requires adequate monitoring	Section 3.4	Once-through systems	Maintain cooling efficiency	Avoid recirculation of warm water plume in rivers and minimise it in estuaries and on marine sites		Annex XII	All cooling towers	Reduce specific energy consumption	Apply pumping heads and fans with reduced energy consumption			<p><b>Applicable</b> - The process requirements have been identified; high efficiency equipment will be selected to provide the most efficient cooling to the required temperature range.</p> <p>The data halls are used using air cooling during normal operations. This system is standard for data storage facilities due to the Irish climate.</p> <p>The cooling system is monitored for temperature, pressure, humidity and flow rates and controlled by an electronic BMS. The system monitors conditions and responds to reduce fan speeds to maintain the operating point at the minimum necessary to meet the data storage room environmental conditions.</p> <p>Additional cooling will be provided by evaporative pads utilizing water as cooling media. There is no requirement for chemical water treatment as the water is typically evaporated during the process. Unused water is re-circulated within the AHUs for re-use and the water is replaced on (at least) a weekly basis to prevent legionella growth. A UV steriliser is employed to ensure the water remains clear of biological growth during the week. The conductivity probe and UV system are controlled by the BMS, as is the flush cycle.</p>	In place
Relevance	Criterion	Primary BAT approach	Remarks	Reference																																	
Large cooling capacity	Overall energy efficiency	Select site for once-through option	See text above table	Section 3.2																																	
All systems	Overall energy efficiency	Apply option for variable operation	Identify required cooling range	Section 1.4																																	
All systems	Variable operation	Modulation of air/ water flow	Avoid instability cavitation in system (corrosion and erosion)																																		
All wet systems	Clean circuit/ exchanger surfaces	Optimised water treatment and pipe surface treatment	Requires adequate monitoring	Section 3.4																																	
Once-through systems	Maintain cooling efficiency	Avoid recirculation of warm water plume in rivers and minimise it in estuaries and on marine sites		Annex XII																																	
All cooling towers	Reduce specific energy consumption	Apply pumping heads and fans with reduced energy consumption																																			

For inspection purposes only. Consent of copyright owner required for any other use.

<p style="text-align: center; color: red; transform: rotate(-45deg); font-weight: bold;">For inspection purposes only. Consent of copyright owner required for any other use.</p>	<p>Evaporative cooling is only used during peak ambient temperatures.</p> <p>There are no once-through water-based systems required. No discharge directly into a water body.</p> <p>The AHUs have high efficiency electrically commutated (EC) fans equipped with Variable Speed Drives (VSD) which are responsible for adjusting the exhaust fan speed based on the measured pressure differentials. The system is monitored and controlled by the BMS which monitors conditions and responds to reduce fan speeds and pump speed to maintain the operating point at the minimum necessary to meet the data storage room environmental conditions.</p> <p>The EPMS will alarm in the event of a supply fan failure, evaporative cooling pump failure, main power loss, failure of supply air temperature sensors, low supply air temperature, high supply air temperature, UV light failure, AHU sump too high, AHU sump level too low, AHU leak detection, etc.</p> <p>The AHU unit controller shall be equipped with default failsafe modes in the event that an input from the BMS Area Controller is lost or fails to send valid setpoints/values. The AHU unit controller shall generate an alarm on any loss of input signal from the EPMS.</p>	
<b>Reduction of water requirements</b>		
<p><b>BAT 9.</b> <b>For new systems the following statements can be made:</b></p>	<p><b>Applicable</b> - The site is not considered to have a large cooling demand. The facility will not</p>	<p>In place</p>



- cooling with water is most efficient with respect to overall energy balance;
- For new installations a site should be selected for availability of sufficient (surface) water and adequate receiving water in case of large cooling demand;
- Cooling demand should be reduced by optimising heat re-use;
- Where water is limited a technology should be chosen that enables different modes of operation requiring less water for required cooling capacity;
- In all cases recirculated cooling in an option.

See table 4.4 BAT for reduction of water requirements.

Relevance	Criterion	Primary BAT approach	Remarks	Ref.
All wet cooling systems	Reduction of need for cooling	Optimisation of heat reuse		Ch.1
	Reduction of use of limited sources	Use of groundwater is not BAT	Site-specific in particular for existing systems	Ch.2
	Reduction of water use	Apply recirculating systems	Different demand on water conditioning	Ch.2/3.3
	Reduction of water use, where obligation for plume reduction and reduced tower height	Apply hybrid cooling system	Accept energy penalty	Ch.2.6/3.3.1.2
	Where water (make-up water) is not available during (part of) process period or very limited (drought-stricken areas)	Apply dry cooling	Accept energy penalty	Section 3.2 and 3.3 Annex XII.6
All recirculating wet and wet/dry cooling systems	Reduction of water use	Optimization of cycles of concentration	Increased demand on conditioning of water, such as use of softened make-up water	Section 3.2 and section XI

consume water during normal operations. Air cooling has been determined to be sufficient to meet the cooling requirements for the server rooms.

The data storage facilities shall have a number of AHUs that require water input when they operate in evaporative cooling mode. Cooling water is only required for the data halls during elevated temperatures when operating in evaporative cooling mode. This system is optimised through the use of temperature sensors and the BMS.

Water is supplied from the mains and stored in cooling water tanks at each of the data storage facilities. Irish Water are consulted prior to submission of each planning application to ensure that there is adequate supply for all data storage facilities on the site.

Evaporative cooling pipework is distributed via a ring main to each AHU corridor with each route / pipework capable of supplying the required volume of chilled water for all units in that corridor. This maximised water use efficiency.

Water in the evaporative cooling system is predominately used up (i.e. evaporated) in the process. Unused water will be recirculated and reused until the conductivity of the water reaches 1500 µS/cm (or after 7 days as is required to prevent legionella growth)

	Dry cooling (air cooling) is the primary cooling method.	
<b>BAT 10. Reduction of entrainment of organisms.</b> For once through systems or systems with intakes of surface water, BAT is analysis of biotope in surface water source and optimisation of water velocities in intake channels to limit sedimentation.	<b>Not applicable</b> – surface water not used.	N/A
<b>BAT 11. Identified reduction techniques within the BAT-approach.</b> Analysis of the biotope in surface water source, Optimise water velocities in intake channels to limit sedimentation; watch for seasonal occurrence of macrofouling. see table 4.5 <i>BAT for reduction of entrainment</i> .	<b>Not applicable</b> – surface water is not used.	N/A
<b>Reduction of emissions to water</b>		
<b>BAT 12. General BAT approach to reduce heat emissions</b> Where the measures generally aim at reducing the $\Delta T$ of the discharged cooling water, a few conclusions on BAT can be drawn. Pre-cooling (Annex XII) has been applied for large power plants where the specific situation requires this, e.g. to avoid raised temperature of the intake water. Discharges will have to be limited with reference to the constraints of the requirements of Directive 78/659/EEC for fresh water sources. The criteria are summarised in Table 3.6. Reference is made to a provision in Article 11 of this directive regarding derogation of the requirements in certain circumstances.	<b>Not applicable</b> - There is no discharge of heated water from the cooling system into a surface water body.	N/A
<b>BAT 13. General BAT approach to reduce chemical emissions to water.</b> With respect to the selection of chemicals, it has been concluded that a ranking of treatments and the chemicals of which they are composed is difficult if not impossible to carry out in a general way and would be unlikely to lead to BAT conclusions. Due to the large variation in conditions and treatments only a site-by-site assessment will lead to the appropriate solution. Such an assessment and its constituent parts could represent an approach that can be considered BAT.	<b>Applicable</b> - The selection of water treatment (UV sterilisation) is appropriate for the facility. No water treatment chemicals are required.	In place
<b>BAT 14.</b> 80% of environmental impact is decided on design table, measures should be taken in the design of wet cooling system using the following order of approach: <ul style="list-style-type: none"> <li>• Identify process conditions (P, T, corrosiveness);</li> <li>• Identify chemical characteristics of cooling water sources;</li> <li>• select appropriate material for heat exchanger for both process and cooling water characteristics;</li> <li>• select appropriate materials for other parts of the cooling system;</li> </ul>	<b>Applicable</b> - The data storage facilities shall have a number of AHUs that require water input when they operate in evaporative cooling mode). These systems have been designed to maximise the use of dry cooling (air cooling) with water cooling used only during the warm summer months.	In place

<ul style="list-style-type: none"> <li>• Identify operational requirements of the cooling system;</li> <li>• Select feasible cooling water treatment using less hazardous chemicals or lower potential for environmental impact;</li> <li>• apply biocide selection scheme;</li> <li>• optimise dosage regime by monitoring of cooling water and systems conditions;</li> </ul>	<p>The evaporative cooling system has been designed to ensure it is as efficient as possible.</p> <p>The evaporative cooling water will be supplied from the mains network.</p> <p>Appropriate material has been designed in for the equipment in contact with the cooling water. Pipes are PVC and copper at most sites however this does vary across the cluster.</p> <p>The operational requirements of the cooling system have been established to ensure energy efficiency.</p> <p>There is no requirement for water treatment (e.g. with biocide) as the water is typically evaporated during the process. A UV sterilisation system is also employed.</p> <p>Cleaning of the closed systems with a chlorine solution will only be undertaken in the event that Legionella has been detected.</p> <p>The use of the evaporative cooling mode and water consumption in the data storage facilities will be minimised by the use of efficient equipment (AHUs), and the use of BMS controls to minimise running speed at all times.</p>	
<p><b>Identified reduction techniques within the BAT-approach</b></p>		
<p><b>BAT 15. Prevention by design &amp; maintenance</b> See table 4.6 BAT for reduction of emissions to water by design and maintenance techniques</p>	<p><b>Applicable</b> - There is no proposed emission of process water during normal operation.</p>	<p>In place</p>

For inspection purposes only.  
Consent of copyright owner required for any other use.

Relevance	Criterion	Primary BAT approach	Remarks	Reference
All wet cooling systems	Apply less corrosion-sensitive material	Analysis of corrosiveness of process substance as well as of cooling water to select the right material		Ch.3.4
	Reduction of fouling and corrosion	Design cooling system to avoid stagnant zones		Annex XI.3.3.2.1
Shell&tube heat exchanger	Design to facilitate cleaning	Cooling water flow inside tube and heavy fouling medium on tube side	Depending on design, process T and pressure	Annex III.1
Condensers of power plants	Reduce corrosion-sensitiveness	Application of Ti in condensers using seawater or brackish water		Annex XII
	Reduce corrosion-sensitiveness	Application of low corrosion alloys (Stainless Steel with high pitting index or Copper Nickel)	Change to low corrosion alloys can affect formation of pathogens	Annex XII.5.1
	Mechanical cleaning	Use of automated cleaning systems with foam balls or brushes	In addition mechanical cleaning and high water pressure may be necessary	Annex XII.5.1

For inspection purposes only. Consent of copyright owner required for any other use.

The cooling systems will require water input only when operating in evaporative cooling mode.

The evaporative cooling water will be supplied from the mains network.

Evaporative cooling pipework is distributed via a ring main to each AHU corridor with each route / pipework capable of supplying the required volume of chilled water for all units in that corridor. This maximised water use efficiency.

Water pipes are designed to be of a size to reduce resistance. Dead legs in the system are currently being addressed and ADSIL are working to remove them.

Appropriate material has been designed in for the equipment in contact with the cooling water. Pipes are PVC and copper at most sites however this does vary across the cluster.

Pipework pressure tests will be carried out during system install to determine if there is a leak in the system.

Cleaning of the closed systems with a hydrogen peroxide solution will only be undertaken in the event that Legionella has been detected.

Site maintenance and housekeeping systems have been developed for the installation and relevant plant will be included within a

Condensers and heat exchangers	Reduce deposition (fouling) in condensers	Water velocity > 1.8 m/s for new equipment and 1.5 m/s in case of tube bundle retrofit	Depending on corrosion sensitivity of material, water quality and surface treatment	Annex XII.5.1	preventative maintenance schedule. This is managed by an Enterprise Asset Management System which is administered by a dedicated Asset Management Team. The EAM system records every piece of plant and equipment at each Aws SITE – each item is individually logged in the EAM system along with the PM requirements and frequency of maintenance required – an automatic update is sent to DCEO when maintenance is required.
	Reduce deposition (fouling) in heat exchangers	Water velocity > 0.8 m/s	Depending on corrosion sensitivity of material, water quality and surface treatment	Annex XII.3.2	
	Avoid clogging	Use debris filters to protect the heat exchangers where clogging is a risk		Annex XII	

For inspection purposes only.  
Consent of copyright owner required for any other use.

Once-through cooling system	Reduce corrosion-sensitiveness	Apply carbon steel in cooling water systems if corrosion allowance can be met	Not for brackish water	Annex IV.1	<p style="color: red; transform: rotate(-45deg); font-weight: bold;">For inspection purposes only. Consent of copy right owner required for any other use.</p>	
	Reduce corrosion-sensitiveness	Apply reinforced glass fibre plastics, coated reinforced concrete or coated carbon steel in case of underground conduits		Annex IV.2		
	Reduce corrosion-sensitiveness	Apply Ti for tubes of shell&tube heat exchanger in highly corrosive environment or high quality stainless steel with similar performance	Ti not in reducing environment, optimised biofouling control may be necessary	Annex IV.2		
Open wet cooling towers	Reduce fouling in salt water condition	Apply fill that is open low fouling with high load support		Annex IV.4		
	Avoid hazardous substances due to anti-fouling treatment	CCA treatment of wooden parts or TBTO containing paints is <u>not</u> BAT		Section 3.4 Annex IV.4		
Natural draught wet cooling towers	Reduce anti-fouling treatment	Apply fill under consideration of local water quality (e.g. high solid content, scale)		Annex XII.8.3		
<p><b>BAT 16. Control by optimised cooling water treatment</b> See table 4.7 BAT for reduction of emissions to water by optimised cooling water treatment</p>					<p><b>Applicable</b> - There is no proposed emission of process water during normal operation.</p> <p>The evaporative cooling water will be supplied from the mains network.</p> <p>There is no requirement for water treatment (e.g. with biocide) as the water is typically</p>	In place

Relevance	Criterion	Primary BAT approach	Remarks	Reference
All wet systems	Reduce additive application	Monitoring and control of cooling water chemistry		Section 3.4 and Annex XI.7.3
	Use of less hazardous chemicals	It is <u>not</u> BAT to use <ul style="list-style-type: none"> <li>chromium compounds</li> <li>mercury compounds</li> <li>organometallic compounds (e.g. organotin compounds)</li> <li>mercaptobenzothiazole</li> <li>shock treatment with biocidal substances other than chlorine, bromine, ozone and H<sub>2</sub>O<sub>2</sub></li> </ul>		Section 3.4/ Annex VI
evaporated during the process. A UV sterilisation system is also employed.				
Cleaning of the closed systems with a hydrogen peroxide solution will only be undertaken in the event that Legionella has been detected.				
There will be no hazardous chemical additions to the water supply.				
<b>Reduction of emissions to air</b>				
<b>BAT 17. Identified reduction techniques within the BAT-approach</b>				
See table 4.8. <i>BAT for reduction of emissions to air</i>				
Identified reduction techniques within the BAT approach for all wet cooling towers:				
i) Avoid plume reaching ground level ii) Avoid plume formation iii) Use of less hazardous material iv) Avoid affecting indoor air quality v) Reduction of drift loss				
<b>Not Applicable</b> - Wet cooling towers are not used; there will be no plume generated.				
N/A				
<b>Reduction of noise emissions</b>				
<b>BAT 18. Identified reduction techniques within the BAT-approach</b>				
See table 4.9 BAT for reduction of noise emissions				
Identified reduction techniques within the BAT approach for natural draught cooling towers:				
i) reduce noise of cascading water at inlet: ii) reduce noise emission around tower base Identified reduction techniques within the BAT approach for mechanical draught cooling towers: iii) reduction of fan noise iv) optimised diffuser design No Standard commercial cooling tower utilised - low noise v) noise reduction				
<b>Not applicable</b> - The facility will not use natural draught cooling towers.				
N/A				
<b>BAT to reduce the risk of leakage</b>				
<b>BAT 19. Identified reduction techniques within the BAT-approach</b>				
<b>Applicable</b> – Water flow in the evaporative cooling system has been designed in				
In place				

<p>To reduce the risk of leakage, attention must be paid to the design of the heat exchanger, the hazardousness of the process substances and the cooling configuration. See table 4.10 BAT to reduce the risk of leakage.</p> <p>The following general measures to reduce the occurrence of leakages can be applied:</p> <ul style="list-style-type: none"> <li>i) select material for equipment of wet cooling systems according to applied water quality</li> <li>ii) operate the system according to its design</li> <li>iii) if cooling water treatment is needed, select the right cooling water treatment programme;</li> <li>iv) monitor leakage in cooling water discharge in recirculating wet cooling systems by analysing the blowdown</li> </ul>	<p>accordance with best practice to minimise the risk of leaks.</p> <p>There are no hazardous process substances.</p> <p>Pipework pressure tests will be carried out during system install to determine if there is a leak in the system.</p> <p>Materials selected to prevent corrosion leading to leakages.</p> <p>System will be operated to design.</p> <p>No treatment of waste heat recovery water taken from the mains system will be necessary.</p> <p>Leak detection systems are installed in the units and these are connected to the BMS.</p>	
<b>Reduction of biological risk</b>		
<p><b>BAT 20. Identified reduction techniques within the BAT approach</b>                  See table 4.11 <i>BAT to reduce biological growth</i>                  Identified reduction techniques within the BAT approach for all wet recirculating cooling systems:</p> <ul style="list-style-type: none"> <li>i) reduce algae formation</li> <li>ii) reduce biological growth</li> <li>iii) cleaning after outbreak</li> <li>iv) control of pathogens</li> </ul> <p>Identified reduction techniques within the BAT approach for all open wet cooling towers:</p> <ul style="list-style-type: none"> <li>v) reduce risk of infection</li> </ul>	<p><b>Not applicable</b> – water is provided by the public main and no biological growth is anticipated.</p> <p>Cleaning following any algae outbreak will be as per vendor recommendation.</p> <p>Cleaning of the closed systems with a hydrogen peroxide solution will only be undertaken in the event that Legionella has been detected.</p>	N/A