

The Tecpro Building,
Clonshaugh Business & Technology Park,
Dublin 17, Ireland.

T: + 353 1 847 4220
F: + 353 1 847 4257
E: info@awnconsulting.com
W: www.awnconsulting.com

ATTACHMENT-7-1-3-2 NOISE IMPACT ASSESSMENT FOR EPA LICENCE APPLICATION

Technical Report Prepared For
Amazon Data Services Ireland Limited

Prepared By
Damian Kelly BSc (Hons) MSc MIOA

Our Reference
DK/20/11534NR01

Date of Issue
21 January 2022

For inspection purposes only.
Consent of copyright owner required for any other use.

Dublin Office
The Tecpro Building,
Clonshaugh Business & Technology Park,
Dublin 17, Ireland.
T: + 353 1 847 4220
F: + 353 1 847 4257



AWN Consulting Limited
Registered in Ireland No. 319812
Directors: F Callaghan, C Dilworth,
T Donnelly, T Hayes, D Kelly, E Porter

For inspection purposes only.
Consent of copyright owner required for any other use.

Document History

Document Reference		Original Issue Date	
DK/20/11534NR01		21 January 2022	
Revision Level	Revision Date	Description	Sections Affected

Record of Approval

Details	Written by	Approved by
Signature		
Name	Damian Kelly	Stephen Smyth
Title	Director (Acoustics)	Associate (Acoustics)
Date	17 January 2022	17 January 2022

For inspection purposes only. Consent of copyright owner required for any other use.

EXECUTIVE SUMMARY

Amazon Data Services Ireland Limited ('ADSIL') operates data storage facilities at a site in the Clonshaugh Business & Technology Park, Dublin 17. Data storage facilities at the site are operational, construction has commenced on 1 additional data storage facility and a planning permission has been granted for a sixth for which construction has not yet commenced. AWN Consulting has been commissioned to prepare a noise impact assessment for the operation of the facility to be compiled and submitted as part of the Industrial Emissions (IE) licence application process.

This technical report has been prepared to provide full details in relation to the noise impact assessment for the licence application. The assessment is based on the most up-to-date design details available for development and has been prepared with due consideration of the guidance contained within the Environmental Protection Agency (EPA) document *Guidance Note for Noise: Licence Applications, Surveys and Assessments in Relation to Scheduled Activities (NG4) 2016*.

Section 6 of the EPA's NG4 Guidance outlines the following assessment stages for the noise impact assessment for licence applications.

- Stage 1 – Baseline Noise Survey / Monitoring Locations;
- Stage 2 – Derivation of Noise Criteria;
- Stage 3 – Assessment of Noise Impact; and,
- Stage 4 – Reporting / Licence Application Form.

This report has been prepared with consideration of the four assessment stages outlined above.

An environmental noise survey was conducted to quantify the existing noise environment in the vicinity of nearest Noise Sensitive Receivers (NSL's) to the site. The survey was conducted in general accordance with the EPA's NG4 Guidance.

Appropriate operational noise criteria have been derived for the site following review of noise survey data and receiving environment, in accordance with the relevant NG4 Guidance. The applicable noise criteria identified are in line with the typical limit values for noise from licensed sites.

To assess the impact of noise from new mechanical plant at nearby NSL's, a detailed computer-based noise model has been prepared using proprietary noise modelling software package. Noise prediction calculations have been carried out in accordance with ISO 9613-2:1996 *Acoustics – Attenuation of sound during propagation outdoors – Part 2: General method of calculation*. The predicted noise levels at all NSL's for new mechanical plant and the levels of existing plant noise from the facility are within the day, evening and night-time noise criteria for site operations.

CONTENTS

1.0 INTRODUCTION..... 6

2.0 FUNDAMENTALS OF ACOUSTICS..... 8

3.0 RECEIVING ENVIRONMENT 10

 3.1 Choice of Measurement Locations..... 10

 3.2 Survey Periods **Error! Bookmark not defined.**

 3.3 Personnel & Instrumentation..... 11

 3.4 Procedure 11

 3.5 Measurement Parameters..... 13

 3.6 Survey Results..... 13

4.0 REVIEW OF RELEVANT GUIDANCE & EXISTING LICENCE 17

 4.1 Quiet Area Screening..... 17

 4.2 Low Background Noise Area Screening..... 17

 4.3 Determining Appropriate Noise Criteria..... 18

 4.4 Compliance Noise Monitoring..... 18

5.0 ASSESSMENT 19

 5.1 Noise Sensitive Locations 19

 5.2 Noise Source Data..... 21

 5.3 Calculation Methodology..... 23

 5.4 Predicted Noise Levels 24

6.0 CONCLUSION 32

For inspection purposes only. Consent of copyright owner required for any other use.

1.0 INTRODUCTION

The following Operational Report relates to the Amazon Data Services Ireland Ltd. (“ADSIL” or ‘the applicant’) data storage facility (the subject ‘installation’ under this licence application) that is located in Clonshaugh Business and Technology Park, Dublin D17. .

ADSIL operate four data storage facilities, at the site are operational, construction has commenced on 1 additional data storage facility and a planning permission has been granted for a sixth for which construction has not yet commenced.

AWN Consulting has been commissioned to prepare a noise impact assessment for the operation of the facility to be compiled and submitted as part of the Industrial Emissions (IE) licence application process.

This assessment is based on the predicted noise emissions from the installation and the most up-to-date design details available for the development and has been prepared with due consideration to the guidance contained within the Environmental Protection Agency (EPA) document *Guidance Note for Noise: Licence Applications, Surveys and Assessments in Relation to Scheduled Activities (NG4) 2016*. This report has been prepared in accordance with the four noise impact assessment stages outlined in Section 6 of NG4, which are as follows:

- Stage 1 – Baseline Noise Survey / Monitoring Locations;
- Stage 2 – Derivation of Noise Criteria;
- Stage 3 – Assessment of Noise Impact; and,
- Stage 4 – Reporting / Licence Application Form.

Figure 1 illustrates the site location in the context of the surrounding environment.




Figure 1 Site Location & Context

The closest residential noise sensitive locations to Buildings A / B / C & D are located to the west of the development site along Turnapin Grove. In addition, there are a number of commercial and industrial operations located on lands to the west on the far side of the M1. The north western boundary of the site abuts a section of the M1/M50 interchange. In relation to Buildings E & F the nearest residential noise sensitive locations are located to the east of the building, where a one-off private residence is

located. To the north are a number of residential units adjacent to a roundabout on the R139, and a hotel located on the northern side of the R139.

Appendix A to this report presents a glossary of the acoustic terminology referred to in this document.

*For inspection purposes only.
Consent of copyright owner required for any other use.*

2.0 FUNDAMENTALS OF ACOUSTICS

In order to provide a broader understanding of some of the technical discussion in this report, this section provides a brief overview of the fundamentals of acoustics and the basis for the preparation of this noise assessment.

A sound wave travelling through the air is a regular disturbance of the atmospheric pressure. These pressure fluctuations are detected by the human ear, producing the sensation of hearing. In order to take account of the vast range of pressure levels that can be detected by the ear, it is convenient to measure sound in terms of a logarithmic ratio of sound pressures. These values are expressed as Sound Pressure Levels (SPL) in decibels (dB).

The audible range of sounds expressed in terms of Sound Pressure Levels is 0dB (for the threshold of hearing) to 120dB (for the threshold of pain). In general, a subjective impression of doubling of loudness corresponds to a tenfold increase in sound energy which conveniently equates to a 10dB increase in SPL. It should be noted that a doubling in sound energy (such as may be caused by a doubling of traffic flows) increases the SPL by 3dB.

The frequency of sound is the rate at which a sound wave oscillates and is expressed in Hertz (Hz). The sensitivity of the human ear to different frequencies in the audible range is not uniform. For example, hearing sensitivity decreases markedly as frequency falls below 250Hz. In order to rank the SPL of various noise sources, the measured level has to be adjusted to give comparatively more weight to the frequencies that are readily detected by the human ear. Several weighting mechanisms have been proposed but the 'A-weighting' system has been found to provide one of the best correlations with perceived loudness. SPL's measured using 'A-weighting' are expressed in terms of dB(A). An indication of the level of some common sounds on the dB(A) scale is presented in Figure 2.

The established prediction and measurement techniques for the dB(A) parameter are well developed and widely applied. For a more detailed introduction to the basic principles of acoustics, reference should be made to an appropriate standard text¹.

¹ For example, *Woods Practical Guide to Noise Control* by Ian Sharland.




Figure 2 Level of Typical Sounds on the dB(A) Scale – (TII – Good Practice Guidance for the Treatment of Noise during the Planning of National Road Schemes)

3.0 RECEIVING ENVIRONMENT

This section deals with 'Stage 1' of the noise impact assessment as outlined in the EPA's NG4 Guidance.

An environmental noise survey was conducted by AWN in support of various planning applications for the development before any works commenced on site. One of the purposes of the survey was to quantify the existing noise environment at nearby noise sensitive locations in light of existing site noise emissions. The surveys were conducted in general accordance with guidance contained in the EPA NG4 publication and ISO 1996: 2017: *Acoustics – Description, measurement and assessment of environmental noise*. Details of this survey are presented in the following sections.

3.1 Noise Surveys




Noise surveys were conducted during the following periods:



- Daytime – 11:00 to 22:00hrs on 15 May 2019.
- Night-time – 23:00hrs on 15 May to 01:55hrs on 16 May 2019.
- Unattended – 13:10hrs on 17 May to 11:40hrs on 22 May 2019.
- Night-time – 23:40hrs on 4 October to 02:49hrs on 5 October 2011.
- Night-time – 23:00hrs on 12 October to 01:15hrs on 13 October 2015.
- Night-time – 22:45hrs on 19 October to 01:00hrs on 20 October 2015.

3.2 Choice of Measurement Locations

Noise measurements were conducted at six positions in the vicinity of the site. The location of these measurements are shown on Figure 3. The survey work was carried out as part of various planning applications associated with the various buildings. The surveys are representative of baseline conditions before the various buildings were developed and became operational.

Table 1 Measurement Locations & Descriptions

Location	Description	Photo
A (Oct 2015)	Located within the Turnapin housing estate to the west of the development. This location is considered representative of the nearest residential dwellings to the west of the site. These properties are c. 475m from the western site boundary.	
B (May 2019)	Located in the vicinity of the Clayton Hotel Dublin Airport located on the northern side of the R139 to the north of the development. This property has some 8 storeys. These properties are c.135m from the northern site boundary.	
C (May 2019)	Located on a grass verge in front of residential units located off the roundabout on the R139. These properties are c. 250m from the northern site boundary.	
D (May 2019)	Located on a point midway along the eastern boundary of the development site. This location	N/A

Location	Description	Photo
	is considered to be representative of background noise levels at the noise sensitive location located c. 65m to the east of the site.	
E (Oct 2011)	Located at the boundary of the IDA Business Park that adjoins the Larch Hill development to the west of the site. These properties are some 440m from the southern site boundary of the development. This location is considered to be indicative of the noise environment experienced at residences within the Larch Hill estate.	
F (Oct 2011)	Located within the Woodlawn residential housing estate located to the south of the development site. The location is representative of dwellings in the vicinity. These properties are some 350m from the southern boundary of the development.	

3.3 Personnel & Instrumentation

James Mangan (AWN) conducted the noise level measurements in 2011 with Leo Williams conducting the work in 2015. Donogh Casey (AWN) conducted the remainder of the noise level measurements.

The noise measurements were performed using a Brüel & Kjær Type 2260 Sound Level Analyzer. Before and after the survey the measurement apparatus was checked calibrated using a Brüel & Kjær Type 4231 Sound Level Calibrator. The unattended noise monitoring was completed using a RION NL-52 sound level meter.

3.4 Procedure

Measurements were conducted at the boundary location noted above. Sample periods for the noise measurements were typically 15 minutes. The results were noted onto a Survey Record Sheet immediately following each sample, and were also saved to the instrument memory for later analysis if required. Survey personnel noted the primary noise sources contributing to noise build-up.

Unattended measurements were 15 minute in duration and were saved directly to the installed sound level meter for later analysis.



Figure 3 Noise Monitoring Locations

3.5 Measurement Parameters

The survey results are presented in terms of the following parameters:

L_{Aeq} is the equivalent continuous sound level. It is a type of average and is used to describe a fluctuating noise in terms of a single noise level over the sample period.

L_{AFmax} is the instantaneous maximum sound level measured during the sample period.

L_{A10} is the sound level that is exceeded for 10% of the sample period. It is typically used as a descriptor for traffic noise.

L_{A90} is the sound level that is exceeded for 90% of the sample period. It is typically used as a descriptor for background noise.

The “A” suffix denotes the fact that the sound levels have been “A-weighted” in order to account for the non-linear nature of human hearing. All sound levels in this report are expressed in terms of decibels (dB) relative to 2×10^{-5} Pa.

Another parameter that will be commented upon in this report is the L_{ArT} .

L_{ArT} The L_{Aeq} during a specified time interval, plus specified adjustments for tonal character and impulsiveness of the sound.

It should be noted for this assessment it has been assumed that detailed design will be carried out in order that there will be not tonal or impulsive noise emissions for the development. Therefore, in this instance L_{Aeq} is equal to L_{ArT} .

3.6 Survey Results

3.6.1 Location A

The survey results for Location A are given in Table 2 below.

Table 2 Summary of Results for Location A

Time		Measured Noise Levels (dB re. 2×10^{-5} Pa)		
		L_{Aeq}	L_{AF10}	L_{AF90}
Day	11:16 – 11:31	67	68	64
	12:43 – 12:58	67	69	63
	14:39 – 14:54	64	65	62
	21:00 – 21:15	64	66	61
Night	23:40 – 00:05	65	61	55
	00:51 – 01:06	66	61	55

Daytime ambient and background noise levels at this location were dictated by road traffic noise from the M50 and M1. Other sources of noise included aircraft activity associated with Dublin Airport and some agricultural machinery. Ambient noise levels ranged from 64 to 67dB $L_{Aeq,15min}$ with background noise levels in the range of 61 to 64dB $L_{A90,15min}$.

During the night-time period again road traffic noise was the dominant noise source at this location with levels decreasing as the volume of traffic on the network decreased

into the early hours of the morning. Noise levels were in the range of 65 to 66dB L_{Aeq,15min} and the order of 55dB L_{A90,15min}.

3.6.2 Location B

The survey results for Location B are given in Table 3 below.

Table 3 Summary of Results for Location B

Time		Measured Noise Levels (dB re. 2x10 ⁻⁵ Pa)		
		L _{Aeq}	L _{AF10}	L _{AF90}
Day	11:54 – 12:09	62	64	59
	13:42 – 13:57	63	65	59
	15:12 – 15:27	63	64	59
	21:36 – 21:51	61	63	58
Night	00:09 – 00:24	57	57	52
	01:16 – 01:31	54	56	46

Daytime ambient and background noise levels at this location were dictated by road traffic noise from the R139, M50 and M1. Other sources of noise included aircraft activity associated with Dublin Airport and some agricultural machinery. Ambient noise levels ranged from 61 to 63dB L_{Aeq,15min} with background noise levels in the range of 58 to 59dB L_{A90,15min}.

During the night-time period again road traffic noise was the dominant noise source at this location with levels decreasing as the volume of traffic on the network decreased into the early hours of the morning. Noise levels were in the range of 54 to 57dB L_{Aeq,15min} and 46 to 52dB L_{A90,15min}.

3.6.3 Location C

The survey results for Location C are given in Table 4.

Table 4 Summary of Results for Location C

Time		Measured Noise Levels (dB re. 2x10 ⁻⁵ Pa)		
		L _{Aeq}	L _{AF10}	L _{AF90}
Day	12:18 – 12:33	65	68	56
	14:11 – 14:26	66	69	56
	15:36 – 15:51	65	69	57
	21:56 – 22:09	61	64	54
Night	00:28 – 00:42	59	60	48
	01:35 – 01:50	52	55	42

Daytime ambient and background noise levels at this location were dictated by road traffic noise from the R139, M50 and M1. Other sources of noise included aircraft activity associated with Dublin Airport and some agricultural machinery. Ambient noise levels ranged from 65 to 66dB L_{Aeq,15min} with background noise levels in the range of 56 to 57dB L_{A90,15min}.

During the night-time period again road traffic noise was the dominant noise source at this location with levels decreasing as the volume of traffic on the network decreased

into the early hours of the morning. Noise levels were in the range of 52 to 59dB $L_{Aeq,15min}$ and 42 to 48dB $L_{A90,15min}$

3.6.4 Location D

The profile of the ambient (i.e. $L_{Aeq,15min}$) and background noise levels (i.e. $L_{A90,15min}$) measured during the survey undertaken at Location D are presented in Figure 4.




Figure 4 Noise Profile at Location D

The survey results for Location D are given in Table 5.

Table 5 Summary of results for Location D

Location	Period	Time	Measured Noise Levels (dB re. 2×10^{-5} Pa)	
			L_{Aeq} (Ambient)	L_{AF90} (Background)
D	Day	Average	57	53
	Night	Average	54	51

Daytime ambient and background noise levels at this location were dictated by road traffic noise from the R139, M50 and M1. Other sources of noise included aircraft activity associated with Dublin Airport and some commercial machinery. Ambient noise levels were the order of 57dB $L_{Aeq,16hr}$ with background noise levels the order of 53dB $L_{A90,16hr}$.

During the night-time period again road traffic noise was the dominant noise source at this location with levels decreasing as the volume of traffic on the network decreased into the early hours of the morning. Noise levels were in the order of 54dB $L_{Aeq,8hr}$ and 51dB $L_{A90,8hr}$.

3.6.5 Location E

The survey results for Location E are given in Table 6 below.

Table 6 Summary of Results for Location E

Time		Measured Noise Levels (dB re. 2×10^{-5} Pa)		
		L _{Aeq}	L _{AF10}	L _{AF90}
Night-time	23:10 – 23:25	51	50	46
	00:31 – 00:46	49	51	46
	01:35 – 01:50	49	51	45

Night time noise levels were influenced by distant road traffic movements along the Oscar Traynor Road, M1 and M50 motorways, occasional local vehicle movements and wind generated noise on nearby foliage. Ambient noise levels were in the range of 49 to 51dB L_{Aeq}. Background noise levels were in the range 45 to 46dB L_{AF90}.

3.6.6 Location F

The survey results for Location F are given in Table 7.

Table 7 Summary of results for Location F

Time		Measured Noise Levels (dB re. 2×10^{-5} Pa)		
		L _{Aeq}	L _{AF10}	L _{AF90}
Night-time	22:56 – 23:09	52	54	51
	23:45 – 00:00	51	53	49
	00:23 – 00:38	50	52	47

Traffic noise from the M1 and the distant M1/M50 junction dictated noise levels at this location during the period both in terms of overall ambient noise and background levels. Levels reduced slightly as the survey period progressed due to a reduction in traffic volumes on the nearby and distant road network. Ambient noise levels were in the range of 51 to 52dB L_{Aeq,15min}. Background noise levels which were dictated by traffic noise were in the range 47 to 51dB L_{AF90,15min}.

3.7 Ecologically sensitive areas or areas of special interest

The lands in which the installation is located have no formal designations. The nearest ecologically sensitive area to the facility is the Santry Demesne Proposed NHA (000178) which is approximately 1km south-west of the facility. The nearest European site to the facility is the South Dublin Bay and River Tolka Estuary SPA c. 4.7km south-east.

An Appropriate Assessment (AA) Screening Report (Attachment 6-3-4) has been prepared by Altemar and have been submitted as part of the licence application for the site.

Based on the separation distance from the facility to the nearest ecologically sensitive area and European site it is highly unlikely that noise arising from the facility under any scenario would have any impact on these sites. Therefore, the noise impact on ecologically sensitive area has been scoped out of any further assessment.

4.0 REVIEW OF RELEVANT GUIDANCE

This section deals with 'Stage 2' of the noise impact assessment as outlined in the EPA's NG4 Guidance.

The discussion of appropriate IE Licence noise emission criteria for the overall facility will be conducted in accordance with the NG4 document. This approach is summarised below in accordance with guidance detailed in Section 4 of the NG4 document.

4.1 Quiet Area Screening

The site is not considered a quiet area in this instance as it fails to meet all the criteria outlined in EPA's Guidance. The most stringent of these criteria are noted in bullet point and commented on below.

- At least 3km from urban area with a population >1,000 people;

The site is within the jurisdiction of Dublin City Council and is located less than 3km from a population significantly greater than 1,000.

- At least 3km away from any local industry;

Other industrial sites operate within 3km of the site.

- At least 5km away from any National Primary Route;

A section of the site bounds the M1/M50 national roads/junctions.

4.2 Low Background Noise Area Screening

In order to establish whether the noise sensitive locations in the vicinity of the site would be considered 'low background noise' areas, the noise levels measured during the environmental noise survey need to satisfy all three of the following criteria:

- Arithmetic Average of L_{A90} During Daytime Period ≤ 40 dB L_{A90} , and;
- Arithmetic Average of L_{A90} During Evening Period ≤ 35 dB L_{A90} , and;
- Arithmetic Average of L_{A90} During Night-time Period ≤ 30 dB L_{A90} .

The arithmetic average L_{A90} results at each location are compared against the criteria in Table 8.

Table 8 Comparison of Measurement Results with NG4 Low Background Noise Area Criteria

Location	Period	$L_{A90,T}$ (dB)	NG4 Screening (dB $L_{A90,T}$)	Satisfies All Criteria for Low Background Noise Area?
A	Daytime	60	≤ 40	No
	Evening	61	≤ 35	
	Night-time	55	≤ 30	
B	Daytime	59	≤ 40	No
	Evening	58	≤ 35	
	Night-time	46	≤ 30	
C	Daytime	46	≤ 40	No
	Evening	54	≤ 35	
	Night-time	42	≤ 30	

Location	Period	L _{A90,T} (dB)	NG4 Screening (dB L _{A90,T})	Satisfies All Criteria for Low Background Noise Area?
D	Daytime	53	≤40	No
D	Evening	52	≤35	No
	Night-time	51	≤30	
E	Night-time	45	≤30	No
F	Night-time	47	≤30	No

As outlined in Table 8, none of the locations would be considered 'Areas of Low Background Noise' as the measured noise levels do not satisfy the criteria.

4.3 Determining Appropriate Noise Criteria

Based on the EPA NG4 guidance the following noise criteria are appropriate at the nearest NSL's to the facility:

- Daytime (07:00 to 19:00hrs) 55dB L_{Ar,15min}
- Evening (19:00 to 23:00hrs) 50dB L_{Ar,15min}
- Night time (23:00 to 07:00hrs) 45dB L_{Aeq,15min}

During the night period, no tonal or impulsive noise from the facility should be clearly audible or measurable at any NSL. The applicable noise criteria identified are in line with the typical limit values for noise from licensed sites.

There are some plant items installed that are designed to be used in emergency situations, for example, when grid power supplies fail. It is common practice to allow a relaxation of noise limits associated with emergency plant operations. Section 4.4.1 of EPA NG4 contains the following comments in relation to emergency plant items:

"In some instances, licensed sites will have certain items of emergency equipment (e.g. standby generators) that will only operate in urgent situations (e.g. grid power failure). Depending upon the context, it may be deemed permissible for such items of equipment to give rise to exceedances in the noise criteria/limits during limited testing and emergency operation only. If such equipment is in regular use for any purposes other than intermittent testing, it is subject to the standard limit values for the site".

It is therefore considered that the proposed noise criterion of 55dB L_{Aeq,(15mins)} is appropriate in emergency scenarios for daytime, evening and night-time periods.

4.4 Compliance Noise Monitoring

See Attachment 7.5 of the Licence application for further details on the noise sensitive locations.

Given there may be potential access constraints at some noise sensitive locations and the presence of extraneous noise sources in the vicinity, it may be necessary to undertake compliance noise monitoring (if required) at the site boundary or at a suitable proxy location and assess to the nearest NSL's. Any such assessment should be undertaken in accordance with the guidance outlined in the EPA NG4 document and supported by a sufficiently detailed noise report outlining the calculation methods used to determine the noise emission levels at the NSL's.

5.0 ASSESSMENT

This section deals with 'Stage 3' of the noise impact assessment as outlined in the EPA's NG4 Guidance.

The noise levels expected at nearest NSL's, due to the operation of the facility, must be considered and presented as part of the licence application.

The following sections present details of the assessment and the findings. Further information in relation to the noise prediction model, inputs, calculation settings and assessment assumptions are provided in Appendix B to this report.

It should be noted that noise impact assessment has been completed using information obtained from the design team for significant items of plant which were procured from vendors.

5.1 Noise Sensitive Locations

Noise prediction calculations have been carried out at the representative nearest noise sensitive locations (NSL's) surrounding the site. Details of the NSL's used for the prediction calculations are presented in Table 9. Free field noise emission levels have been predicted at a height stated in Table 9.

Table 9 Coordinates of Noise Sensitive Receivers

Noise Sensitive Location	Calculation Height (m)	National Grid Reference	
		North	East
R01	4	717,654	741,392
R02	4	717,640	741,278
R03	4	717,659	741,190
R04	4	717,165	740,672
R05	4	717,259	740,646
R06	4	717,278	740,578
R07	4	717,543	740,589
R08	4	717,578	740,505
R09	4	717,674	740,471
R10	4	717,764	740,432
R11	4	717,797	740,415
R12	4	717,931	740,267
R13	4	718,198	740,073
R14	4	718,641	740,939
R15	4	718,626	741,050
R16	14	718,709	741,277
R17	14	718,725	741,413
R18	4	718,587	741,574
R19	4	718,550	741,431
R20	14	718,330	741,593



Figure 5 Noise Assessment Locations

5.2 Noise Source Data

The noise modelling completed indicates the following limits in relation to various items of plant associated with the overall site development. Plant items will be selected in order to achieve the stated noise levels and or appropriate attenuation will be incorporated into the design of the plant/building in order that the plant noise emission levels are achieved on site (including any system regenerated noise).

Table 10 L_{wA} levels Utilised in Noise Model – Building A

Source	No. of	L_{wA} - Octave Band Centre Frequency								dB (A)
		63	125	250	500	1k	2k	4k	8k	
Roof Fan ^{Note A}	96	57	72	81	80	75	69	65	60	84.5
Data Hall CRAH (Roof)	84	55.5	64.6	71.1	75.5	75.7	71.9	65.7	59.6	80.3
Electrical Room Extract Fan ^{Note B}	10	61.5	67.7	71.8	73.8	69.3	74.5	75.3	73.2	81.4
Generator Exhaust	18	67.2	77.1	80.8	86.4	83.6	79.6	73.0	58.0	89.8
Generator Intake	18	79.4	91.6	94.2	95.0	90.0	84.9	79.9	66.0	99.4
Generator Stack	18	70.0	79.4	87.2	92.2	90.2	87.3	82.3	70.2	96.0
Pumps ^{Note C}	12	38.0	48.0	55.0	65.0	64.0	65.0	61.0	52.0	70.0

Note A Includes directivity effect of unit exhausting in the vertical plane.

Note B Includes provision of in line attenuation offering the following minimum sound reduction:

Element	Sound Insertion Loss dB – Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
Louvre	6.0	9.0	16.0	19.0	24.0	17.0	13.0	10.0

Note C Acoustic enclosures will be provided for external pumps in order that the stated noise levels in Table 10 are achieved.

Table 11 L_{wA} levels Utilised in Noise Model – Building B, C and D

Source	L_{wA} - Octave Band Centre Frequency								dB (A)
	63	125	250	500	1k	2k	4k	8k	
Roof Fan ^{Note D}	57	72	81	80	75	69	65	60	84.5
Data Hall CRAH (Roof)	55.5	64.6	71.1	75.5	75.7	71.9	65.7	59.6	80.3
Electrical Room Extract Fan ^{Note E}	61.5	67.7	71.8	73.8	69.3	74.5	75.3	73.2	81.4
AHU Louvres ^{Note F}	54	63	74	73	66	67	71	66	79
Generator Exhaust ^{Note G}	54	63	74	73	66	67	71	66	79
Generator Intake ^{Note G}	88	90	82	83	83	80	78	76	94
Generator Rear ^{Note G}	88	90	82	83	83	80	78	76	94
Generator Stack ^{Note H}	84	77	77	73	69	74	71	71	86
Generator Sides & Roof ^{Note G}	82	93	92	94	94	93	88	75	101
Pumps ^{Note I}	38	48	55	65	64	65	61	52	70
Transformers (x 4)	64	66	96	88	76	69	71	71	97

Note D Includes directivity effect of unit exhausting in the vertical plane.

Note E Includes provision of in line attenuation offering the following minimum sound reduction:

Element	Sound Insertion Loss dB – Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
Louvre	6.0	9.0	16.0	19.0	24.0	17.0	13.0	10.0

Note F It is assumed the relevant L_w associated with the AHU intake fan(s) is 84dB(A) as detailed in supplied data sheets. Provision of in line attenuation offering the following minimum sound reduction has been assumed:

Element	Sound Insertion Loss dB – Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
Splitter	6	8	13	15	18	12	9	8
Filter	0	2	2	2	4	7	7	12

Note G Assuming generator housing dimensions of 17m (L) x 4m (W) x 4m (H). Data based on CAT data supplied in relation to previous sites.

Note H Additional attenuation due to 25m stack and additional bends assumed.

Note I Acoustic enclosures will be provided for external pumps in order that the stated noise levels in Table 11 are achieved.

Table 12 L_{wA} levels Utilised in Noise Model – Building E & F

Source	L_{wA} - Octave Band Centre Frequency								dB (A)
	63	125	250	500	1k	2k	4k	8k	
Roof Fan	61	68	75	77	75	74	77	73	84
Roof Condensers	57	71	67	74	77	74	68	65	82
AHU Louvres	54	69	73	70	63	62	61	61	79
Generator Intake ^{Note J}	110	105	100	85	70	65	70	94	97
Generator Rear ^{Note J}	108	105	103	92	84	73	62	66	97
Generator Stack ^{Note K}	82	87	83	79	78	78	77	70	85
Generator Stack ^{Note K}	100	93	93	89	85	90	87	87	102
Generator Sides ^{Note J}	110	107	106	95	86	75	64	68	99
Generator Roof ^{Note J}	110	108	103	98	97	97	96	94	104
Pumps ^{Note L}	38	48	55	65	64	65	61	52	70
Transformers (x 4) ^{Note M}	49	51	81	73	61	54	56	56	82

Note J Assuming generator housing dimensions of 17m (L) x 4m (W) x 4m (H). Data based on CAT data supplied in relation to previous sites.

Note K Additional attenuation due to 20m stack and additional bends assumed.

Note L Acoustic enclosures will be provided for external pumps in order that the stated noise levels in Table 10.4.2 are achieved.

Note M Based on extract from ABB Determination of Sound Level Report S/N 1LIT755437-01

In the emergency power outage scenario, the main noise sources will be diesel emergency back-up generators.

5.3 Calculation Methodology

A 3D computer-based prediction model has been prepared in order to quantify the noise level associated with the data storage facilities. This section discusses the methodology behind the noise modelling process.

5.3.1 Brüel & Kjær Type 7810 Predictor

Proprietary noise calculation software has been used for the purposes of this modelling exercise. The selected software, Brüel & Kjær Type 7810 Predictor, calculates noise levels in accordance with *ISO 9613: Acoustics – Attenuation of sound during propagation outdoors, Part 2: General method of calculation, 1996*.

Brüel & Kjær Type 7810 Predictor is a proprietary noise calculation package for computing noise levels in the vicinity of noise sources. Predictor calculates noise levels in different ways depending on the selected prediction standard. In general, however, the resultant noise level is calculated taking into account a range of factors affecting the propagation of sound, including:

- the magnitude of the noise source in terms of A weighted sound power levels (L_{WA});
- the distance between the source and receiver;
- the presence of obstacles such as screens or barriers in the propagation path;
- the presence of reflecting surfaces;
- the hardness of the ground between the source and receiver;
- Attenuation due to atmospheric absorption; and
- Meteorological effects such as wind gradient, temperature gradient and humidity (these have significant impact at distances greater than approximately 400m).

5.3.2 Brief Description of ISO9613-2:1996

ISO9613-2:1996 calculates the noise level based on each of the factors discussed previously. However, the effect of meteorological conditions is significantly simplified by calculating the average downwind sound pressure level, $L_{AT}(DW)$, for the following conditions:

- wind direction at an angle of $\pm 45^\circ$ to the direction connecting the centre of the dominant sound source and the centre of the specified receiver region with the wind blowing from source to receiver, and;
- wind speed between approximately 1ms^{-1} and 5ms^{-1} , measured at a height of 3m to 11m above the ground.

The equations and calculations also hold for average propagation under a well-developed moderate ground-based temperature inversion, such as commonly occurs on clear calm nights. The basic formula for calculating $L_{AT}(DW)$ from any point source at any receiver location is given by:

$$L_{rT}(DW) = L_W + D_c - A \quad \text{Eqn. A}$$

Where:

$L_{rT}(DW)$ is an octave band centre frequency component of $L_{AT}(DW)$ in dB relative to $2 \times 10^{-5}\text{Pa}$;

L_W is the octave band sound power of the point source;

- D_c is the directivity correction for the point source;
- A is the octave band attenuation that occurs during propagation, namely attenuation due to geometric divergence, atmospheric absorption, ground effect, barriers and miscellaneous other effects.

The estimated accuracy associated with this methodology is shown in Table 13 below:

Table 13 Estimated Accuracy for Broadband Noise of $L_{AT}(DW)$

Height, h^*	Distance, d^\dagger	
	$0 < d < 100m$	$100m < d < 1,000m$
$0 < h < 5m$	$\pm 3dB$	$\pm 3dB$
$5m < h < 30m$	$\pm 1dB$	$\pm 3dB$

* h is the mean height of the source and receiver. d is the mean distance between the source and receiver. N.B. These estimates have been made from situations where there are no effects due to reflections or attenuation due to screening.

5.3.3 Input Data and Assumptions

The noise model has been constructed using data from various source as follows:

- Site Layout** The general site layout has been obtained from the drawings forwarded by Kavanagh Tuite Architects.
- Local Area** The location of noise sensitive locations has been obtained from a combination of site drawings provided by Kavanagh Tuite Architects and others obtained from Ordnance Survey Ireland (OSI).
- Heights** The heights of buildings on site have been obtained from site drawings forwarded by Kavanagh Tuite Architects. Off-site buildings have been assumed to be 8m high for houses and 16m for apartments with the exception of industrial buildings where a default height of 15m has been assumed.
- Contours** Site ground contours/heights have been obtained from site drawings forwarded by Kavanagh Tuite Architects where available.

5.4 Predicted Noise Levels

This section presents the predicted noise levels at the nearest noise sensitive locations. The cumulative impact of all modelled noise sources on the site has been assessed for three distinct operational scenarios.

- Scenario A** would be considered to be the most representative of the day to day operation.
- Scenario B** is representative of emergency situation; a loss, reduction or instability of grid power supply, critical maintenance to power systems, a request from the utility supplier (or third party acting on its behalf) to reduce grid electricity load.
- Scenario C** considers the impact associated with the occasional testing of back-up emergency generators on the site. Typically, only one generator unit will be tested at any one time. The assessment presented here assumes the closest generator to existing noise sensitive locations are running

when presenting expected noise levels associated with the generator testing.

Figures 6, 7 and 8 presents the predicted noise contour plot for mechanical services and process plant associated with the development for Scenarios A, B and C receptively.

The predicted noise levels from new mechanical plant at each NSL are tabulated in Table 14.

Table 14 Predicted Operational Noise Levels at NSL's for New Mechanical Plant Items

Location	Plant Predicted Level (dB)		
	Scenario A	Scenario B	Scenario C
R01	41	54	41
R02	41	54	42
R03	43	55	43
R04	32	44	33
R05	33	46	34
R06	34	48	34
R07	34	48	35
R08	36	49	36
R09	36	50	37
R10	37	51	37
R11	36	51	36
R12	35	49	35
R13	33	45	33
R14	36	47	37
R15	40	51	40
R16	39	49	39
R17	39	49	39
R18	38	45	38
R19	40	48	40
R20	42	54	42

Table 15 present the predicted plant noise emission levels at the nearest NSL's and compares the results against the relevant criteria that have been derived for the site for Scenario A.

Table 15 Predicted Operational Noise Levels vs Criteria – Scenario A

Receptor	Predicted L _{Aeq,T}	Day (07:00 – 19:00hrs)		Evening (19:00 – 23:00hrs)		Night (23:00 – 07:00hrs)	
		Criterion dB L _{Ar,T}	Complies?	Criterion dB L _{Ar,T}	Complies?	Criterion dB L _{Aeq,T}	Complies?
R01	41	55	Yes	50	Yes	45	Yes
R02	41		Yes		Yes		Yes
R03	43		Yes		Yes		Yes
R04	32		Yes		Yes		Yes
R05	33		Yes		Yes		Yes
R06	34		Yes		Yes		Yes
R07	34		Yes		Yes		Yes
R08	36		Yes		Yes		Yes
R09	36		Yes		Yes		Yes
R10	37		Yes		Yes		Yes
R11	36		Yes		Yes		Yes
R12	35		Yes		Yes		Yes
R13	33		Yes		Yes		Yes
R14	36		Yes		Yes		Yes
R15	40		Yes		Yes		Yes
R16	39		Yes		Yes		Yes
R17	39		Yes		Yes		Yes
R18	38		Yes		Yes		Yes
R19	40		Yes		Yes		Yes
R20	42		Yes		Yes		Yes

For inspection purposes only. Consent of copyright owner required for any other use.

Table 16 present the predicted plant noise emission levels at the nearest NSL's and compares the results against the relevant criteria that have been derived for the site for Scenario B.

Table 16 Predicted Operational Noise Levels vs Criteria – Scenario B

Receptor	Predicted L _{Aeq,T}	Day (07:00 – 19:00hrs)		Evening (19:00 – 23:00hrs)		Night (23:00 – 07:00hrs)	
		Criterion dB L _{Ar,T}	Complies?	Criterion dB L _{Ar,T}	Complies?	Criterion dB L _{Aeq,T}	Complies?
R01	54	55	Yes	55	Yes	55	Yes
R02	54		Yes		Yes		Yes
R03	55		Yes		Yes		Yes
R04	44		Yes		Yes		Yes
R05	46		Yes		Yes		Yes
R06	48		Yes		Yes		Yes
R07	48		Yes		Yes		Yes
R08	49		Yes		Yes		Yes
R09	50		Yes		Yes		Yes
R10	51		Yes		Yes		Yes
R11	51		Yes		Yes		Yes
R12	49		Yes		Yes		Yes
R13	45		Yes		Yes		Yes
R14	47		Yes		Yes		Yes
R15	51		Yes		Yes		Yes
R16	49		Yes		Yes		Yes
R17	49		Yes		Yes		Yes
R18	45		Yes		Yes		Yes
R19	48		Yes		Yes		Yes
R20	54		Yes		Yes		Yes

For inspection purposes only. Consent of copyright owner required for any other use.

Table 17 present the predicted plant noise emission levels at the nearest NSL's and compares the results against the relevant criteria that have been derived for the site for Scenario C. Note emergency back up generator testing will only take place during daytime periods.

Table 17 Predicted Operational Noise Levels vs Criteria – Scenario C

Receptor	Predicted $L_{Aeq,T}$	Day (07:00 – 19:00hrs)		Evening (19:00 – 23:00hrs)		Night (23:00 – 07:00hrs)	
		Criterion dB $L_{Ar,T}$	Complies?	Criterion dB $L_{Ar,T}$	Complies?	Criterion dB $L_{Aeq,T}$	Complies?
R01	41	55	Yes	50	Yes	45	Yes
R02	42		Yes		Yes		Yes
R03	43		Yes		Yes		Yes
R04	33		Yes		Yes		Yes
R05	34		Yes		Yes		Yes
R06	34		Yes		Yes		Yes
R07	35		Yes		Yes		Yes
R08	36		Yes		Yes		Yes
R09	37		Yes		Yes		Yes
R10	37		Yes		Yes		Yes
R11	36		Yes		Yes		Yes
R12	35		Yes		Yes		Yes
R13	33		Yes		Yes		Yes
R14	37		Yes		Yes		Yes
R15	40		Yes		Yes		Yes
R16	39		Yes		Yes		Yes
R17	39		Yes		Yes		Yes
R18	38		Yes		Yes		Yes
R19	40		Yes		Yes		Yes
R20	42		Yes		Yes		Yes

For inspection purposes only.
Consent of copyright owner required for any other use.




Figure 6 Operational Noise Prediction Contours – Scenario A



Figure 7 Operational Noise Prediction Contours – Scenario B



Figure 8 Operational Noise Prediction Contours – Scenario C

6.0 CONCLUSION

A detailed noise survey has been completed at six noise sensitive locations surrounding the installation to establish the existing noise environment. This work has demonstrated that the existing noise environment is dictated by road traffic noise and noise associated with aircraft movements and some existing industry plant noise.

In accordance with the relevant NG4 Guidance, appropriate operational noise criteria have been derived for the site which are based on consideration of the existing licence noise conditions and the existing noise environment at the nearest NSL's.

A noise impact assessment has been completed using information obtained from the design team for significant items of new mechanical plant. A detailed computer-based noise model has been prepared using proprietary noise modelling software in accordance with the calculation method outlined in ISO 9613-2:1996.

The predicted noise levels at all NSL's are below the day, evening and night-time noise criteria that are applicable to the site operations.

*For inspection purposes only.
Consent of copyright owner required for any other use.*

APPENDIX A

GLOSSARY OF ACOUSTIC TERMINOLOGY

ambient noise	The totally encompassing sound in a given situation at a given time, usually composed of sound from many sources, near and far.
background noise	The steady existing noise level present without contribution from any intermittent sources. The A-weighted sound pressure level of the residual noise at the assessment position that is exceeded for 90 per cent of a given time interval, T ($L_{AF90,T}$).
broadband	Sounds that contain energy distributed across a wide range of frequencies.
dB	Decibel - The scale in which sound pressure level is expressed. It is defined as 20 times the logarithm of the ratio between the RMS pressure of the sound field and the reference pressure of 20 micro-pascals (20 μ Pa).
dB L_{pA}	An 'A-weighted decibel' - a measure of the overall noise level of sound across the audible frequency range (20 Hz – 20 kHz) with A-frequency weighting (i.e. 'A'-weighting) to compensate for the varying sensitivity of the human ear to sound at different frequencies.
Hertz (Hz)	The unit of sound frequency in cycles per second.
impulsive noise	A noise that is of short duration (typically less than one second), the sound pressure level of which is significantly higher than the background.
$L_{Aeq,T}$	This is the equivalent continuous sound level. It is a type of average and is used to describe a fluctuating noise in terms of a single noise level over the sample period (T). The closer the L_{Aeq} value is to either the L_{AF10} or L_{AF90} value indicates the relative impact of the intermittent sources and their contribution. The relative spread between the values determines the impact of intermittent sources such as traffic on the background.
L_{AFN}	The A-weighted noise level exceeded for N% of the sampling interval. Measured using the "Fast" time weighting.
L_{AFmax}	is the instantaneous slow time weighted maximum sound level measured during the sample period (usually referred to in relation to construction noise levels).
$L_{Ar,T}$	The Rated Noise Level, equal to the L_{Aeq} during a specified time interval (T), plus specified adjustments for tonal character and impulsiveness of the sound.
L_{AF90}	Refers to those A-weighted noise levels in the lower 90 percentile of the sampling interval; it is the level which is exceeded for 90% of the measurement period. It will therefore exclude the intermittent features of traffic and is used to estimate a background level. Measured using the "Fast" time weighting.

APPENDIX A

GLOSSARY OF ACOUSTIC TERMINOLOGY (Continued)

L_{AT}(DW)	equivalent continuous downwind sound pressure level.
L_{FT}(DW)	equivalent continuous downwind octave-band sound pressure level.
low frequency noise	LFN - noise which is dominated by frequency components towards the lower end of the frequency spectrum.
noise	Any sound, that has the potential to cause disturbance, discomfort or psychological stress to a person exposed to it, or any sound that could cause actual physiological harm to a person exposed to it, or physical damage to any structure exposed to it, is known as noise.
noise sensitive location	NSL – Any dwelling house, hotel or hostel, health building, educational establishment, place of worship or entertainment, or any other facility or other area of high amenity which for its proper enjoyment requires the absence of noise at nuisance levels.
octave band	A frequency interval, the upper limit of which is twice that of the lower limit. For example, the 1,000Hz octave band contains acoustical energy between 707Hz and 1,414Hz. The centre frequencies used for the designation of octave bands are defined in ISO and ANSI standards.
rating level	See L _{A,r,T} .
sound power level	The logarithmic measure of sound power in comparison to a referenced sound intensity level of one picowatt (1pW) per m ² where:
	$L_w = 10 \log \frac{P}{P_0} \text{ dB}$
	Where p is the rms value of sound power in pascals; and P ₀ is 1 pW.
sound pressure level	The sound pressure level at a point is defined as:
	$L_p = 20 \log \frac{P}{P_0} \text{ dB}$
specific noise level	A component of the ambient noise which can be specifically identified by acoustical means and may be associated with a specific source. In BS 4142, there is a more precise definition as follows: 'the equivalent continuous A-weighted sound pressure level at the assessment position produced by the specific noise source over a given reference time interval (L _{Aeq, T})'.

APPENDIX A**GLOSSARY OF ACOUSTIC TERMINOLOGY (Continued)**

tonal	Sounds which cover a range of only a few Hz which contains a clearly audible tone i.e. distinguishable, discrete or continuous noise (whine, hiss, screech, or hum etc.) are referred to as being 'tonal'.
1/3 octave analysis	Frequency analysis of sound such that the frequency spectrum is subdivided into bands of one-third of an octave each.

*For inspection purposes only.
Consent of copyright owner required for any other use.*

APPENDIX B

NOISE MODELLING DETAILS

Noise Model

A 3D computer-based prediction model has been prepared in order to quantify the noise level associated with the data storage facilities. This section discusses the methodology behind the noise modelling process.

Brüel & Kjær Type 7810 Predictor

Proprietary noise calculation software has been used for the purposes of this modelling exercise. The selected software, Brüel & Kjær Type 7810 Predictor, calculates noise levels in accordance with *ISO 9613: Acoustics – Attenuation of sound during propagation outdoors, Part 2: General method of calculation, 1996*.

Brüel & Kjær Type 7810 Predictor is a proprietary noise calculation package for computing noise levels in the vicinity of noise sources. Predictor calculates noise levels in different ways depending on the selected prediction standard. In general, however, the resultant noise level is calculated taking into account a range of factors affecting the propagation of sound, including:

- the magnitude of the noise source in terms of A weighted sound power levels (L_{WA});
- the distance between the source and receiver;
- the presence of obstacles such as screens or barriers in the propagation path;
- the presence of reflecting surfaces;
- the hardness of the ground between the source and receiver;
- Attenuation due to atmospheric absorption; and
- Meteorological effects such as wind gradient, temperature gradient and humidity (these have significant impact at distances greater than approximately 400m).

Brief Description of ISO9613-2: 1996

ISO9613-2:1996 calculates the noise level based on each of the factors discussed previously. However, the effect of meteorological conditions is significantly simplified by calculating the average downwind sound pressure level, $L_{AT}(DW)$, for the following conditions:

- wind direction at an angle of $\pm 45^\circ$ to the direction connecting the centre of the dominant sound source and the centre of the specified receiver region with the wind blowing from source to receiver, and;
- wind speed between approximately 1 ms^{-1} and 5 ms^{-1} , measured at a height of 3m to 11m above the ground.

The equations and calculations also hold for average propagation under a well-developed moderate ground-based temperature inversion, such as commonly occurs on clear calm nights.

The basic formula for calculating $L_{AT}(DW)$ from any point source at any receiver location is given by:

$$L_{AT}(DW) = LW + Dc - A \quad \text{Eqn. A}$$

Where:

$L_{AT}(DW)$ is an octave band centre frequency component of $L_{AT}(DW)$ in dB relative to $2 \times 10^{-5} \text{ Pa}$;

L_w is the octave band sound power of the point source;

D_c is the directivity correction for the point source;

A is the octave band attenuation that occurs during propagation, namely attenuation due to geometric divergence, atmospheric absorption, ground effect, barriers and miscellaneous other effects.

The estimated accuracy associated with this methodology is shown in Table B.1 below:

Table B.1 Estimated Accuracy for Broadband Noise of $L_{AT}(DW)$

Height, h^*	Distance, d^\dagger	
	$0 < d < 100m$	$100m < d < 1,000m$
$0 < h < 5m$	$\pm 3dB$	$\pm 3dB$
$5m < h < 30m$	$\pm 1dB$	$\pm 3dB$

* h is the mean height of the source and receiver. $\dagger d$ is the mean distance between the source and receiver.

N.B. These estimates have been made from situations where there are no effects due to reflections or attenuation due to screening.

Input Data and Assumptions

The noise model has been constructed using data from various source as follows:

Site Layout The general site layout has been obtained from the drawings forwarded by Kavanagh Tuite Architects.

Local Area The location of noise sensitive locations has been obtained from a combination of site drawings provided by Kavanagh Tuite Architects and others obtained from Ordinance Survey Ireland (OSI).

Heights The heights of buildings on site have been obtained from site drawings forwarded by Kavanagh Tuite Architects. Off-site buildings have been assumed to be 8m high for houses and 16m for apartments with the exception of industrial buildings where a default height of 15m has been assumed.

Contours Site ground contours/heights have been obtained from site drawings forwarded by Kavanagh Tuite Architects where available.

Figure B1 presents a 3D render of the developed site noise model for the current proposals.

Modelling Calculation Parameters²

Prediction calculations for plant noise have been conducted in accordance with *ISO 9613: Acoustics – Attenuation of sound during propagation outdoors, Part 2: General method of calculation, 1996*.

Ground attenuation factors of 1.0 have been assumed. No metrological corrections were assumed for the calculations. The atmospheric attenuation outlined in Table B.3 has been assumed for all calculations.

² See Appendix C for further discussion of calculation parameters.

Table B.3 Atmospheric Attenuation Assumed for Noise Calculations (dB per km)

Temp (°C)	% Humidity	Octave Band Centre Frequencies (Hz)							
		63	125	250	500	1k	2k	4k	8k
10	70	0.12	0.41	1.04	1.92	3.66	9.70	33.06	118.4




Figure B1 Images of Developed Noise Model – View of Site

APPENDIX C

NOISE MODELLING PARAMETERS

Prediction calculations for noise emissions have been conducted in accordance with *ISO 9613: Acoustics – Attenuation of sound during propagation outdoors, Part 2: General method of calculation, 1996*. The following are the main aspects that have been considered in terms of the noise predictions presented in this instance.

Directivity Factor: The directivity factor (D) allows for an adjustment to be made where the sound radiated in the direction of interest is higher than that for which the sound power level is specified. In this case the sound power level is measured in a down wind direction, corresponding to the worst-case propagation conditions and needs no further adjustment.

Ground Effect: Ground effect is the result of sound reflected by the ground interfering with the sound propagating directly from source to receiver. The prediction of ground effects is inherently complex and depend on source height receiver height propagation height between the source and receiver and the ground conditions. The ground conditions are described according to a variable defined as G, which varies between 0.0 for hard ground (including paving, ice concrete) and 1.0 for soft ground (includes ground covered by grass trees or other vegetation). Our predictions have been carried out using various source height specific to each plant item, a receiver heights of 1.6m for single storey properties and 4m for double. An assumed ground factor of G = 1.0 has been applied off site. Noise contours presented in the assessment have been predicted to a height of 4m in all instances. For construction noise predictions have been made at a level of 1.6m as these activities will not occur at night.

Geometrical Divergence This term relates to the spherical spreading in the free-field from a point sound source resulting in attenuation depending on distance according to the following equation:

$$A_{geo} = 20 \times \log (\text{distance from source in meters}) + 11$$

Atmospheric Absorption Sound propagation through the atmosphere is attenuated by the conversion of the sound energy into heat. This attenuation is dependent on the temperature and relative humidity of the air through which the sound is travelling and is frequency dependent with increasing attenuation towards higher frequencies. In these predictions a temperature of 10°C and a relative humidity of 70% have been used, which give relatively low levels of atmosphere attenuation and corresponding worst case noise predictions.

Table 10.6.1 Atmospheric Attenuation Assumed for Noise Calculations (dB per km)

Temp (°C)	% Humidity	Octave Band Centre Frequencies (Hz)							
		63	125	250	500	1k	2k	4k	8k
10	70	0.12	0.41	1.04	1.92	3.66	9.70	33.06	118.4

Barrier Attenuation

The effect of any barrier between the noise source and the receiver position is that noise will be reduced according to the relative heights of the source, receiver and barrier and the frequency spectrum of the noise.

For inspection purposes only.
Consent of copyright owner required for any other use.