

Electronic copy

On behalf of Amazon Data Services Ireland Limited



09 March 2022

Reg. No. P1171-01

Re: Appropriate Assessment in respect of a licence application from Amazon Data Services Ireland Limited in respect of the installation located at Clonshaugh Business & Technology Park, Dublin D17, D17 V088

Dear Sir or Madam,

I refer to your application for a licence application in respect of the installation located at Clonshaugh Business & Technology Park, Dublin D17, D17 V088 .

I am to advise you in accordance with Regulation 42(8)(a) of the European Communities (Birds and Natural Habitats) Regulations 2011 as amended, that the EPA has made a determination that an Appropriate Assessment is not required as the project, individually or in combination with other plans or projects, is not likely to have a significant effect on a European site(s). Notification of this determination is attached for your reference.

The application and all associated correspondence are available to view on the EPA website at www.epa.ie. You are advised to refer to the website for information on the progress of the application.

If you have any further queries, please contact licensing@epa.ie.

Yours faithfully,

Environmental Licensing Programme
Office of Environmental Sustainability
Tel: 053 – 9160600

Appropriate Assessment Screening Determination

In accordance with Regulation 42(1) of the European Communities (Birds and Natural Habitats) Regulations 2011 as amended, the Agency has undertaken Appropriate Assessment screening to assess, in view of best scientific knowledge and the conservation objectives of the site, if the activity, individually or in combination with other plans or projects is likely to have a significant effect on European Sites. In this context, particular attention was paid to the European Sites listed below.

Consent Details:

Reg. No.	P1171-01
Applicant Name:	Amazon Data Services Ireland Limited
Type of Consent Sought:	Industrial Emissions Licence
Location of installation:	Clonsaugh Business & Technology Park, Dublin D17, D17 V088
Licence Application Date:	21/01/2022
European Site(s) assessed:	Baldoyle Bay SAC (Site Code: 000199) North Dublin Bay SAC (Site Code: 000206) South Dublin Bay SAC (Site Code: 000210) Howth Head SAC (Site Code: 000202) Rockabill to Dalkey Island SAC (Site Code: 003000) South Dublin Bay and River Tolka Estuary SPA (Site Code: 004024) Baldoyle Bay SPA (Site Code: 004016) North Bull Island SPA (Site Code: 004006) Howth Head Coast SPA (Site Code: 004113)
Date of AA Screening Determination:	09/03/2022

AA Screening Determination:

That the activity is not directly connected with or necessary to the management of any European site and that it can be excluded, on the basis of objective information, that the activity, individually or in combination with other plans or projects, will have a significant effect on any European site and accordingly determined that an Appropriate Assessment of the activity was not required.

This determination is based on the following reasons:

- The installation is located in a business park and is not located within a European site.
- There are no direct process emissions to surface water or groundwater from the installation.
- Process effluent generated from the installation is discharged to the existing foul sewer network and ultimately treated in the licensed Ringsend WWTP. Process effluent consists of cooling water, rainfall runoff which has passed through the emergency generator exhausts and drainage from the bulk diesel storage areas and associated loading bays.
- The separation distance from European sites (approx. 5km) and their qualifying interests which are outside of the zone of influence of the installation in relation to noise and air emissions. Emissions to air consist of emissions from the emergency backup generators.

Rachel Neeson

Rachel Neeson

Office of Environmental Sustainability

Date: __09/03/2022__