

Industrial Emissions Licence

APPLICATION FORM

Organisation: Amazon Data Services Ireland Limited

Reg. No.: P1184-01

Application Receipt Date: 26 May 2022

Environmental Protection Agency

P.O. Box 3000, Johnstown Castle Estate, Co. Wexford

Lo Call: 1890 335599 Telephone: 053-9160600 Fax: 053-9160699

Web: www.epa.ie Email: licensing@epa.ie

Contents

OUT THIS APPLICATION FORM	3
Introduction	5
Organisation	6
Site	10
Activity and Capacity	12
Financial	29
Stakeholder Engagement	30
Emissions	31
Waste Generated On-Site	39
Environmental Management and Techniques	39
Submit Application	40
	Introduction

ABOUT THIS APPLICATION FORM

Application for an Industrial (including Intensive Agriculture) Licence or a Waste Licence or Review of a Licence

This application/review application covers three licence types; Industrial Emissions (IE), Integrated Pollution Control (IPC) and Waste, under the Environmental Protection Agency Act 1992 as amended and the Waste Management Act 1996 as amended.

This application has been developed by the EPA for the purposes of:

Making an application to the EPA for a licence or review of a licence or revised licence. In this
case, licence means Industrial Emissions (IE), Integrated Pollution Control (IPC) or Waste
Licence.

Further information and guidance on the licence application and review process is available on the EPA's website at: www.epa.ie.

Your licence application/review and all supporting information should be submitted to the EPA via EDEN, hereafter called 'Application Form'.

About the Application Form

The 'Application Form' must be completed in accordance with the instructions included in EDEN and available on the EPA website. A valid application for a licence must contain the information prescribed in the relevant Licensing Regulations available on the EPA website. The Regulations sets out the statutory requirements for information to accompany a licence application. The application form is designed in such a way as to set out these questions in a structured manner and not necessarily in the order presented in Regulation.

This 'Application Form' does not purport to be and should not be considered a legal interpretation of the provisions and requirements of the Environmental Protection Agency Act 1992 as amended or Waste Management Act 1996 as amended and the associated Regulations. While every effort has been made to ensure the accuracy of the material contained in the 'Application Form', the EPA assumes no responsibility and gives no guarantees, undertakings and warranties concerning the accuracy, completeness or up-to-date nature of the information provided herein and does not accept any liability whatsoever arising from any errors or omissions.

Should there be any contradiction between the information requirements set out in the 'Application Form' and any clarifying explanation on the EPA website then the requirements in this 'Application Form' shall take precedence. The requirements of the Regulations, shall take precedence over any considerations mentioned in this 'Application Form' or on the website.

Public Access

Information supplied in this 'Application Form' including supporting documentation and attachments will be put on public display on the internet and is therefore open to inspection by any person.

Confidential Information

Should you consider information to be confidential, this information should be submitted in a separate enclosure to the headquarters of the EPA bearing the legend "In the event this information is deemed not to be held as confidential, it must be returned to". In the event that the information is considered to be of a confidential nature, then the nature of this information, and the reasons why it is considered confidential (with reference to the "Access to Information on the Environment" Regulations) should be stated in the submission and the 'Application Form', where relevant.

Attachment format and file size

All files attached to this 'Application Form' should be submitted in searchable PDF format and be no larger than 10MB each in size.

The information you provide in this 'Application Form' will be used by the EPA to assess your application and may be used for other EPA purposes.

Please note that the EPA is subject to Freedom of Information Act 2014 and the Access to Environmental Information Regulations 2007 as amended. Any information that you save to EDEN at any time will be stored on the EPA's IT system and will be made available as required under law, including the above legislation.

The system generated Application ID for this licence application/review is: LA009979

1. Introduction

1.1. New/Review Authorisation Application

Is this a new or existing activity? New

1.2. Non-Technical Summary

Upload a copy of the non-technical summary, in accordance with the guidance.

Document Type	Document Name
Non Technical Summary	Attachment-1-2-Non Technical Summary

2. Organisation

2.1 Organisation Details

Business type

Body Corporate

Company CRO (Registration) number

390566

Organisation Name

Amazon Data Services Ireland Limited

Organisation Address

Organisation Registered Address

ONE BURLINGTON PLAZA

BURLINGTON ROAD

DUBLIN 4

Dublin 4

Dublin

D04RH96

Organisation's Website Address

Not Provided

Upload a Certificate of Incorporation, in accordance with the guidance, if applicable

Document Type	Document Name
Certificate of Incorporation	Attachment-2-1-Certificate of Incorporation

If the applicant is NOT the operator, please upload an attachment that states the name, address and telephone number of the operator and, if the operator is a body corporate, the address of its registered office or principal office (Optional):

Document Type	Document Name
No files	uploaded

Tick to confirm that the above organisation details are correct

NUTS 2 Code	NACE Code
IE061	6311

State the gross capital cost of the activity to which the application relates € 0.00

2.2 Primary Contact for Correspondence on this Application

Primary Contact Address of Primary Contact

Mr. Jonathan Gauntlett AWN Consulting

The Tecpro Building

Position in Organisation IDA Business and Technology Park

Consultant Dublin

N/A

Business Mobile Number

0831333370

Landline Number

Not Provided

Email Address

jonathan.gauntlett@awnconsulting.com

2.3 Primary Contact for Correspondence - Post Determination

Primary Contact Address of Primary Contact

Ms. Emer Tierney One Burlington Plaza

Burlington Road

Position in Organisation Dublin 4

Manager Dublin

Dublin

Business Mobile Number D04RH96

0867966974

Landline Number

Not Provided

Email Address

tierneye@amazon.com

2.4 Holding (Parent) Company

Does the organisation have a holding (parent) company?

Yes

Holding (parent) company name

Amazon EU S.à r.l. 15 Rue Plaetis. 2 L-2338. Luxembourg. Postcode L-2338

2.5 Fit and Proper Person

Convictions and Financial Commitment

Has the applicant or other relevant person been convicted as per guidance? No

Indicate whether the applicant or other relevant person has current or past bankruptcy or other insolvency proceedings against them or has entered into an arrangement with its creditors or suspended its business activities

No

Please confirm that the applicant, or other relevant persons, will be in a position to meet any financial commitments or liabilities that may have been or will be entered into or incurred in carrying on the activity to which the application relates or in consequence of ceasing to carry out that activity

Financial Commitments Declaration

Please download the attached declaration form, sign and upload the signed copy as a PDF document

Document Type	Document Name
Fit and Proper Declaration	Attachment-2-5 Financial-Commitments- Declaration

Technical Knowledge

Upload details of the applicant's technical knowledge and/or qualifications, along with that of other relevant employees.

Document Type	Document Name
Technical Knowledge	Attachment-2-5-3-Technical Knowledge

3. Site

3.1 Site Name and Address

State the site name (update if necessary)

ADSIL Grange Castle South

Site Address

Grange Castle Business Park South Baldonnell Road Dublin 22 Dublin Dublin D22 T2P7

NUTS 2 Code NUTS 3 Code

IE06 IE061

NACE Code

6311

Site Telephone Number

Not Provided

3.2 Site Geographical Location

Site Centre Point – Easting Site Centre Point – Northing

(Irish Grid Reference – 6 digits) (Irish Grid Reference – 6 digits)

302918 230689

Does the site cover multiple townlands?

Yes

Upload a document detailing the additional townland(s) covered by the site:

Document Type	Document Name
Additional Townlands	Attachment-3 Multiple Townlands Details

Upload a copy of the site plan(s) in accordance with the guidance:

Document Type	Document Name
Site Plan	21_123J-CSE-00-XX-DR-C-1200 FOUL WATER LAYOUT PLAN
Site Plan	21_123J-CSE-00-XX-DR-C-0002 SITE LAYOUT PLAN
Site Plan	21_123J-CSE-00-XX-DR-C-1100 SURFACE WATER LAYOUT
Site Plan	21_123J-CSE-00-XX-DR-C-2000 EMISSION LAYOUT PLAN

Upload a copy of the location map in accordance with the guidance:

Document Type	Document Name
Site Map	21_123J-CSE-00-XX-DR-C-0001 SITE LOCATION PLAN

3.3 Site Contact

Primary Contact

Ms. Emer Tierney

Position in Organisation

Manager

Business Mobile Number

0867966974

Landline Number

Not Provided

Email Address

tierneye@amazon.com

3.4 Site and Building Ownership

Is the applicant (or will the applicant be, in the case of a new activity) the owner of the site where the proposed activity is to take place?

No

Upload evidence of who owns the site and details of the arrangement in place with the applicant:

Document Type	Document Name
Site Ownership	AWS Letter confirming tenancy 220520

Is the applicant (or will the applicant be, in the case of a new activity) the owner of the building where the proposed activity is to take place?

No

Upload evidence of ownership of the building and details of the arrangement/ agreement in place with the applicant:

Document Type	Document Name
Building Ownership	AWS Letter confirming tenancy 220520

4. Activity and Capacity

4.1 Sectors and Classes of Activity

Add sectors and corresponding Classes of Activity relevant to the operation. Then select one Main Class of Activity using the radio buttons.

Sector	Activity and Description	IED Category of Activity	Main Class of Activity
Energy	2.1 – Combustion of fuels in installations with a total rated thermal input of 50 MW or more.	1.1	Yes

4.2 Application Type Confirmation

Based on the activities selected above the application type has been determined as:

Industrial Emissions Licence

4.3 Waste Activities

Section Not Required - based on applicant's response

4.4 Capacity

Other Capacity

Do you have to provide capacity information as per the guidance? $\ensuremath{\text{Yes}}$

Upload details of the capacity and how the capacity was calculated:

Document Type	Document Name
Activity Capacity Information	Attachment-4-4-1-Capacity Calculations

4.5 Other Regulations or Directives

Select all other regulations and directives that are relevant for activities carried out or proposed to be carried out at the installation or facility

	•	
1	EC (Control of Major Accident Hazards involving Da 74 of 2006)	angerous Substances) Regulations (S.I. No.
	No	
2	Greenhouse gas emissions regulations permit	
	Yes	
	Authorisation Number(where relevant)	Status (where relevant)
	IE-GHG201-03	Active
3	GMO regulations permit	
	No	
4	Waste authorisation (certificate of registration, wa	aste facility permit) regulations
	No	
5	Operator of equipment and systems containing oz with Regulation (EC) No. 1005/2009 on substances	
	No	
6	Operator of equipment and systems containing fluwith Regulation (EC) No. 842/2006 on certain fluor	
	No	
7	European Communities Mercury (Export Ban and S 2012)	Safe Storage) Regulations (S.I. No. 27 of
	No	

8	S.I. No 564 of 2012: European Union (Paints, Varnishes, Vehicle Refinishing Products and Activities) Regulations 2012
	No
9	Regulation (EC) No 1102/2008 of the European Parliament and of the Council of 22 October 2008 on the banning of exports or metallic mercury and certain mercury compounds and mixtures and the safe storage of metallic mercury
	No
10	Operator of an agro-food processing plant where Article 13 of the Council Directive 91/271/EEC concerning urban waste water treatment (> 4,000p.e WWTP discharging to surface water) applies
	No
11	Local Government (Water Pollution) Act, 1977 (Control of Cadmium Discharges) Regulations 1985 (S.I. No. 294 of 1985);
	No
12	Local Government (Water Pollution) Act, 1977 (Control of Hexachlorocyclohexane and Mercury Discharges) Regulations 1986 (S.I. No. 55 of 1986) No
13	Local Government (Water Pollution) Acts, 1977 and 1990 (Control of Carbon Tetrachloride, DDT and Pentachlorophenol Discharges) Regulations 1994 (S.I. No. 43 of 1994)
	No
14	Medium Combustion Plant Directive (EU) 2015/2193 on the limitation of emissions of certain pollutants into the air from medium combustion plants.
	No

Uploaded a document that describes how each selected regulation or directive is applicable to the activities

Document Type	Document Name	
Applicable Regulations	Attachment-4-5-1-Applicable Regulations	

Extractive Waste Regulations

Do the Extractive Waste Regulations (Waste Management (Management of Waste from the Extractive Industries) Regulations) apply to your activities?

No

4.6 Resource and Energy Usage

Water Usage

Do you or do you propose to abstract groundwater for use at the installation or facility? $\ensuremath{\mathsf{No}}$

Do you or do you propose to abstract surface water for use at the installation or facility? $\ensuremath{\text{No}}$

Do you or do you propose to use water from the public supply for use at the installation or facility?

Yes

Do you or do you propose to use water from another source for use at the installation or facility? $\ensuremath{\text{No}}$

Electricity Usage

Do you or do you propose to generate renewable electricity at the installation or facility? No

Do you or do you propose to generate non-renewable electricity at the installation or facility? Yes

Water and Energy Usage

Upload tabulated details of water and energy used or generated on the site.

Document Type	Document Name	
Water and Energy Usage	Attachment-4-6-1-Water-Energy-Usage	

Raw Materials, Intermediates and Products

Upload tabulated details of process related raw and ancillary materials, substances, preparations, intermediates, products etc., which will be produced by or utilised in the activity

Document Type	Document Name
Materials Used or Generated	Attachment-4-6-2-Raw-Material-Interm- Products

4.7 BAT (Best Available Techniques)

BAT Conclusions

Licence BAT Assessment			
CID	Best available techniques (BAT) conclusions, under Directive 2010/75/EU of the		
2017/1442/EU	2017/1442/EU European Parliament and of the Council, for large combustion plants		
General BAT Co	General BAT Conclusions		
BATC No.	Objective / Licensee Response / Attachment	Applicability	
1	In order to improve the overall environmental	Will Be	
	performance, BAT is to implement and adhere to an	20 June 2024	
	environmental management system (EMS) that	30 June 2024	
	incorporates all of the following features:		
	Click on the '[?]' link to see the full text of the BAT		
	conclusion.		
	Response : Applicable – See BAT 1 Attachment-4-7-1-BREF-		
	Large Combustion Plants		
2	BAT is to determine the net electrical efficiency and/or the	Yes	
	net total fuel utilisation and/or the net mechanical energy		
	efficiency of the gasification, IGCC and/or combustion units		
	by carrying out a performance test at full load (1),		
	according to EN standards		
	Click on the '[?]' link to see the full text of the BAT		
	conclusion.		
	Response: Applicable – See BAT 2 Attachment-4-7-1-BREF-		
	Large Combustion Plants		
3	BAT is to monitor key process parameters relevant for	Not Applicable	
	emissions to air and water including those given below.		
	Click on the '[?]' link to see the full text of the BAT		
	conclusion.		
	Response: Not Applicable – See BAT 3 Attachment-4-7-1-		
	BREF-Large Combustion Plants		
4	BAT is to monitor emissions to air with at least the	Not Applicable	
	frequency given below and in accordance with EN		
	standards. If EN standards are not available, BAT is to use		
	1	l	

	ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response: Not Applicable – See BAT 4 Attachment-4-7-1-BREF-Large Combustion Plants	
5	BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	Not Applicable
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response : Not Applicable – See BAT 5 Attachment-4-7-1-BREF-Large Combustion Plants	
6	In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is toensure optimised combustion and to use an appropriate combination of the techniques given below. Click on the '[?]' link to see the full text of the BAT	Yes
	conclusion.	
	Response : Applicable – See BAT 6 Attachment-4-7-1-BREF- Large Combustion Plants	
7	In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NOX emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NOX ratio, homogeneous reagent distribution and optimum size of the reagent drops).	Not Applicable
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response: Not Applicable – See BAT 7 Attachment-4-7-1-BREF-Large Combustion Plants	

8	In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability. Click on the '[?]' link to see the full text of the BAT conclusion. Response: Not Applicable – See BAT 8 Attachment-4-7-1-BREF-Large Combustion Plants	Not Applicable
9	In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1): Click on the '[?]' link to see the full text of the BAT conclusion. Response: Applicable – See BAT 9 Attachment-4-7-1-BREF-Large Combustion Plants	Will Be 30 June 2024
10	In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements: Click on the '[?]' link to see the full text of the BAT conclusion. Response: Applicable – See BAT 10 Attachment-4-7-1-BREF-Large Combustion Plants	Yes
11	BAT is to appropriately monitor emissions to air and/or to water during OTNOC. Click on the '[?]' link to see the full text of the BAT conclusion. Response: Not Applicable – See BAT 11 Attachment-4-7-1-BREF-Large Combustion Plants	Not Applicable

In order to increase the energy efficiency of combustion,	Not Applicable
gasification and/or IGCC units operated ? 1 500 h/yr, BAT is to use an appropriate combination of the techniques given below. Click on the '[?]' link to see the full text of the BAT	ног Арріісавіе
conclusion.	
Response : Not Applicable – See BAT 12 Attachment-4-7-1-BREF-Large Combustion Plants	
In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.	Not Applicable
Click on the '[?]' link to see the full text of the BAT conclusion.	
Response : Not Applicable – See BAT 13 Attachment-4-7-1-BREF-Large Combustion Plants	
In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.	Yes
Click on the '[?]' link to see the full text of the BAT conclusion.	
Response : Applicable – See BAT 14 Attachment-4-7-1-BREF-Large Combustion Plants	
In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.	Not Applicable
Click on the '[?]' link to see the full text of the BAT conclusion.	
Response : Not Applicable – See BAT 15 Attachment-4-7-1-BREF-Large Combustion Plants	
In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:	Not Applicable
	to use an appropriate combination of the techniques given below. Click on the '[?]' link to see the full text of the BAT conclusion. Response: Not Applicable – See BAT 12 Attachment-4-7-1-BREF-Large Combustion Plants In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below. Click on the '[?]' link to see the full text of the BAT conclusion. Response: Not Applicable – See BAT 13 Attachment-4-7-1-BREF-Large Combustion Plants In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content. Click on the '[?]' link to see the full text of the BAT conclusion. Response: Applicable – See BAT 14 Attachment-4-7-1-BREF-Large Combustion Plants In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution. Click on the '[?]' link to see the full text of the BAT conclusion. Response: Not Applicable – See BAT 15 Attachment-4-7-1-BREF-Large Combustion Plants In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account

	Click on the '[?]' link to see the full text of the BAT conclusion. Response: Not Applicable – See BAT 16 Attachment-4-7-1-BREF-Large Combustion Plants	
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below. Click on the '[?]' link to see the full text of the BAT conclusion. Response: Not Applicable – See BAT 17 Attachment-4-7-1-BREF-Large Combustion Plants	Not Applicable

	Licence BAT Assessment	
CID 2017/1442/EU	Best available techniques (BAT) conclusions, under Directive 2010/75/EU of the European Parliament and of the Council, for large combustion plants	
Combustion of L	iquid Fuels	
BATC No.	Objective / Licensee Response / Attachment	Applicability
28	In order to prevent or reduce NOX emissions to air while limiting CO emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given below. Click on the '[?]' link to see the full text of the BAT conclusion. Response: Not Applicable – See BAT 28 Attachment-4-7-1-BREF-Large Combustion Plants	Not Applicable
29	In order to prevent or reduce SOX, HCl and HF emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given below. Click on the '[?]' link to see the full text of the BAT conclusion. Response: Not Applicable – See BAT 29 Attachment-4-7-1-BREF-Large Combustion Plants	Not Applicable
30	In order to reduce dust and particulate-bound metal emissions to air from the combustion of HFO and/or gas oil	Not Applicable

	in boilers, BAT is to use one or a combination of the techniques given below.	
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response : Not Applicable – See BAT 30 Attachment-4-7-1-BREF-Large Combustion Plants	
31	In order to increase the energy efficiency of HFO and/or gas oil combustion in reciprocating engines, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.	Not Applicable
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response : Not Applicable – See BAT 31 Attachment-4-7-1-BREF-Large Combustion Plants	
32	In order to prevent or reduce NOX emissions to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given below.	Yes
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response: Applicable – See BAT 32 Attachment-4-7-1-BREF-Large Combustion Plants	
33	In order to prevent or reduce emissions of CO and volatile organic compounds to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or both of the techniques given below.	Not Applicable
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response : Not Applicable – See BAT 33 Attachment-4-7-1-BREF-Large Combustion Plants	
34	In order to prevent or reduce SOX, HCl and HF emissions to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given below.	Yes

	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response : Applicable – See BAT 34 Attachment-4-7-1-BREF-Large Combustion Plants	
35	In order to prevent or reduce dust and particulate-bound metal emissions from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given below.	Yes
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response: Applicable – See BAT 35 Attachment-4-7-1-BREF-Large Combustion Plants	
36	In order to increase the energy efficiency of gas oil combustion in gas turbines, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.	Not Applicable
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response : Not Applicable – No Gas Turbines. See BAT 36 Attachment-4-7-1-BREF-Large Combustion Plants	
37	In order to prevent or reduce NOX emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given below.	Not Applicable
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response : Not Applicable – No Gas Turbines. See BAT 37 Attachment-4-7-1-BREF-Large Combustion Plants	
38	In order to prevent or reduce CO emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given below.	Not Applicable
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response: Not Applicable – No Gas Turbines. See BAT 38 Attachment-4-7-1-BREF-Large Combustion Plants	

39	In order to prevent or reduce SOX and dust emissions to air from the combustion of gas oil in gas turbines, BAT is to use the technique given below.	Not Applicable
	Click on the '[?]' link to see the full text of the BAT conclusion.	
	Response : Not Applicable – No Gas Turbines. See BAT 39 Attachment-4-7-1-BREF-Large Combustion Plants	

BREF Select all relevant BAT reference document(s) (BREFs), provide an assessment against each

BREF	Document Type	BREF Document Name
Industrial Cooling Systems	BREF Assessment	Attachment-4-7-4-BREF-Industrial Cooling Systems
Energy Efficiency	BREF Assessment	Attachment-4-7-2-BREF-Energy Efficiency
Large Combustion Plants	BREF Assessment	Attachment-4-7-1-BREF-Large Combustion Plants
Emissions from Storage	BREF Assessment	Attachment-4-7-3-BREF-Emissions from Storage

EPA National BAT

Select all relevant EPA BAT guidance notes and attach the assessments made against them

EPA Bat Guidance Note	Document Type	EPA National BAT Assessment Document Name
No files uploaded		

4.8 Reports

Operational Report

Upload an 'Operational Report' for the activity in accordance with the guidance

Document Type	Document Name
Operational Report	Attachment-4-8-1 Operational Report

Baseline Report

Upload a report that addresses sections 1 to 3 of the <u>European Commission's guidance concerning</u> <u>baseline reports</u>

Document Type	Document Name
Baseline Screening	Attachment-4-8-2-Baseline Report

Does the report referred to above specify that a Baseline Report is required? \forall_{PS}

Upload the baseline report in accordance with the European Commission's guidance concerning baseline reports

Document Type	Document Name
Baseline Report	Attachment 4-8-3 Complete Baseline Report

Site Condition Report

Upload a document that describes the condition of the site of the installation or facility in accordance with the guidance

Document Type	Document Name
Site Condition Report	Attachment-4-8-4-Site Condition Report

4.9 Solvents

Do you or do you intend to use organic solvents at the installation or facility? $\ensuremath{\text{No}}$

4.10 Large Combustion Plants

Completed Template

Document Type	Document Name
LCP Section	Attachment-4-10-1-LCP-Plant Information

Additional Documents

Upload the additional documents referred to in the completed template

Document Type	Document Name
No files t	uploaded

Additional Questions

Does or will Chapter III of the IED apply to the plant or plant(s) identified?

Upload a brief description as to why Chapter III of the IED does not apply to the identified combustion plant(s).

Document Type	Document Name
IED Chapter III Applicability	Attachment-4-10-7-IED Chapter III

Upload a description of the abatement methods and technology proposed to be used at the LCP units/plants at the installation using the template provided.

Document Type	Document Name
LCP Abatement Methods	Attachment-4-10-2-LCP-Abatement

4.11 Incineration and Co-Incineration

Section Not Required - based on applicant's response

5. Financial

5.1 Financial Template

Completed template

Document Type	Document Name
Financial Application Section	Attachment-5-1-Financial

5.2 Additional Documents

Document Type	Document Name
Fee Payment Evidence	Attachment-5-2-Fee Payment Evidence

6. Stakeholder Engagement

6.1 Stakeholder Engagement Template

Completed template

Document Type	Document Name
Stakeholder Engagement Section	Attachment-6-1-Stakeholder-Engagement

6.2 Additional Documents

Document Type	Document Name
AA - Planning	Attachment-6-3-4-AA Screening-Planning-Apr- 2019
EIA Confirmation - Planning	Attachment-6-3-6-EIAR-Planning-Apr-2019
Evidence of Notices	Attachment-6-7-2-Evidence of Notices- Newspaper
Evidence of Notices	Attachment-6-7-3-Evidence of Notices-Map
Evidence of Notices	Attachment-6-7-1-Evidence of Notices-Site
Evidence of Notices	Attachment-6-7-4-Evidence of Notices-PA
PA/ABP Determination	Attachment-6-3-1-ABP Decision-Apr-2019
PA/ABP Determination	Attachment-6-3-1-ABP Report-Apr-2019
Planning Decision	Attachment-6-3-1-Planning Report-Feb-2021
Planning Decision	Attachment-6-3-1-Planning Decision-Feb-2021
Planning Decision	Attachment-6-3-1-Planning Decision-Apr-2019
Project and Threshold - Planning	Attachment-6-3-7-Project and Threshold- Planning

7. Emissions

7.1 Overview

Emissions, Discharges and Landspreading Applicability

With reference to the emissions/discharges from the installation and any associated landspreading activity indicate whether the thematic is applicable by inserting yes or no (Note: If you select 'no' you are indicating that there are no emissions of this type and your application will be considered on this basis)

Emission Type	Applicable
Emissions to Surface Water (not including Storm Water)	No
Emissions to Sewer	No
Emissions to Air (including minor, potential and fugitive emissions to air)	Yes
Noise Emissions and Noise Monitoring Points	Yes
Emissions to Ground (including disposal of sanitary effluent and potential emissions to ground) and Landspreading	No
Storm Water Discharges	Yes

Emissions Overview Template

Completed template

Document Type	Document Name
Emissions Overview Section	Attachment-7-1-Emissions-Overview

Additional Documents

Document Type	Document Name
Emissions Compliance Report	Attachment-7-1-3-1-Emissions Compliance Report
Emissions Impact Assessment	Attachment-7-1-3-2-Soil Water Impact

Emissions Impact Assessment	Attachment-7-1-3-2-Air Emissions Impact
Emissions Impact Assessment	Attachment-7-1-3-2-Noise Emissions Impact

7.0	Emigricus to Comfoco Water (not in the direct Charge Western)
7.2	Emissions to Surface Water (not including Storm Water)
Section	n Not Required – based on applicant's response

7.3 Emissions to Sewer	
Section Not Required – based on applicant's response	

7.4 Emissions to Air (including minor, potential and fugitive emissions to air) Emissions to Air (including minor, potential and fugitive emissions to air) Template

Completed template

Document Type	Document Name
Emissions - Air Section	Attachment-7-4-1-Emissions-to-Air-Main

Additional Documents

Document Type	Document Name
Minor - Potential Emissions	Attachment-7-4-2-Emissions-to-Air-Minor- Potential

7.5 Noise Emissions and Noise Monitoring Points

Noise Emissions and Noise Monitoring Points Template

Completed template

Document Type	Document Name
Emissions - Noise Section	Attachment-7-5-Noise-Emissions

ection Not Required	d – based on app	licant's respon	se	

7.7 Storm Water Discharges

Storm Water Discharges Template

Completed template

Document Type	Document Name
Storm Water Section	Attachment-7-7-1 Stormwater Monitoring

Additional Documents

Document Type	Document Name
Storm Water Monitoring	Attachment-7-7-Storm-Water-Discharges

8. Waste Generated On-Site

8.1 Waste Generated On-Site Template

Completed template

Document Type	Document Name
Waste Generated Section	Attachment-8-1-Waste-(Generated)

8.2 Additional Documents

Upload additional documents referred to in the completed template

Document Type	Document Name
Waste Hierarchy	Attachment-8-1-2-Waste Hierarchy

9. Environmental Management and Techniques

9.1 Environmental Management and Techniques Template

Completed template

Document Type	Document Name
EMT Section	Attachment-9-1-Environmental-Management- Techniques
EMT Section	Attachment-9-2-3-Fire Water Assessment

9.2 Additional Documents

Document Type	Document Name
Site Closure	Attachment 9-2-3 Site Closure Plan

10. Submit Application

Prior to submitting your completed application, please tick the box below to confirm the following:

- I declare that all the information and particulars given in this application form and all associated attachments are truthful, accurate and complete to the best of my knowledge and belief.
- I give consent to the EPA to copy this application form and all associated attachments for its own use and to make it available for inspection and copying by the public both in paper form and on the EPA's website. This consent relates to the application form itself, all associated attachments and to any further information, submission, objection, or submission to an objection whether provided by me as applicant or any person acting on the applicant's behalf.

✓ I confir

First Name	Surname
Alan	Judge
Danisia	
Position	
Director	

Upload a copy of scanned signature and company stamp

Document Type	Document Name
Signature and Company Stamp	Attachment-10-1-Signature-Stamp