

**Amazon Data Services Irelands Limited**

# **Energy Efficiency - BAT Reference Document**

**Attachment-4-7-1**

---

**Prepared by AWN Consulting**

**Licence Application Ref: LA009979**

---

**Conclusions on BAT from the Energy Efficiency BAT Reference Document (extracts)**

The full and complete Energy Efficiency BAT reference document (February 2009) is available at the EIPPC Bureau website: <http://eippcb.jrc.ec.europa.eu/reference/>. You may need to refer to this document in completing the form below.

**SCOPE OF BEST AVAILABLE TECHNIQUES (BAT)**

The particular processes and activities at the installation that may have particular relevance with regard to the scope of the conclusions on BAT from the Energy Efficiency reference document (BREF) are:

- Emergency generators
- Cooling systems – heating, ventilation, air conditioning
- Lighting
- Electrical power supply from mains
- IT hardware and associated equipment

Due to the Class of Activity being applied for it is the EPA’s expectation that an applicant has regard to these Horizontal BAT Conclusions for Energy Efficiency.

Conclusions on BAT	Applicability Assessment (Describe how the technique applies or not to your installation)	State whether it is in place or state schedule for implementation
<b>4.2.1 Energy Efficiency Management</b>		
<p><b>BAT 1.</b></p> <p>BAT is to implement and adhere to an energy efficiency management system (ENEMS) that incorporates, as appropriate to the local circumstances, all of the following features (see Section 2.1).</p> <ol style="list-style-type: none"> <li>a. Commitment of top management (commitment of the top management is regarded as a precondition for the successful application of energy efficiency management).</li> <li>b. Definition of an energy efficiency policy for the installation by top management.</li> <li>c. Planning and establishing objectives and targets (see BAT 2, 3 and 8).</li> <li>d. Implementation and operation of procedures paying particular attention to:                             <ul style="list-style-type: none"> <li>• Structure and responsibility</li> </ul> </li> </ol>	<p><b>Applicable</b> - Energy management forms an integral part of the installation’s management. Measures are in place to minimise energy use as far as possible.</p> <p>A Building Management System (BMS) and an Electrical Power Management System (EPMS) are in place to track the operation of critical sub-units and report back on energy efficiency of each section.</p>	<p>ENEMS will be in place 12 months after commencement of IE Licence</p>

<ul style="list-style-type: none"> <li>• Training, awareness and competence (see BAT 13)</li> <li>• Communication</li> <li>• Employee Involvement</li> <li>• Documentation</li> <li>• Effective control of processes (see BAT 14)</li> <li>• Maintenance (see BAT 15)</li> <li>• Emergency preparedness and response</li> <li>• Safeguarding compliance with energy efficiency-related legislation and agreements (where such agreements exist).</li> </ul> <p>e. Benchmarking: the identification and assessment of energy efficiency indicators over time (see BAT 8), and the systematic and regular comparisons with sector, national or regional benchmarks for energy efficiency, where verified data are available (see Sections 2.1(e), 2.16 and BAT 9).</p> <p>f. Checking performance and taking corrective action paying particular attention to:</p> <ul style="list-style-type: none"> <li>• Monitoring and measurement (see BAT 16)</li> <li>• Corrective and preventive action</li> <li>• Maintenance of records</li> <li>• Independent (where practical) internal auditing in order to determine whether or not the energy efficiency management system conforms to planned arrangements and has been properly implemented and maintained (see BAT 4 and 5)</li> </ul> <p>g. Review of the ENEMS and its continuing suitability, adequacy and effectiveness by top management.</p>	<p>An Environmental Management System (EMS) is currently being developed for the ADSIL facilities and will be reviewed to ensure it includes the requirements of this BREF and the requirements of the facility's IE Licence, once granted. The EMS will outline the management of the site's environmental program and will be broadly in line with the principals of ISO14001; however, it will not be accredited.</p> <p>Electrical performance monitoring in respect of Power Usage Effectiveness (PuE) of the site is undertaken on a continuous basis. PUE is an indicator for measuring the energy efficiency of a data centre. PuE is measured as a ratio of total amount of energy used by a computer data center facility to the energy delivered to computing equipment. An ideal PUE is 1.0. Anything that isn't considered a computing device in a data center (i.e. lighting, cooling, etc.) falls into the category of facility energy consumption.</p> <p>An energy efficiency management system (ENEMS) will be developed that will set out the energy targets for the facility and will define the facility's energy policy.</p> <p>Responsibility for the consumption of energy and utilities will be allocated to the Data Centre Engineering Operations (DCEO) Chief Engineer for the facility, and this responsibility will be set out in the EMS.</p> <p>The overall electrical energy for the facility is controlled and monitored to achieve the energy efficiency and power use effectiveness goals.</p>	
--	--	--

4.2.2 Planning and establishing objectives and targets		
4.2.2.1 Continuous environmental improvement		
<p><b>BAT 2.</b></p> <p>BAT is to continuously minimise the environmental impact of an installation by planning actions and investments on an integrated basis and for the short, medium and long term, considering the cost-benefits and cross-media effects.</p>	<p><b>Applicable</b> - Energy management forms an integral part of the installation's management. Measures are in place to minimise energy use as far as possible. ADSIL is committed to continually improving their energy efficiency and reducing their carbon footprint.</p> <p>The ENEMS will set out the energy targets for the specific facility on an annual basis along with the responsible party; and targets will be assessed at the end of each year and reported in the AER for the facility.</p> <p>Energy efficiency learnings are shared between sister facilities in Ireland and Europe.</p>	<p>ENEMS will be in place 12 months after commencement of IE Licence</p>
4.2.2.2 Identification of energy efficiency aspects of an installation and opportunities for energy savings		
<p><b>BAT 3.</b></p> <p>BAT is to identify the aspects of an installation that influence energy efficiency by carrying out an audit. It is important that an audit is coherent with a systems approach (see BAT 7).</p>	<p><b>Applicable</b> - Energy audits will be carried out in accordance with relevant EPA guidance Article 8 of the European Energy Efficiency Directive to identify further opportunities for energy efficiency improvement as part of facility management systems.</p> <p>ADSIL currently undertake Energy Efficiency audits, in the context of Article 8, every 4 years for a sample of their facilities in Ireland. The next compliance deadline is in 2023. The sites are selected randomly for auditing.</p>	<p>Will be undertaken as described in EPA guidance Article 8 of the European Energy Efficiency Directive</p>
<p><b>BAT 4.</b></p> <p>When carrying out an audit, BAT is to ensure that the audit identifies the following</p>	<p><b>Applicable</b> - ADSIL will ensure that the energy audits meet the requirements of this BAT.</p>	<p>Will be undertaken as described</p>

<p>aspects (see Section 2.11):</p> <ol style="list-style-type: none"> <li>a. Energy use and type in the installation and its component systems and processes</li> <li>b. Energy-using equipment, and the type and quantity of energy used in the installation</li> <li>c. Possibilities to minimise energy use, such as:             <ul style="list-style-type: none"> <li>• controlling/reducing operating times, e.g. switching off when not in use (e.g. see Sections 3.6, 3.7, 3.8, 3.9, 3.11)</li> <li>• ensuring insulation is optimised, e.g. see Sections 3.1.7, 3.2.11 and 3.11.3.7</li> <li>• optimising utilities, associated systems, processes and equipment (see Chapter 3)</li> </ul> </li> <li>d. Possibilities to use alternative sources or use of energy that is more efficient, in particular energy surplus from other processes and/or systems, see Section 3.3</li> <li>e. Possibilities to apply energy surplus to other processes and/or systems, see Section 3.3</li> <li>f. Possibilities to upgrade heat quality (see Section 3.3.2)</li> </ol>	<p>The results of these audits will be reported in the relevant facility's Annual Environmental Report (AER) as required.</p>	
<p><b>BAT 5.</b></p> <p>BAT is to use appropriate tools or methodologies to assist with identifying and quantifying energy optimisation, such as:</p> <ul style="list-style-type: none"> <li>• Energy models, databases and balances (see Section 2.15)</li> <li>• A technique such as pinch methodology (see Section 2.12) exergy or enthalpy analysis (see Section 2.13), or thermoeconomics (see Section 2.14)</li> <li>• Estimates and calculations (see Sections 1.5 and 2.10.2)</li> </ul>	<p><b>Applicable</b> - An energy efficiency management system (ENEMS) will be developed that will set out the energy targets for the facility and will define the facility's energy policy.</p> <p>The facility performance and equipment will be continually monitored using an Electrical Power Management System (EPMS) and a system will be in place to optimise performance. The EPMS monitors equipment in real time and will be able to identify areas of inefficiencies on an ongoing basis.</p> <p>This information from the continuous monitoring undertaken by the EPMS will feed into the energy database to determine the efficiencies of the units. There are energy databases and metrics for continuous improvement.</p> <p>Performance parameters will be in place and monitoring against the parameters will</p>	<p>ENEMS be place 12 months after commencement of IE Licence</p>

	<p>be used to ensure the facilities are operating efficiently.</p>	
<p><b>BAT 6.</b></p> <p>BAT is to identify opportunities to optimise energy recovery within the installation, between systems within the installation (see BAT 7) and/or with a third party (or parties), such as those described in Sections 3.2, 3.3 and 3.4.</p>	<p><b>Applicable</b> - throughout the design of the facility a systems approach was undertaken to optimise energy recovery.</p> <p>Energy recovery in the form of heat recovery is in place for the Installation for the office spaces as part of the fresh air ventilation system only. Energy efficient Heat Recover Units recover the waste heat and use it to pre-heat the incoming air thereby reducing the overall energy consumption of the heating system.</p>	<p>In place</p>
<p><b>4.2.2.3 A systems approach to energy management</b></p>		
<p><b>BAT 7.</b></p> <p>BAT is to optimise energy efficiency by taking a systems approach to energy management in the installation. Systems to be considered for optimising as a whole are, for example:</p> <ul style="list-style-type: none"> <li>• Process units (see sector BREFs)</li> <li>• Heating systems such as: <ul style="list-style-type: none"> <li>○ steam (see Section 3.2)</li> <li>○ hot water</li> </ul> </li> <li>• Cooling and vacuum (see the ICS BREF)</li> <li>• Motor driven systems such as: <ul style="list-style-type: none"> <li>○ compressed air (see Section 3.7)</li> <li>○ pumping (see Section 3.8)</li> </ul> </li> <li>• Lighting (see Section 3.10)</li> <li>• Drying, separation and concentration (see Section 3.11)</li> </ul>	<p><b>Applicable.</b> Throughout the design of the facility a systems approach was undertaken to optimise energy recovery.</p> <p>At design stage, each unit operation for the development has been assessed for energy efficiency most notably process, heating, cooling, heating, ventilation, Computer Room Air Handling Units (CRAHUs), motors / transformers and lighting.</p> <p>Energy efficiency of all the individual systems (lights, servers, fans, etc) is monitored continuously by the EPMS and used to determine the overall efficiency of the site.</p> <p>Cooling systems have been considered in the Industrial Cooling Systems BREF (Attachment 4.7.4).</p>	<p>In place</p>

	<p>The emergency generators (combustion plant) have been considered under the LCP BREF (Attachment 4.7.1).</p> <p>Motors, pumps, and lighting are addressed below.</p>	
<p><b>4.2.2.4 Establishing and reviewing energy efficiency objectives and indicators</b></p>		
<p><b>BAT 8.</b></p> <p>BAT is to establish energy efficiency indicators by carrying out all of the following:</p> <ol style="list-style-type: none"> <li>a. Identifying suitable energy efficiency indicators for the installation, and where necessary, individual processes, systems and/or units, and measure their change over time or after the implementation of energy efficiency measures (see Sections 1.3 and 1.3.4)</li> <li>b. Identifying and recording appropriate boundaries associated with the indicators (see Sections 1.3.5 and 1.5.1)</li> <li>c. Identifying and recording factors that can cause variation in the energy efficiency of the relevant process, systems and/or units (see Sections 1.3.6 and 1.5.2)</li> </ol>	<p><b>Applicable</b> –The ENEMS will include Key Performance Indicators (KPIs) for energy efficiency.</p> <p>The efficient use of energy will be monitored as part of the site’s continuous improvement programme to ensure all colleagues on site actively participate in the programme.</p> <p>Key process monitoring will be carried out to monitor the plant performance including water usage, energy consumption (diesel and electricity), hours of operation and power generated.</p> <p>The energy monitoring via the BMS will be accessible in real time so that future decisions on energy management/optimisation can be made on a fully informed basis.</p> <p>Electrical performance monitoring in respect of Power Usage Effectiveness (PuE) of the site is undertaken on a continuous basis. PUE is an indicator for measuring the energy efficiency of a data centre. PuE is measured as a ratio of total amount of energy used by a data center to the energy delivered to computing equipment. An ideal PUE is 1.0. Anything that isn’t considered a computing device in a data center (i.e.</p>	<p>ENEMS will be in place 12 months after commencement of IE Licence</p>

	lighting, cooling, etc.) falls into the category of facility energy consumption.	
<b>4.2.2.5 Benchmarking</b>		
<p><b>BAT 9.</b></p> <p>BAT is to carry out systematic and regular comparisons with sector, national or regional benchmarks, where validated data are available.</p>	<p><b>Applicable</b> – as a part of the ENEMS and energy audits, benchmarking will be undertaken.</p> <p>Electrical performance monitoring in respect of Power Usage Effectiveness (PuE) of the site is undertaken on a continuous basis. PUE is an indicator for measuring the energy efficiency of a data centre. PuE is measured as a ratio of total amount of energy used by a data center to the energy delivered to computing equipment. An ideal PUE is 1.0. Anything that isn't considered a computing device in a data center (i.e. lighting, cooling, etc.) falls into the category of facility energy consumption.</p> <p>The Sustainable Energy Authority of Ireland (SEAI) maintains benchmark records of energy performance, broken down by sector, which is used as part of site benchmarking.</p> <p>Comparisons are also be made to ADSIL's sister facilities in Ireland and Europe particularly with respect to PUE.</p>	<p>ENEMS will be in place 12 months after commencement of IE Licence</p>
<b>4.2.3 Energy efficient design (EED)</b>		
<p><b>BAT 10.</b></p> <p>BAT is to optimise energy efficiency when planning a new installation, unit or system or a significant upgrade (see Section 2.3) by considering all of the following:</p> <p>a. The energy efficient design (EED) should be initiated at the early stages of the conceptual design/basic design phase, even though the planned investments may</p>	<p><b>Applicable</b> - the data storage facility has been designed using energy efficient design (EED). EED has been incorporated into the electrical, mechanical and process design elements. The EED was carried out by an energy expert.</p>	<p>In place and ongoing</p>



<p>not be well-defined. The EED should also be taken into account in the tendering process</p> <ul style="list-style-type: none"> <li>b. The development and/or selection of energy efficient technologies (see Sections 2.1(k) and 2.3.1)</li> <li>c. Additional data collection may need to be carried out as part of the design project or separately to supplement existing data or fill gaps in knowledge</li> <li>d. The EED work should be carried out by an energy expert</li> <li>e. The initial mapping of energy consumption should also address which parties in the project organisations influence the future energy consumption and should optimise the energy efficiency design of the future plant with them. For example, the staff in the (existing) installation who may be responsible for specifying design parameters.</li> </ul>	<p>Any new capital equipment will be evaluated as per documented procedures for energy performance prior to purchase.</p> <p>Mapping of energy consumption across data servers and the cooling/heating systems has been undertaken to optimise efficiency and provide a clear understanding for future developments on the site. This process includes identifying which elements in any new ADSIL project are critical for influencing energy use at any new data storage facility.</p> <p>Photovoltaic panels will be installed on the roofs of the proposed data storage facility buildings to generate electricity to feed back into the electrical supply for the buildings, serving lighting, office area general services and office IT equipment.</p>	
<p><b>4.2.4 Increased process integration</b></p>		
<p><b>BAT 11.</b></p> <p>BAT is to seek to optimise the use of energy between more than one process or system (see Section 2.4), within the installation or with a third party.</p>	<p><b>Applicable</b> – energy supplied from the mains for the operation of the server hardware and associated ancillary equipment produces heat which must be managed by use of the roof mounted cooling plant. The waste heat is removed continually by motorised fans in the CRAHU system.</p> <p>Office air conditioning is provided by a Variable Refrigerant Flow (VRF) system which allows varying degrees of cooling across the office and support spaces thereby reducing energy consumption. High efficiency unit are used to minimise the electrical power demand.</p>	<p>In place and ongoing</p>

	<p>Waste heat from the office spaces for the Installation is re-used within the development as part of the fresh air ventilation system. Energy efficient Heat Recover Units recover the waste heat and use it to pre-heat the incoming air thereby reducing the overall energy consumption of the heating system.</p>	
<p><b>4.2.5 Maintaining the impetus of energy efficiency initiatives</b></p>		
<p><b>BAT 12.</b></p> <p>BAT is to maintain the impetus of the energy efficiency programme by using a variety of techniques, such as:</p> <ol style="list-style-type: none"> <li>a. Implementing a specific energy efficiency management system (see Section 2.1 and BAT 1)</li> <li>b. Accounting for energy usage based on real (metered) values, which places both the obligation and credit for energy efficiency on the user/bill payer (see Sections 2.5, 2.10.3 and 2.15.2)</li> <li>c. The creation of financial profit centres for energy efficiency (see Section 2.5)</li> <li>d. Benchmarking (see Section 2.16 and BAT 9)</li> <li>e. A fresh look at existing management systems, such as using operational excellence (see Section 2.5)</li> <li>f. Using change management techniques (also a feature of operational excellence, see Section 2.5)</li> </ol>	<p><b>Applicable</b> – a number of these measures are included in the design of the new facility and have been addressed across other BAT including management systems, real time monitoring of energy usage, etc.</p> <p>Critical plant performance and equipment is continually monitored by the BMS/EPMS, and a system is in place to optimise performance.</p> <p>ADSIL’s parent company is also involved in several energy efficiency schemes and has pledged to be net zero carbon by 2040.</p> <p>ADSIL is committed to operational excellence and is constantly working to improve energy efficiencies. A study by 451 Research found that ADSIL’s infrastructure is 5 times more energy efficient than the</p>	<p>In place and ongoing</p>

	<p>average European enterprise data centre surveyed.  <a href="https://blog.aboutamazon.eu/aws/eu-businesses-that-move-to-aws-cloud-improve-energy-efficiency-and-reduce-carbon-emissions">https://blog.aboutamazon.eu/aws/eu-businesses-that-move-to-aws-cloud-improve-energy-efficiency-and-reduce-carbon-emissions</a></p>	
<b>4.2.6 Maintaining expertise</b>		
<p><b>BAT 13.</b></p> <p>BAT is to maintain expertise in energy efficiency and energy-using systems by using techniques such as:</p> <ol style="list-style-type: none"> <li>a. Recruitment of skilled staff and/or training of staff. Training can be delivered by in-house staff, by external experts, by formal courses or by self-study/development (see Section 2.6)</li> <li>b. Taking staff off-line periodically to perform fixed term/specific investigations (in their original installation or in others, see Section 2.5)</li> <li>c. Sharing in-house resources between sites (see Section 2.5)</li> <li>d. Use of appropriately skilled consultants for fixed term investigations (e.g. see Section 2.11)</li> <li>e. Outsourcing specialist systems and/or functions</li> </ol>	<p><b>Applicable</b> – these techniques are applied relative to the sector, nature, scale, and complexity of the installation.</p> <p>ADSIL energy team are responsible for energy strategy, policy, and innovation..</p> <p>All staff employed to work at the data storage facilities are appropriately experienced Engineering Operations Technicians (EOT) and will be supervised by the Chief Engineer for each facility.</p> <p>ADSIL shares learnings and resources between its different data storage facilities including sharing the findings of energy audits for future learnings across all clusters.</p> <p>All investigations and reporting are completed by a suitably qualified consultants with experience in the relevant area.</p> <p>Specialist functions, audits, calibration or testing that cannot be carried out by the EOTs will be undertaken by suitably qualified contractors as and when required.</p>	<p>In place and ongoing</p>
<b>4.2.7 Effective control of processes</b>		
<p><b>BAT 14.</b></p>	<p><b>Applicable</b> – these techniques are applied relative to the sector, nature, scale, and complexity of the installation.</p>	<p>ENEMS will be in place 12 months after</p>

<p>BAT is to ensure that the effective control of processes is implemented by techniques such as:</p> <ol style="list-style-type: none"> <li>Having systems in place to ensure that procedures are known, understood and complied with (see Sections 2.1(d)(vi) and 2.5)</li> <li>Ensuring that the key performance parameters are identified, optimised for energy efficiency and monitored (see Sections 2.8 and 2.10)</li> <li>Documenting or recording these parameters (see Sections 2.1(d)(vi), 2.5, 2.10 and 2.15)</li> </ol>	<p>The facility is operated in accordance with a number of SOPs which address energy efficiency as well as the ENEMS which will outline how the use of energy will be minimised.</p> <p>Site maintenance and housekeeping systems are in place at the installation and relevant plant is included within a preventative maintenance schedule. This is managed by an Enterprise Asset Management System which is administered by a dedicated Asset Management Team. The EAM system records plant and equipment at each ADSIL site – each item is individually logged in the EAM system along with the PM requirements and frequency of maintenance required – an automatic update is sent to DCEO in advance when maintenance is due.</p> <p>Training programmes are in place to ensure that relevant operational and maintenance staff are aware of relevant procedures for ensuring energy efficiency.</p> <p>The ENEMS will outline the key performance parameters will be applied relative to the sector, nature, scale, and complexity of the installation.</p> <p>PuE is continuously measured and discussed with senior management on a weekly basis.</p>	<p>commencement of IE Licence</p>
<p><b>4.2.8 Maintenance</b></p>		
<p><b>BAT 15.</b> BAT is to carry out maintenance at installations to optimise energy efficiency by applying all of the following:</p>	<p><b>Applicable</b> – these techniques are applied relative to the sector, nature, scale, and complexity of the installation.</p>	<p>In place and ongoing</p>

<ul style="list-style-type: none"> <li>a. Clearly allocating responsibility for the planning and execution of maintenance</li> <li>b. Establishing a structured programme for maintenance based on technical descriptions of the equipment, norms, etc. as well as any equipment failures and consequences. Some maintenance activities may be best scheduled for plant shutdown periods</li> <li>c. Supporting the maintenance programme by appropriate record keeping systems and diagnostic testing</li> <li>d. Identifying from routine maintenance, breakdowns and/or abnormalities possible losses in energy efficiency, or where energy efficiency could be improved</li> <li>e. Identifying leaks, broken equipment, worn bearings, etc. that affect or control energy usage, and rectifying them at the earliest opportunity.</li> </ul>	<p>A comprehensive preventative maintenance regime is implemented at the facility by the maintenance team. This is managed by the Enterprise Asset Management System (see previous explanation).</p>	
<p><b>4.2.9 Monitoring and measurement</b></p>		
<p><b>BAT 16.</b></p> <p>BAT is to establish and maintain documented procedures to monitor and measure, on a regular basis, the key characteristics of operations and activities that can have a significant impact on energy efficiency. Some suitable techniques are given in Section 2.10</p>	<p><b>Applicable</b> – these techniques are applied relative to the sector, nature, scale, and complexity of the installation.</p> <p>Operational procedures incorporating measures aimed at ensuring the installation operates efficiently and safely will be in place. The facility will be operated in accordance with these procedures as well as the planned ENEMS which outlines how the use of energy will be minimised. All relevant staff will be trained in the procedures.</p> <p>Electrical performance monitoring in respect of Power Usage Effectiveness (PuE) of the site is undertaken on a continuous basis. PUE is an indicator for measuring the energy efficiency of a data centre. PuE is measured as a ratio of total amount of energy used by a computer data center facility to the energy delivered to computing equipment. An ideal PUE is 1.0. Anything that isn't considered a computing device in a data center (i.e. lighting, cooling, etc.) falls into the category of facility energy</p>	<p>ENEMS will be in place 12 months after commencement of IE Licence</p>

	<p>consumption. On-site electricity usage will be minimised as far as possible within the constraints of the process optimisation.</p> <p>Key process monitoring will be carried out to monitor the plant performance including water usage, energy consumption (diesel and electricity), hours of operation and power generated. Weekly metrics are gathered and compared for each site (fuel consumption/water consumption/ electrical demand).</p> <p>The plant performance and equipment will be continually monitored, and a system will be in place to optimise performance.</p> <p>The SOPs will be updated on a regular basis; the EMS will be updated annually in accordance with the requirements of the IE Licence.</p>	
<p><b>4.3 Best available techniques for achieving energy efficiency in energy-using systems, processes, activities, or equipment</b></p>		
<p><b>4.3.1 Combustion</b></p>		
<p><b>BAT 17.</b></p> <p>BAT is to optimise the energy efficiency of combustion by relevant techniques such as: those specific to sectors given in vertical BREFs, and those given in Table 4.1 (of the BREF document), including:</p> <ul style="list-style-type: none"> <li>• Advanced computer control of combustion conditions.</li> <li>• Reduced excess air.</li> <li>• Lowering exhaust gas temperatures</li> <li>• pre-heating of fuel gas using waste heat</li> <li>• pre-heating of combustion air.</li> <li>• Recuperative and regenerative burners.</li> <li>• Reducing heat losses by insulation.</li> <li>• Reducing losses through furnace doors.</li> </ul>	<p><b>Applicable</b> – Opportunities to optimise energy efficiency will be included in the ENEMS.</p> <p>The combustion processes are monitored through the EPMS which alarms in the event of a malfunction. Any operation of the combustion plant is tracked manually and automatically via the EAM system. Additional measures are addressed in Attachment 4-7-1. BREF Large Combustion Plants.</p> <p>The containerised emergency generators are pre-heated, and have engine jacket</p>	<p>ENEMS will be in place 12 months after commencement of IE Licence</p>

<ul style="list-style-type: none"> <li>Fluidised bed combustion</li> </ul>	<p>heaters, to ensure optimal start-up running conditions.</p> <p>Recuperative burners are not applicable to this site as combustion units are emergency back-up generators only.</p> <p>The fuel choice is restricted due to the type of units used (emergency back-up generators). However, their use is infrequent and under normal operating conditions will consist of regular testing and maintenance only. Pre-heating of natural gas is not applicable as only diesel fuel is used.</p> <p>Cogeneration is not applicable to the emergency back-up generators due to their infrequent use.</p>	
<p><b>4.3.2 Steam Systems</b></p>		
<p><b>BAT 18.</b></p> <p>BAT for steam systems is to optimise the energy efficiency by using techniques such as:</p> <ul style="list-style-type: none"> <li>Those specific to sectors given in vertical BREFs</li> <li>Those given in Table 4.2 (of the BREF document).</li> </ul>	<p><b>Not applicable</b> -no steam systems.</p>	<p>N/A</p>
<p><b>4.3.3 Heat Recovery</b></p>		
<p><b>BAT 19.</b></p> <p>BAT is to maintain the efficiency of heat exchangers by both:</p> <ol style="list-style-type: none"> <li>Monitoring the efficiency periodically, and</li> <li>Preventing or removing fouling</li> </ol>	<p><b>Not Applicable</b></p>	<p>N/A</p>
<p><b>4.3.4 Cogeneration</b></p>		
<p><b>BAT 20.</b></p>	<p><b>Not Applicable</b> – no viable cogeneration opportunities.</p>	<p>N/A</p>

BAT is to seek possibilities for cogeneration, inside and/or outside the installation (with a third party).													
<b>4.3.5 Electrical Power Supply</b>													
<p><b>BAT 21.</b></p> <p>BAT is to increase the power factor according to the requirements of the local electricity distributor by using techniques such as those in Table 4.3 (of the BREF document), according to applicability (see Section 3.5.1).</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>Installing capacitors in the AC circuits to decrease the magnitude of reactive power</td> <td>All cases. Low cost and long lasting, but requires skilled application</td> </tr> <tr> <td>Minimising the operation of idling or lightly loaded motors</td> <td>All cases</td> </tr> <tr> <td>Avoiding the operation of equipment above its rated voltage</td> <td>All cases</td> </tr> <tr> <td>When replacing motors, using energy efficient motors (see Section 3.6.1)</td> <td>At time of replacement</td> </tr> </tbody> </table>		Technique	Applicability	Installing capacitors in the AC circuits to decrease the magnitude of reactive power	All cases. Low cost and long lasting, but requires skilled application	Minimising the operation of idling or lightly loaded motors	All cases	Avoiding the operation of equipment above its rated voltage	All cases	When replacing motors, using energy efficient motors (see Section 3.6.1)	At time of replacement	<p><b>Applicable</b> – all of the items listed in Table 4.3 have been incorporated into the design of the new facility where applicable.</p> <p>The operator continuously monitors the electricity usage of all plant and equipment against the power drawn from the grid to ensure all systems meet the specified efficiency threshold.</p> <p>The electrical load is supplied to the critical IT load via the uninterrupted power supply (UPS), which also acts as power factor correction, capacitors are installed.</p> <p>During normal operation conditions plant equipment idle time is minimised when non-operational and managed as part of the site wide BMS.</p> <p>No equipment is operated above its rated voltage in normal operations.</p> <p>All motors will be energy efficient motors as per BAT 24.</p>	In place
Technique	Applicability												
Installing capacitors in the AC circuits to decrease the magnitude of reactive power	All cases. Low cost and long lasting, but requires skilled application												
Minimising the operation of idling or lightly loaded motors	All cases												
Avoiding the operation of equipment above its rated voltage	All cases												
When replacing motors, using energy efficient motors (see Section 3.6.1)	At time of replacement												
<p><b>BAT 22.</b></p> <p>BAT is to check the power supply for harmonics and apply filters if required (see Section 3.5.2)</p>		<p><b>Applicable</b> - ADSIL checks the power supply for harmonics and provides active harmonic input filters on UPS modules, no harmonic filters are required.</p>	In place										
<p><b>BAT 23.</b></p> <p>BAT is to optimise the power supply efficiency by using techniques such as those in Table 4.4 (of the BREF document), according to applicability.</p>		<p><b>Applicable</b> - At the design stage, each unit operation has been assessed for energy efficiency and factors such as location of high electrical load items relative to supply connection point, sizing of electrical transformers etc have been incorporated into the design.</p>	In place										



Technique	Applicability	<p>The measures listed Table 4.4 have been considers as part of the EED and there will be regular review to ensure that power supply efficiency measures are applied.</p> <p>To reduce electrical losses between HV/MV/LV conversions, the Operator has installed low loss transformers. These comply with the Eco-design directive 2009/125/EC as a minimum.</p>	
Ensure power cables have the correct dimensions for the power demand	When the equipment is not in use, e.g. at shutdown or when locating or relocating equipment		
Keep online transformer(s) operating at a load above 40 – 50 % of the rated power	<ul style="list-style-type: none"> <li>• for existing plants: when the present load factor is below 40 %, and there is more than one transformer</li> <li>• on replacement, use a low loss transformer and with a loading of 40 – 75 %</li> </ul>		
Use high efficiency/low loss transformers	At time of replacement, or where there is a lifetime cost benefit		
Place equipment with a high current demand as close as possible to the power source (e.g. transformer)	When locating or relocating equipment		
<b>4.3.6 Electric motor driven sub-systems</b>			
<p><b>BAT 24.</b></p> <p>BAT is to optimise electric motors in the following order (see Section 3.6):</p> <ol style="list-style-type: none"> <li>1. Optimise the entire system the motor(s) is part of (e.g. cooling system, see Section 1.5.1)</li> <li>2. Then optimise the motor(s) in the system according to the newly-determined load requirements, by applying one or more of the techniques in Table 4.5 (of the BREF document), according to applicability</li> <li>3. When the energy-using systems have been optimised, then optimise the remaining (non-optimised) motors according to Table 4.5 (of the BREF document) and criteria such as:                             <ul style="list-style-type: none"> <li>• Prioritising the remaining motors running more than 2000 hrs per year for replacement with EEMs</li> <li>• Electric motors driving a variable load operating at less than 50 % of capacity more than 20 % of their operating time and operating for more than 2000 hours a year should be considered for equipping with variable speed drives.</li> </ul> </li> </ol>		<p><b>Applicable</b> – Electric motors are used for fans in the air handling units and associated systems, as well as for the assorted pumping systems onsite.</p> <p>All electrical motors have been selected based on EED and are typically controlled and monitored by the BMS, or by onboard controllers that alarm in case of a fault.</p> <p>The cooling systems employed for the data halls have been designed to be as efficient as possible. The CRAHUs have high efficiency electrically commutated (EC) fans which are responsible for adjusting the exhaust fan speed based on the measured pressure differentials. The system is monitored and controlled by the BMS which monitors conditions and responds to reduce fan speeds and pump speed to maintain the operating point at the minimum necessary</p>	<p>In Place</p>

Driven system energy savings measure	Applicability	Section in this document <sup>1</sup>	
<b>SYSTEM INSTALLATION or REFURBISHMENT</b>			
Using energy efficient motors (EEM)	Lifetime cost benefit	3.6.1	
Proper motor sizing	Lifetime cost benefit	3.6.2	
Installing variable speed drives (VSD)	Use of VSDs may be limited by security and safety requirements. According to load. Note in multi-machine systems with variable load systems (e.g. CAS) it may be optimal to use only one VSD motor	3.6.3	
Installing high efficiency transmission/reducers	Lifetime cost benefit	3.6.4	
Use: • direct coupling where possible • synchronous belts or cogged V-belts in place of V belts • helical gears in place of worm gears	All	3.6.4	
Energy efficient motor repair (EEMR) or replacement with an EEM	At time of repair	3.6.5	
Rewinding: avoid rewinding and replace with an EEM, or use a certified rewinding contractor (EEMR)	At time of repair	3.6.6	
Power quality control	Lifetime cost benefit	3.5	
<b>SYSTEM OPERATION and MAINTENANCE</b>			
Lubrication, adjustments, tuning	All cases	2.9	
Note <sup>1</sup> : Cross-media effects, Applicability and Economics are given in Section 3.6.7			
<b>4.3.7 Compressed air systems (CAS)</b>			
<p><b>BAT 25.</b> - Optimise compressed air systems (CAS) as per table 4.6. BAT is to optimise compressed air systems (CAS) using the techniques such as those in Table 4.6 (of the BREF document), according to applicability, including the following.</p> <p>System design, installation or refurbishment techniques:</p> <ul style="list-style-type: none"> <li>- Overall system design, including multi-pressure systems</li> <li>- Upgrade compressor</li> </ul>			<p>to meet the data storage room environmental conditions.</p> <p>Other electric motors include those associated with the assorted pumping systems onsite (fuel distribution, cooling water distribution, stormwater, mains water). These are typically Energy Efficient Motors (IE 3 rated or better) and include VSDs were applicable/practical.</p> <p>All plant on site is subject to regular checks and preventative maintenance. Lubrication, adjustments, and tuning will be incorporated into system operation and maintenance as per BAT.</p>
			In place

<ul style="list-style-type: none"> <li>- Improve cooling, drying and filtering</li> <li>- Reduce frictional pressure losses (for example by increasing pipe diameter)</li> <li>- Improvement of drives (high efficiency motors)</li> <li>- Improvement of drives (speed control)</li> <li>- Use of sophisticated control systems</li> <li>- Recover waste heat for use in other functions</li> <li>- Use external cool air as intake</li> <li>- Storage of compressed air near highly-fluctuating uses</li> </ul> <p>System operation and maintenance techniques:</p> <ul style="list-style-type: none"> <li>- Optimise certain end use devices</li> <li>- Reduce air leaks</li> <li>- More frequent filter replacement</li> <li>- Optimise working pressure</li> </ul>		
<p><b>4.3.8 Pumping Systems</b></p>		
<p><b>BAT 26.</b> - Optimise pumping systems as per 4.3.8</p> <p>BAT is to optimise pumping systems by using the techniques in Table 4.7 (of the BREF document), according to applicability (see Section 3.8)</p> <p>Design techniques:</p> <ul style="list-style-type: none"> <li>- Avoid oversizing when selecting pumps and replace oversized pumps</li> <li>- Match the correct choice of pump to the correct motor for the duty</li> <li>- Design of pipework system (see Distribution system, below)</li> </ul> <p>Control and maintenance techniques:</p> <ul style="list-style-type: none"> <li>- Control and regulation system</li> <li>- Shut down unnecessary pumps</li> <li>- Use of variable speed drives (VSDs)</li> <li>- Use of multiple pumps (staged cut in) - When the pumping flow is less than half the maximum single capacity</li> <li>- Regular maintenance</li> </ul> <p>Distribution system techniques:</p>	<p><b>Applicable</b> – Pumps will be employed for the firewater main, water main, fuel delivery system, water treatment, and in the chilled water cooling system.</p> <p>Typically, pumps have been designed to their requirement; or when due for replacement will be not oversized, and will be matched correctly to the motor type, and the pipe size. All pumps will be controlled by the BMS and monitored continuously to ensure they are operating efficiently.</p> <p>All pumps will be subject to regular checks and preventative maintenance.</p> <p>Water and fuel distribution pipelines have been matched with the appropriate pump size. Bends and other obstructions have been reduced where practicable.</p>	<p>In place</p>

<ul style="list-style-type: none"> <li>- Minimise the number of valves and bends commensurate with keeping ease of operation and maintenance</li> <li>- Avoiding using too many bends (especially tight bends)</li> <li>- Ensuring the pipework diameter is not too small (correct pipework diameter)</li> </ul>		
<b>4.3.9 Heating, ventilation and air conditioning (HVAC) systems</b>		
<p><b>BAT 27.</b> - Optimise HVAC systems as per 4.3.9</p> <p>BAT is to optimise heating, ventilation and air conditioning systems by using techniques such as:</p> <ul style="list-style-type: none"> <li>• for ventilation, space heating and cooling, techniques in Table 4.8 (of the BREF document) according to applicability</li> <li>• for heating, see Sections 3.2 and 3.3.1, and BAT 18 and 19</li> <li>• for pumping, see Section 3.8 and BAT 26</li> <li>• for cooling, chilling and heat exchangers, see the ICS BREF, as well as Section 3.3 and BAT 19</li> </ul>	<p><b>Applicable-</b> the cooling and ventilation system for the server rooms is an integral part of the installation.</p> <p>The ventilation system for the data halls will be an air-cooled system whereby fresh air is used to cool the space. The warm air is recirculated or exhausted to atmosphere subject to external ambient conditions. Refrigerant cooling is used as an alternative during the peak temperatures.</p> <p>Further details are in Attachment 4-8-1 Operational Report.</p> <p>The cooling systems employed for the data halls have been designed to be as efficient as possible and this has been addressed in Attachment 4.7.4.</p> <p>The office air conditioning units are served by a VRF refrigerant system. High efficiency units will be used to minimise electrical power demand. Typically, the energy efficiency of a VRF system will exceed that of traditional air-cooled chillers by 15-25%. The fresh air ventilation system for the office area will be served using energy efficient Heat Recovery Units which will recover waste heat from the office spaces and re-use to pre-heat the air with the HRU. This</p>	<p>In place</p>

	<p>will reduce the overall energy consumption for this system.</p> <p>Routine preventative maintenance activities will be undertaken to optimise systems and reduce energy losses.</p>	
<b>4.3.10 Lighting</b>		
<p><b>BAT 28.</b> - Optimise lighting systems as per 4.3.10.</p> <p>BAT is to optimise artificial lighting systems by using the techniques such as those in Table 4.9 (of the BREF document) according to applicability</p>	<p><b>Applicable</b></p> <p>Artificial lighting both internal and external lighting are also an essential component of the security system, which is vital due to the sensitive nature of the site.</p> <p>External lighting will make use of high efficiency, low energy LED luminaires. The lighting design has been optimised to reduce glare, spillage, or other light nuisance to adjacent sites and/or public roads.</p> <p>Secondary external lighting in areas such as the generator compound will be operated via presence and daylight detection to minimize hours of operation and thus keep energy usage to a minimum.</p> <p>Internal lighting is be provided by highly efficient, low energy LED luminaires combined with presence detection controls or local switching where appropriate. The lighting design meets the illumination level requirements as outlined in EN 12464.</p> <p>LED luminaires are also to be used for the emergency lighting installation which is designed to comply with the requirements of EN 1838.</p>	<p>In place</p>

4.3.11 Drying, separation and concentration processes		
<p><b>BAT 29.</b>                      BAT is to optimise drying, separation and concentration processes by using techniques such as those in Table 4.10 (of the BREF document) according to applicability, and to seek opportunities to use mechanical separation in conjunction with thermal processes</p>	<p><b>Not Applicable</b> – no drying, separation, or concentration processes at the facility.</p>	<p>N/A</p>