Amazon Data Services Ireland Limited

Emissions from Storage BAT Reference Document

Attachment-4-7-3

Prepared by AWN Consulting

Licence Application Ref: LA009940

Conclusions on BAT from the Emissions from Storage BAT Reference Document (extracts)

The full and complete Emissions from Storage BAT reference document (July 2006) is available at the EIPPC Bureau website: http://eippcb.jrc.ec.europa.eu/reference/

SCOPE OF BAT

The particular processes and activities at the installation that come within the scope of the conclusions on BAT from the Emissions from Storage BAT reference documents (BREF) are:

- Diesel is stored in multiple locations across the site:
 - Bulk diesel is supplied to the emergency backup generator tanks from the Bulk Tank Farm(s). 3 no. 54,000 litre bulk tanks associated with Building W, and 5 no. 52,000 litre bulk tanks associated with Building X and Y,
 - o Building W: the emergency generators have 13 no. 2,500 litres double skinned steel day tanks,
 - o Building X: the emergency generators have 20 no. 2,500 litres double skinned steel day tanks,
 - o Building Y: the emergency generators have 7 no. 2,500 litres double skinned steel day tanks,
 - 2-no. diesel powered fire pumps at the sprinkler house associated with Building W have 3 no. 1,000 litre tanks for supply to the fire sprinkler pump, and
 - o 2-no. diesel powered fire pumps at the sprinkler house associated with Building X and Y have 3 no. 1,000 litre tanks for supply to the fire sprinkler pump.
- Diesel fuel pipelines above ground are Carbon Steel, and below ground are Close Fit PLX (dual-contained pipe system).

Due to the Class of Activity being applied for it is the EPA's expectation that an applicant has regard to these Horizontal BAT Conclusions for emissions from storage.

Conclusions on BAT	Applicability assessment and description of the technique.	Schedule for implementation
5.1 Storage of liquids and Liquefied gases 5.1.1.1 General principles to prevent and reduce emissions		
BAT 1. BAT for a proper design is to take into account at least the following:	Applicable – The bulk storage areas have been designed in accordance with the requirements of BAT.	EMS will be in place 12 months after



- the physico-chemical properties of the substance being stored
- how the storage is operated, what level of instrumentation is needed, how many operators are required, and what their workload will be
- how the operators are informed of deviations from normal process conditions (alarms)
- how the storage is protected against deviations from normal process conditions (safety instructions, interlock systems, pressure relief devices, leak detection and containment, etc.)
- what equipment has to be installed, largely taking account of past experiences of the product (construction materials, valve quality, etc.)
- which maintenance and inspection plan needs to be implemented and how to ease the maintenance and inspection work (access, layout, etc.)
- how to deal with emergency situations (distances to other tanks, facilities and to the boundary, fire protection, access for emergency services such as the fire brigade, etc.).

The primary chemical stored onsite is diesel for use in the emergency generators.

A site wide Environmental Management System (EMS) will be developed for the facility. In addition, Emergency Operating Procedures (EOP), and Standard Operating Procedures (SOP) have been developed for the facility to reduce the risk of spill. Staff will be fully trained in the use of the EOPs and SOPs.

The design of the chemical storage area at the facility has taken into account the requirement for full containment and all containers are appropriate for the chemicals stored within.

The bulk diesel tanks are steel tanks at atmospheric pressure. All tanks have been designed to BS799.

The emergency backup generators each have double skinned day tanks. All tanks have been designed to BS799.

There is full containment for diesel storage, and all containers are designed to be suitable for the chemicals stored within and in accordance with the EPA's guidelines for the storage and transfer of materials for scheduled activities (EPA, 2004).

Breather vents are installed for the bulk diesel storage tanks to prevent vacuum formation or overpressure in the tank during drawdown or tank filling, or due to atmospheric temperature changes.

Tank levels are monitored by level gauges with highhigh, low and low-low-level alarms. These will detect leaks in the tanks. Bunds and delivery bays are equipped with hydrocarbon probes in the bund sump which detects diesel in the bund. This triggers closure of the sump discharge and sends an alarm signal to commencement of IE Licence



	the BMS to alert EOTs. Further detail on this is supplied in the Operational Report (Attachment 4-8-1).	
	A standard operating procedure for fuel unloading is in place at the site. The 2 no. dedicated fuel tanker unloading areas include a stormwater drainage channel, that directs waters through the Class 1 hydrocarbon separator(s) to capture any hydrocarbon spill.	
	The site maintains spill kits at all storage areas, and stormwater systems including hydrocarbon interceptors are installed as discussed in Operational Report.	
	An on-site Emergency Response Plan (ERP) is in place for the existing data centre facilities and this will be updated to incorporate the additional developments as well as the requirements of the EPA's guidance.	
BAT 2. BAT is to apply a tool to determine proactive maintenance plans and to develop risk-based inspection plans such as the risk and reliability-based maintenance approach; see Section 4.1.2.2.1.	Applicable – A risk based preventative maintenance schedule will be developed for the facility which will form part of the EMS for the site; this will incorporate existing EPA guidance on materials storage.	
	Enterprise Asset Management (EAM) is the software platform ADSIL uses to maintain and manage its mechanical, electrical, and plumbing (MEP) equipment. This platform enables Infrastructure teams to do a variety of tasks:	
	 Track and coordinate planned and unplanned maintenance. 	In place
	 Track the full life cycle of critical data center assets. 	
	 Identify defective equipment through mechanisms like field service bulletins (FSBs). 	
	 Provide tracking for DCEO spare part inventory. 	



	Provide key insights for equipment failure, root cause analysis (RCA), and total cost of ownership (TCO). The EAM team maintains the EAM system – the EAM team objective is to create and maintain a reliable maintenance platform that improves operational excellence, reduces both equipment failures and maintenance costs, and promotes standardized processes that support operations in ADSIL data storage facilities. In addition to the PM there are also regular inspections of all infrastructure onsite. Checks of all plant are done by operations staff twice per shift.	
BAT3. BAT is to locate a tank operating at, or close to, atmospheric pressure aboveground. However, for storing flammable liquids on a site with restricted space, underground tanks can also be considered. For liquefied gases, underground, mounded storage or spheres can be considered, depending on the storage volume.	Applicable – All fuel storage tanks are above ground structures operating at or near to atmospheric pressure.	In place
BAT 4. BAT is to apply either a tank colour with a reflectivity of thermal or light radiation of at least 70 %, or a solar shield on aboveground tanks which contain volatile substances, see Section 4.1.3.6 and 4.1.3.7 respectively.	Applicable – The fuel storage tanks are supplied in an appropriate colour to reflect heat, in accordance with BAT.	In place
BAT 5. BAT is to abate emissions from tank storage, transfer and handling that have a significant negative environmental effect, as described in Section 4.1.3.1	Applicable – There is full containment and all containers are chosen to be appropriate for the chemicals stored within, and designed in accordance with the EPA's guidelines for the storage and transfer of materials for scheduled activities (EPA, 2004). The fuel tanks are be sealed and equipped with breathing vents for safety purposes. Emissions to air	In place



	from the tanks is not anticipated to have a significant negative environmental effect. Delivery of fuel oil will be a controlled process and is undertaken in accordance with the Fuel Delivery SOP. Deliveries are supervised and will take place in designated bunded loading bays. Hydrocarbon interceptors are in place for tanker delivery bays to capture any spills. The removal of any waste (oil/diesel) from the hydrocarbon interceptors is undertaken by a licenced contractor.	
BAT 6. On sites where significant VOC emissions are to be expected, BAT includes calculating the VOC emissions regularly.	Not Applicable – no bulk solvents stored.	N/A
BAT 7. BAT is to apply dedicated systems; see Section 4.1.4.4.	Applicable - All tanks are dedicated to the specific substances held within and will not be used to hold other substances at any time.	In place
5.1.1.2 Tank specific considerations		
BAT 8. Open top tanks If emissions to air occur, BAT is to cover the tank by applying: • a floating cover, see Section 4.1.3.2 • a flexible or tent cover, see Section 4.1.3.3, or • a rigid cover, see Section 4.1.3.4. Additionally, with an open top tank covered with a flexible, tent or a rigid cover, a vapour treatment installation can be applied to achieve an additional emission reduction, see Section 4.1.3.15. The type of cover and the necessity for applying the vapour treatment system depend on the substances stored and must be decided on a case-by-case basis.	Not Applicable – No Open Top Tanks	N/A



BAT 9. To prevent deposition that would call for an additional cleaning step, BAT is to mix the stored substance (e.g. slurry), see Section 4.1.5.1.	Not Applicable – No Open Top Tanks	N/A
BAT 10 External floating roof tank		
The BAT associated emission reduction level for a large tank is at least 97 % (compared to a fixed roof tank without measures), which can be achieved when over at least 95 % of the circumference the gap between the roof and the wall is less than 3.2 mm and the seals are liquid mounted, mechanical shoe seals.	Not Applicable – No external floating roof tanks	N/A
BAT 11.		
BAT is to apply direct contact floating roofs (double-deck), however, existing non-contact floating roofs (pontoon) are also BAT. See Section 3.1.2. A dome can be BAT for adverse weather conditions, such as high winds, rain or snowfall. See	Not Applicable – No external floating roof tanks	N/A
Section 4.1.3.5.		
BAT 12.		
For liquids containing a high level of particles (e.g. crude oil), BAT is to mix the stored substance to prevent deposition that would call for an additional cleaning step, see Section 4.1.5.1.	Not Applicable – No external floating roof tanks	N/A
BAT 13 Fixed roof tanks		
For the storage of volatile substances which are toxic (T), very toxic (T+), or carcinogenic, mutagenic and reproductive toxic (CMR) categories 1 and 2 in a fixed roof tank, BAT is to apply a vapour treatment installation.	Not Applicable – No volatile substances stored (diesel is a stable liquid at ambient temperatures).	N/A
BAT 14.		
For other substances, BAT is to apply a vapour treatment installation, or to install an internal floating roof (see Sections 4.1.3.15 and 4.1.3.10 respectively). Direct contact floating roofs and non-contact floating roofs are BAT.	Not Applicable –diesel is stored in liquid- and vaportight fixed roof tanks, equipped with breather valve.	N/A



BAT 15.	Applicable – The day tanks and fire sprinkler pump tanks are < 50 m ³ .	
For tanks < 50 m ³ , BAT is to apply a pressure relief valve set at the highest possible value consistent with the tank design criteria.	Breather vents are installed for all diesel tanks in accordance with the manufacturers design. Fuel tanks are at atmospheric pressure.	In place
BAT 16.		
For liquids containing a high level of particles (e.g. crude oil) BAT is to mix the stored substance to prevent deposition that would call for an additional cleaning step, see Section 4.1.5.1.	Not Applicable – no liquids containing a high level of particles stored.	N/A
BAT 17. Atmospheric horizontal tanks		
For the storage of volatile substances which are toxic (T), very toxic (T+), or CMR categories 1 and 2 in an atmospheric horizontal tank, BAT is to apply a vapour treatment installation.	Not Applicable – No volatile substances (diesel is a stable liquid at ambient temperatures).	N/A
BAT 18.		
For other substances, BAT is to do all, or a combination, of the following techniques, depending on the substances stored:		N/A.
apply pressure vacuum relief valves; see Section 4.1.3.11	Not Applicable – there are no atmospheric horizontal	
• up rate to 56 mbar; see Section 4.1.3.11	tanks; tanks are atmospheric vertical tanks and	
apply vapour balancing; see Section 4.1.3.13	breather valves are installed for all diesel tanks in accordance with the manufacturers design.	
apply a vapour holding tank, see Section 4.1.3.14, or	accordance man and management according in	
apply vapour treatment; see Section 4.1.3.15.		
The selection of the vapour treatment technology has to be decided on a case-by-case basis.		
BAT 19. Pressurised storage		
BAT for draining depends on the tank type, but may be the application of a closed drain system connected to a vapour treatment installation, see Section 4.1.4. The selection of the vapour treatment technology has to be decided on a case-by-case basis.	Not Applicable – No pressurised gas storage.	N/A



BAT 20. Lifter roof tanks		
For emissions to air, BAT is to (see Sections 3.1.9 and 4.1.3.14):	Not Applicable – No lifter roof tanks	
apply a flexible diaphragm tank equipped with pressure/vacuum relief valves, or		N/A
apply a lifter roof tank equipped with pressure/vacuum relief valves and connected to a vapour treatment installation.		
The selection of the vapour treatment technology has to be decided on a case-by-case basis.		
BAT 21. Underground and mounded tanks		
For the storage of volatile substances which are toxic (T), very toxic (T+), or CMR categories 1 and 2 in an underground or mounded tank, BAT is to apply a vapour treatment installation.	Not Applicable – No underground tanks	N/A
BAT 22.		
For other substances, BAT is to do all, or a combination, of the following techniques, depending on the substances stored:		
apply pressure vacuum relief valves; see Section 4.1.3.11		
apply vapour balancing; see Section 4.1.3.13	Not Applicable – No underground tanks	N/A
apply a vapour holding tank, see Section 4.1.3.14, or		
apply vapour treatment; see Section 4.1.3.15.		
The selection of the vapour treatment technology has to be decided on a case-by-case basis.		
5.1.1.3 Preventing incidents and (major) accidents		
BAT 23. BAT in preventing incidents and accidents is to apply a safety management system as described in Section 4.1.6.1.	Applicable - A safety management system (SMS) is currently being developed for ADSIL's facilities. The SMS will set out the ways ADSIL will prevent or minimise the occurrence of incidents and accidents. The safety management system will be reviewed to ensure it complies with this BAT.	SMS will be in place 12 months after commencement of IE Licence



BAT 24. BAT is to implement and follow adequate organisational measures and to enable training and instruction of employees for safe and responsible operation of the installation as described in Section 4.1.6.1.1.	Applicable – Relevant site staff will be fully qualified and fully trained for safe and responsible operation of the installation. All training records will be held on site. Training is provided to staff on all relevant SOPs, emergency response procedure, housekeeping, safety procedures and future EMS procedures.	EMS will be in place 12 months after commencement of IE Licence
BAT 25. BAT is to prevent corrosion by: • selecting construction material that is resistant to the product stored • applying proper construction methods • preventing rainwater or groundwater entering the tank and if necessary, removing water that has accumulated in the tank • applying rainwater management to bund drainage • applying preventive maintenance, and • where applicable, adding corrosion inhibitors, or applying cathodic protection on the inside of the tank.	Applicable - the fixed roof closed tanks are not expected to have significant rainwater infiltration. The materials of construction are appropriate for the material stored. This will ensure that corrosion is avoided. Diesel fuel pipelines above ground are Carbon Steel, and below ground are Close Fit PLX (dual-contained pipe system) corrosion is not expected to be a significant concern for these materials. Fuel pipelines are routinely inspected as part of the operation's daily inspections and during vendor maintenance. Tanks are integrity tested by the manufacturer prior to installation. Concrete bunds are integrity tested on site once construction has been completed. Enterprise Asset Management (EAM) is the software platform ADSIL uses to maintain and manage its mechanical, electrical, and plumbing (MEP) equipment. This platform notifies the DCEO team if maintenance is due on any piece of equipment or plant. Each bulk tank is bunded to a volume of 110% of the capacity of the tank within the bund. Drainage from the bunds is diverted for collection and safe disposal. Bunds and delivery bays are equipped with hydrocarbon probes in the bund sump which detects diesel in the bund. This triggers closure of the sump discharge and sends an alarm signal to the BMS to	In place



	alert EOTs. Further detail on this is supplied in the Operational Report (Attachment 4-8-1). Preventative maintenance is undertaken regularly at all ADSIL sites. Checks of all plant are done by operations staff twice per shift. Tanks, bunds, sump probes, etc. are regularly inspected in accordance with the EAM schedule.	
BAT 26. Additionally for an underground tank, BAT is to apply to the outside of the tank: a corrosion-resistant coating; plating, and/or a cathodic protection system.	Not applicable – No underground storage tanks.	N/A
BAT 27. BAT is to prevent stress corrosion cracking (SCC) by: • stress relieving by post-weld heat treatment, see Section 4.1.6.1.4, and • applying a risk based inspection as described in Section 4.1.2.2.1.	Applicable – Regular inspections and maintenance is carried out at the site as part of its preventative maintenance programme and repair of tanks and pipework is carried out as required. It is not envisioned that SCC will be an issue. There are no ammonia storage tanks on site, which are prone to SCC. The substances on site should not cause stress and is not within corrosive environment. Integrity testing (pressure testing) on the pipelines is completed at time of installation.	In place
BAT 28. BAT is to implement and maintain operational procedures – e.g. by means of a management system – as described in Section 4.1.6.1.5, to ensure that: • high level or high pressure instrumentation with alarm settings and/or auto closing of valves is installed • proper operating instructions are applied to prevent overfill during a tank filling operation, and • sufficient ullage is available to receive a batch filling.	Applicable - The fuel tanks also have high/low level alarms (90% high, 30% low) and a high-level switch at 95% which alarm to the BMS/EPMS critical alarm (locally referred to as high-high) and an equivalent low level alarm (low-low). A refuelling Standard Operating Procedure (SOP) is in place as part of the SOPs for the delivery of substances to the site to prevent tank overfill and will ensure that there is sufficient capacity in the tank to accept the delivery. Operations staff receive regular training on the SOP.	In place



	Applicable – The bulk fuel tank's bund contains hydrocarbon detection probes which shut off the bund drainage and alerts the operations staff by raising a critical alarm to the BMS to alert EOTs if diesel is detected in the bund.	
	The containerised emergency backup generator housing includes retention bunding in the base of the container, there are leak detection systems within the bund to alert in the event of a leak from the generator fuel day tank or lubricating oil tank	
BAT 29. BAT is to apply leak detection on storage tanks containing liquids that	Underground fuel distribution pipelines are double lined and comprise a system of leak detection.	In place
can potentially cause soil pollution.	Fuel unloading bays include concrete bunded areas, these fuel delivery areas are surrounded with hardstand concrete bases that drain to hydrocarbon interceptor.	
	The bulk diesel tanks are be fitted with automated level gauges and the online readings from these gauges are fed back into the facility's BMS/EPMS. The bulk tanks also have high/low level alarms (90% high, 30% low) and a high-level switch at 95% which alarm to the BMS/EPMS critical alarm (locally referred to as high-high) and an equivalent low level alarm (low-low).	
BAT 30.	Applicable – The diesel day tanks at the generators	
BAT is to achieve a 'negligible risk level' of soil pollution from bottom and bottom-wall connections of aboveground storage tanks. However,	are double skinned and located on hardstanding concrete areas.	
on a case-by-case basis, situations might be identified where an 'acceptable risk level' is sufficient.	The containerised emergency backup generator housing includes retention bunding in the base of the	la alone
A negligible risk for soil pollution can only be achieved by applying the following technical combinations:	container, there are leak detection systems within the bund to alert in the event of a leak from the generator	In place
 a thickness of the tank bottom of at least 6 mm, together with an impervious barrier between the tank bottom and soil surface, or 	fuel or lubricating oil tank. The onboard controller for individual generators is connected to the Building Management System (BMS).	



 an original double tank bottom with a leak detection system and the thickness of the primary and secondary bottom of at least 6 mm, or a thickness of the tank bottom of at least 5 mm, together with a leak detection system in combination with an external coating system and measures to prevent rainwater and groundwater ingress, or a combination of other maximum measures in combination with a non-corrosive product or a tank bottom of more than 3 mm thickness. 	The bulk diesel tanks are located within a concrete bund. Underground fuel distribution pipelines are double lined and comprise a system of leak detection. Due to the preventative measures outlined in the Operational Report 4-8-1 the onsite diesel storage is considered to meet a negligible risk level.	
BAT 31. BAT for aboveground tanks containing flammable liquids or liquids that pose a risk for significant soil pollution or a significant pollution of adjacent watercourses is to provide secondary containment, such as: • tank bunds around single wall tanks; see Section 4.1.6.1.11 • double wall tanks; see Section 4.1.6.1.13 • cup-tanks; see Section 4.1.6.1.14 • double wall tanks with monitored bottom discharge; see Section 4.1.6.1.15.	Applicable – All tanks are designed to fully meet the BAT requirements and are bunded in accordance with the EPA Guidance on Storage and Transfer of Materials. The bulk diesel storage tanks are contained within concrete bunds upon continuous hard standing. The day tanks at the generators are double skinned and located in an area of continuous hard stand.	In place
BAT 32. For building new single walled tanks containing liquids that pose a risk for significant soil pollution or a significant pollution of adjacent watercourses, BAT is to apply a full, impervious, barrier in the bund, see Section 4.1.6.1.10.	Applicable – The 8 no. steel bulk storage tanks are single skinned and are bunded within concrete bunds and located on hard stand. The design of all bunds conforms to standard bunding specifications - BS8007:1987. Not Applicable: The diesel day tanks at the generators are double skinned and located on hardstanding concrete areas.	In place
BAT 33. For existing tanks within a bund, BAT is to apply a risk-based approach, considering the significance of risk from product spillage to the soil, to determine if and which barrier is best applicable. This risk-	Not applicable – All tanks are new tanks in respect of this BAT.	N/A



based approach can also be applied to determine if a partial impervious barrier in a tank bund is sufficient or if the whole bund needs to be equipped with an impervious barrier. See Section 4.1.6.1.11.		
BAT 34.		
For chlorinated hydrocarbon solvents (CHC) in single walled tanks, BAT is to apply CHC-proof laminates to concrete barriers (and containments), based on phenolic or furan resins. One form of epoxy resin is also CHC-proof. See Section 4.1.6.1.12.	Not applicable – no bulk storage of solvents.	N/A
BAT 35.		
BAT for underground and mounded tanks containing products that can potentially cause soil pollution is to:		
• apply a double walled tank with leak detection, see Section 4.1.6.1.16, or	Not applicable – No underground storage tanks.	N/A
to apply a single walled tank with secondary containment and leak detection, see		
Section 4.1.6.1.17.		
BAT 36. For toxic, carcinogenic or other hazardous substances, BAT is to apply	Applicable – All tanks containing toxic, carcinogenic or other hazardous substances, are designed to fully meet the BAT requirements and are fully bunded in accordance with the EPA Guidance on Storage and	In place
full containment.	Transfer of Materials.	
5.1.2. Storage of packaged dangerous substances		
BAT 37.	Applicable A cofety management system (CMC) is	In place
BAT in preventing incidents and accidents is to apply a safety management system as described in Sections 4.1.6.1. The minimum level of BAT is to assess the risks of accidents and incidents on the site using the five steps described in Section 4.1.6.1	Applicable – A safety management system (SMS) is currently being developed for ADSIL's facilities along with the EMS. The SMS will set out the ways ADSIL will prevent or minimise the occurrence of incidents and accidents. The safety management system will be	
one doing the five steps described in decitor 4.1.0.1	reviewed to ensure it complies with this BAT.	SMS will be in place 12 months after



Step 1: identify the hazards Step 2: decide who and/or what may be harmed (and/or damaged and/or contaminated and how seriously)	Standard Operating Procedures for Emergency Response and Spill Prevention are in place.	commencement of IE Licence
Step 3: evaluate the risks arising from the hazards and decide whether existing precautions are adequate or if more needs to be done		
Step 4: record significant findings		
Step 5: review assessment from time to time and revise it if necessary.		
	Applicable – Relevant staff are be fully trained specifically in relation to the storage and handling of all substances being used at the facility.	
	Wastes are collected by appropriately authorised waste contractors for disposal offsite. ADSIL require third-party waste contractors to provide all the relevant permits and waste disposal documentation.	
BAT 38. BAT is to appoint a person or persons who is or are responsible for the operation of the store.	A number of waste SOPs are in place at the facility including a Hazardous Waste Management SOP. Online training is provided for all Operations staff which must be repeated on an annual basis including; Emergency Response and Spill kit deployment training.	In place
	The waste storage areas are inspected as part of the shift inspections and site staff must inspect all areas on a monthly basis to ensure that there is no unrecorded hazardous waste on site.	
BAT 39. BAT is to provide the responsible person(s) with specific training and retraining in emergency procedures as described in Section 4.1.7.1 and to inform other staff on the site of the risks of storing packaged dangerous substances and the precautions necessary to safely store substances that have different hazards.	Applicable – Relevant staff are fully trained in site procedures for safe and responsible operation of the installation. Online training is provided for all Operations staff which must be repeated on an annual basis including; Emergency Response and Spill kit deployment training.	In place



	The operations teams hold drills which are training exercises to ensure the operations staff are appropriately trained.	
BAT 40. BAT is to apply a storage building and/or an outdoor storage area covered with a roof, as described in Section 4.1.7.2. For storing quantities of less than 2500 litres or kilograms dangerous substances, applying a storage cell as described in Section 4.1.7.2 is also BAT.	Not Applicable – There are no external materials storage areas other than those stated, there are no smaller quantities (< 2500L) or dangerous substances stored. Any materials required, for example for maintenance, are brought to site by maintenance contractors.	N/A
BAT 41. BAT is to separate the storage area or building of packaged dangerous substances from other storage, from ignition sources and from other buildings on- and off-site by applying a sufficient distance, sometimes in combination with fire-resistant walls.	Applicable – The separation distances from ignition sources has been considered and implemented. It is anticipated that the only flammable material stored on a regular basis is diesel fuel oil.	In place
BAT 42. BAT is to separate and/or segregate incompatible substances. For the compatible and incompatible combinations see Annex 8.3.	Applicable – All incompatible substances are separated.	In place
BAT 43. BAT is to install a liquid-tight reservoir according to Section 4.1.7.5, that can contain all or a part of the dangerous liquids stored above such a reservoir. The choice whether all or only a part of the leakage needs to be contained depends on the substances stored and on the location of the storage (e.g. in a water catchment area) and can only be decided on a case-by-case basis.	Applicable – Bulk diesel is stored in concrete bunded tanks external to the buildings. The bunds are liquid tight and contain oil detection probes which shuts off the bund drainage and alerts the operations staff by raising a critical alarm to the BMS to alert EOTs if oil is detected in the bund. All other diesel is stored in double skinned day tanks, with bunding inside the containerised generator, the generators are located on continuous hardstand.	In place
BAT 44. BAT is to install a liquid-tight extinguishant collecting provision in storage buildings and storage areas according to Section 4.1.7.5. The collecting capacity depends on the substances stored, the amount of	Applicable – Penstocks will be installed to allow the stormwater discharge from the installation to be shut off in the event of a fire.	Will be in place on commencement of IE Licence



substances stored, the type of package used and the applied fire-fighting system and can only be decided on a case-by-case basis.		
BAT 45. BAT is to apply a suitable protection level of fire prevention and fire-fighting measures as described in Section 4.1.7.6. The appropriate protection level has to be decided on a case-by-case basis in agreement with the local fire brigade.	Applicable – There is a comprehensive fire detection and suppression systems in place across the facility. The appropriate protection level has been designed in agreement with the local fire authority.	In place
BAT 46. BAT is to prevent ignition at source as described in Section 4.1.7.6.1. • smoking and smokers' materials • maintenance work, particularly involving hot work • electrical power supplies • storage close to hot pipes or light fittings • arson • heating systems incorporating open flames • warehouse vehicles and battery charging facilities • LPG fuelled shrink-wrapping machines.	Applicable – SOPs are in place to prevent ignition at source as described in Section 4.1.7.6.1. Measures will also be incorporated within the EMS to prevent and reduce ignition in at risk areas. Measures include (but are not limited to); designated smoking areas, fire resistant control areas, appropriate security, and a scheduled routine maintenance program.	In place
5.1.3 Basins and lagoons		
 BAT 47. Where emissions to air from normal operation are significant, e.g. with the storage of pig slurry, BAT is to cover basins and lagoons using one of the following options: a plastic cover; see Section 4.1.8.2 a floating cover; see Section 4.1.8.1, or only small basins, a rigid cover; see Section 4.1.8.2. 	Not applicable – no storage basins or lagoons for the storage of raw materials or wastes on site.	N/A



Additionally, where a rigid cover is used, a vapour treatment installation can be applied to achieve an extra emission reduction, see Section 4.1.3.15. The need for and type of vapour treatment must be decided on a case-by-case basis.		
BAT 48.		
To prevent overfilling due to rainfall in situations where the basin or lagoon is not covered, BAT is to apply a sufficient freeboard, see Section 4.1.11.1.	Not applicable – no storage basins or lagoons for the storage of raw materials or wastes on site.	N/A
BAT 49.		
Where substances are stored in a basin or lagoon with a risk of soil contamination, BAT is to apply an impervious barrier. This can be a flexible membrane, a sufficient clay layer or concrete, see Section 4.1.9.1	Not applicable – no storage basins or lagoons for the storage of raw materials or wastes on site.	N/A
5.2 Transfer and handling of liquids and liquefied gases		
5.2 Transfer and handling of liquids and liquefied gases 5.2.1 General principles to prevent and reduce emissions		
	Applicable – Preventative maintenance and	
5.2.1 General principles to prevent and reduce emissions	Applicable – Preventative maintenance and corrective maintenance is undertaken regularly at all ADSIL sites. See further details on the Enterprise Asset Management (EAM) under BAT 2 above.	In place
5.2.1 General principles to prevent and reduce emissions BAT 50. BAT is to apply a tool to determine proactive maintenance plans and to develop risk-based inspection plans such as, the risk and reliability	corrective maintenance is undertaken regularly at all ADSIL sites. See further details on the Enterprise Asset Management (EAM) under BAT 2 above. Applicable – The bulk diesel tank bunds contain	In place
5.2.1 General principles to prevent and reduce emissions BAT 50. BAT is to apply a tool to determine proactive maintenance plans and to develop risk-based inspection plans such as, the risk and reliability	corrective maintenance is undertaken regularly at all ADSIL sites. See further details on the Enterprise Asset Management (EAM) under BAT 2 above. Applicable – The bulk diesel tank bunds contain diesel detection probes which shut off the bund drainage and alerts the operations staff by raising a	In place
5.2.1 General principles to prevent and reduce emissions BAT 50. BAT is to apply a tool to determine proactive maintenance plans and to develop risk-based inspection plans such as, the risk and reliability based maintenance approach; see Section 4.1.2.2.1.	corrective maintenance is undertaken regularly at all ADSIL sites. See further details on the Enterprise Asset Management (EAM) under BAT 2 above. Applicable – The bulk diesel tank bunds contain diesel detection probes which shut off the bund	In place



	Underground fuel distribution pipelines are double lined and comprise a system of leak detection. Checks of all plant are done by operations staff twice per shift (typically 4 times per day). Tanks, bunds, sump probes, etc. are regularly inspected in accordance with the schedule. Preventative maintenance and corrective maintenance are undertaken regularly at all ADSIL sites. The bunds have been constructed in accordance with the EPA Guidance on Storage and Transfer of Materials.	
BAT 52. BAT is to abate emissions from tank storage, transfer and handling that have a significant negative environmental effect, as described in Section 4.1.3.1.	Applicable – Handling and transfer of fuel and chemicals is carefully controlled to avoid waste and spills. Delivery of diesel fuel is a controlled process. and is undertaken in accordance with the Fuel Delivery SOP. Deliveries are supervised and will take place in designated bunded loading bays. Hydrocarbon interceptors capture any spills from the diesel unloading areas. Online training is provided for all relevant Operations staff which must be repeated on an annual basis including; Emergency Response and Spill kit deployment training. A site wide EMS will be developed for the facility. Designated staff will be trained in these procedures. Spill kits are available in storage areas across the site.	In place
BAT 53. BAT in preventing incidents and accidents is to apply a safety management system as described in Section 4.1.6.1.	Applicable - A safety management system is currently being developed for ADSIL's facilities. The SMS will set out the ways ADSIL will prevent or minimise the occurrence of incidents and accidents. The safety	SMS will be in place 12 months after commencement of IE Licence



	management system will be reviewed to ensure it	
	complies with this BAT.	
BAT 54. BAT is to implement and follow adequate organisational measures and to enable the training and instruction of employees for safe and	Applicable –Relevant staff are qualified and trained for safe and responsible operation of the installation. All training records will be held on site. Training will include training staff on all relevant SOPs, emergency response procedure, housekeeping, safety procedures.	In place
responsible operation of the installation as described in Section 4.1.6.1.1.	Online training is provided for all Operations staff on relevant SOPs which must be repeated on an annual basis, for example: Emergency Response and Spill kit deployment training.	
5.2.2 Considerations on transfer and handling techniques		
5.2.2.1 Piping		
BAT 55.	Applicable –The majority of pipelines related to the storage and transfer of materials are underground, Underground fuel distribution pipelines are double lined and comprise a system of leak detection.	
BAT is to apply aboveground closed piping in new situations, see Section 4.2.4.1. For existing underground piping it is BAT to apply a risk and reliability based maintenance approach as described in Section 4.1.2.2.1.	Above ground fuel pipelines are routinely inspected as part of the operation's daily inspections and during vendor maintenance. The Operations teams visually inspect front and rear crankshaft seals and lubrication system gasket for leaks, check fuel system for leaks (pumps, coolers, fuel tanks); inspect flexible fuel lines for cracking, leaks, and pliability; Inspect steel fuel lines for cracks, leaks, and proper line support.	In place
BAT 56.		
BAT is to minimise the number of flanges by replacing them with welded connections, within the limitation of operational requirements for equipment maintenance or transfer system flexibility, see Section 4.2.2.1.	Applicable – Diesel fuel pipelines above ground are Carbon Steel, and below ground are Close Fit double lined (dual-contained pipe system)	In place



	Where possible and practically feasible the use of flanges has been reduced, by using a fully welded system.	
BAT 57.	Applicable – The pipelines for diesel distribution	
BAT for bolted flange connections (see Section 4.2.2.2.) include:	include using a fully welded system at the tank and along the lines. Diesel fuel pipelines above ground are	
• fitting blind flanges to infrequently used fittings to prevent accidental opening	Carbon Steel, and below ground are Close Fit PLX (dual-contained pipe system).	
• using end caps or plugs on open-ended lines and not valves	Flanges have been minimised where practical by	
• ensuring gaskets are selected appropriate to the process application	utilising a fully welded system. Any flanges and valves are routinely inspected as part of the operations	In place
ensuring the gasket is installed correctly	inspections and during vendor maintenance.	
ensuring the flange joint is assembled and loaded correctly	Sheet gasketing is used for flanged connections. This	
 where toxic, carcinogenic or other hazardous substances are transferred, fitting high integrity gaskets, such as spiral wound, kammprofile or ring joints. 	provides increased residual gasket stress and greater blow out resistance. All gasketing will be installed by an appropriate installer / contractor.	
BAT 58.	Applicable – The materials of construction for	
BAT is to prevent corrosion by:	pipelines is be compatible with the materials being transferred. Diesel fuel pipelines above ground are	
• selecting construction material that is resistant to the product	Carbon Steel, and below ground are Close Fit PLX	In place
applying proper construction methods	(dual-contained pipe system).	
applying preventive maintenance, and	All pipelines are subject to preventative maintenance scheduled on the EAM system. A preventative maintenance schedule will form part of the EMS for the facility.	
 where applicable, applying an internal coating or adding corrosion inhibitors. 		
BAT 59.	Applicable – The pipelines for the transfer of	
To prevent the piping from external corrosion, BAT is to apply a one, two, or three layer coating system depending on the site-specific conditions (e.g. close to sea). Coating is normally not applied to plastic or stainless steel pipelines. See Section 4.2.3.2.	materials have been designed to be appropriate to the environment at the facility location. Diesel fuel pipelines above ground are Carbon Steel, and below ground are Close Fit PLX (Plastic).	In place
5.2.2.2 Vapour treatment		<u>'</u>



BAT 60. BAT is to apply vapour balancing or treatment on significant emissions from the loading and unloading of volatile substances to (or from) trucks, barges and ships. The significance of the emission depends on the substance and the volume that is emitted, and has to be decided on a case-by-case basis. For more detail see Section 4.2.8.	Not applicable – no bulk storage of solvents or other volatile substances.	N/A
5.2.2.3 Valves		
BAT 61.		
BAT for valves include:	Applicable - Non-return valves are fitted on the fuel	
correct selection of the packing material and construction for the process application	lines as required. Non return valves are fitted on the storage tanks to ensure pump prime and as a consequence the storage vessels shall operate independently of each other and tank levels will not normalise.	In place
 with monitoring, focus on those valves most at risk (such as rising stem control valves in continual operation) 		
 applying rotating control valves or variable speed pumps instead of rising stem control valves 	All valves are fit for purpose and are installed by a qualified contractor.	
 where toxic, carcinogenic or other hazardous substances are involved, fit diaphragm, bellows, or double walled valves 	All valves are routinely inspected as part of the operations inspections and during vendor maintenance.	
 route relief valves back into the transfer or storage system or to a vapour treatment system. 		
5.2.2.4 - Pumps and compressors		
BAT 62.	Applicable – diesel distribution pump, diesel sump	
The following are some of the main factors which constitute BAT:	pump, diesel polisher pump, fuel forwards pump and	
 proper fixing of the pump or compressor unit to its base-plate or frame 	fuel intake pump.	
having connecting pipe forces within producers' recommendations	All pumps are installed by a qualified contractor and are commissioned and tested prior to use. Installation is in accordance with BAT where relevant.	In place
 proper design of suction pipework to minimise hydraulic imbalance alignment of shaft and casing within producers' recommendations 	All pumps are registered on the Enterprise Asset Management (EAM) system to ensure that preventive	



alignment of driver/pump or compressor coupling within producers' recommendations when fitted	maintenance is undertaken at a frequency in accordance with the manufacturer's advice.	
correct level of balance of rotating parts		
effective priming of pumps and compressors prior to start-up		
operation of the pump and compressor within producers' recommended performance range (The optimum performance is achieved at its best efficiency point.)		
the level of net positive suction head available should always be in excess of the pump or compressor		
regular monitoring and maintenance of both rotating equipment and seal systems, combined with a repair or replacement programme.		
BAT 63.		
BAT is to use the correct selection of pump and seal types for the process application, preferably pumps that are technologically designed to be tight such as canned motor pumps, magnetically coupled pumps, pumps with multiple mechanical seals and a quench or buffer system, pumps with multiple mechanical seals and seals dry to the atmosphere, diaphragm pumps or bellow pumps. For more details see Sections 3.2.2.2, 3.2.4.1 and 4.2.9.	Applicable – All pumps have been sized, selected and purchased for their dedicated systems for the new facility where relevant, or will be re-sized when replacement is due.	In place
BAT 64.		
BAT for compressors transferring non-toxic gases is to apply gas lubricated mechanical seals.	Not applicable No transfer of gases.	N/A
BAT 65.		
BAT for compressors, transferring toxic gases is to apply double seals with a liquid or gas barrier and to purge the process side of the containment seal with an inert buffer gas.	Not applicable No transfer of gases.	N/A
BAT 66.		
In very high pressure services, BAT is to apply a triple tandem seal system.	Not applicable No transfer of gases.	N/A



5.2.2.5 Sampling connections		
BAT 67. BAT, for sample points for volatile products, is to apply a ram type sampling valve or a needle valve and a block valve. Where sampling lines require purging, BAT is to apply closed-loop sampling lines. See Section 4.2.9.14.	Not applicable – There will be no volatile products onsite.	N/A
5.3 Storage of solids		
5.3.1 Open storage		
BAT 68. BAT is to apply enclosed storage by using, for example, silos, bunkers, hoppers and containers, to eliminate the influence of wind and to prevent the formation of dust by wind as far as possible by primary measures. See Table 4.12 for these primary measures with cross-references to the relevant sections.	Not applicable – no bulk storage of solids.	N/A
BAT 69. BAT for open storage is to carry out regular or continuous visual inspections to see if dust emissions occur and to check if preventive measures are in good working order. Following the weather forecast by, e.g, using meteorological instruments on site, will help to identify when the moistening of heaps is necessary and will prevent unnecessary use of resources for moistening the open storage. See Section 4.3.3.1.	Not applicable – no bulk storage of solids.	N/A
BAT 70. BAT for long-term open storage are one, or a proper combination, of the following techniques: • moistening the surface using durable dust-binding substances, see Section 4.3.6.1 • covering the surface, e.g. with tarpaulins, see Section 4.3.4.4	Not applicable – no bulk storage of solids.	N/A



solidification of the surface, see Table 4.13		
• grassing-over of the surface, see Table 4.13.		
BAT 71.		
BAT for short-term open storage are one, or a proper combination, of the following techniques:		
moistening the surface using durable dust-binding substances, see Section 4.3.6.1	Not applicable – no bulk storage of solids.	N/A
moistening the surface with water, see Sections 4.3.6.1		
• covering the surface, e.g. with tarpaulins, see Section 4.3.4.4.		
5.3.2 Enclosed storage		
BAT 72.		
BAT is to apply enclosed storage by using, for example, silos, bunkers, hoppers and containers. Where silos are not applicable, storage in sheds can be an alternative. This is, e.g. the case if apart from storage, the mixing of batches is needed.	Not applicable – no bulk storage of solids.	N/A
BAT 73.		
BAT for silos is to apply a proper design to provide stability and prevent the silo from collapsing. See Sections 4.3.4.1 and 4.3.4.5.	Not applicable – no bulk storage of solids.	N/A
BAT 74.		
BAT for sheds is to apply proper designed ventilation and filtering systems and to keep the doors closed. See Section 4.3.4.2.	Not applicable – no bulk storage of solids.	N/A
BAT 75		
BAT is to apply dust abatement and a BAT associated emission level of 1 – 10 mg/m³, depending on the nature/type of substance stored. The type of abatement technique has to be decided on a case-by-case basis. See Section 4.3.7.	Not applicable – no bulk storage of solids.	N/A



BAT 76. For a silo containing organic solids, BAT is to apply an explosion resistant silo (see Section 4.3.8.3), equipped with a relief valve that closes rapidly after the explosion to prevent oxygen entering the silo, as described in Section 4.3.8.4.	Not applicable – no bulk storage of solids.	N/A
5.3.4 Preventing incidents and (major) accidents		
BAT 77.		
BAT in preventing incidents and accidents is applying a safety management system as described in Section 4.1.7.1.	Not applicable – no bulk storage of solids.	N/A
5.4 Transfer and handling of solids		
5.4.1 General approaches to minimise dust from transfer and handle	ing	
BAT 78.		
BAT is to prevent dust dispersion due to loading and unloading activities in the open air, by scheduling the transfer as much as possible when the wind speed is low. However, and taking into account the local situation, this type of measure cannot be generalised to the whole EU and to any situation irrespective of the possible high costs. See Section 4.4.3.1.	Not applicable – no bulk storage of solids.	N/A
BAT 79.		
When applying a mechanical shovel, BAT is to reduce the drop height and to choose the best position during discharging into a truck; see Section 4.4.3.4.	Not applicable – no bulk storage of solids.	N/A
BAT 80.		
BAT then is to adjust the speed of vehicles on-site to avoid or minimise dust being swirled up; see Section 4.4.3.5.2.	Not applicable – no bulk storage of solids.	N/A
BAT 81.	Not applicable – no bulk storage of solids.	N/A



BAT for roads that are used by trucks and cars only, is applying hard surfaces to the roads of, for example, concrete or asphalt, because these can be cleaned easily to avoid dust being swirled up by vehicles, see Section 4.4.3.5.3. However, applying hard surfaces to the roads is not justified when the roads are used just for big shovel vehicles or when a road is temporary.		
BAT 82.		
BAT is to clean roads that are fitted with hard surfaces according to Section 4.4.6.12.	Not applicable – no bulk storage of solids.	N/A
BAT 83.		
Cleaning of vehicle tyres is BAT. The frequency of cleaning and type of cleaning facility applied (see Section 4.4.6.13) has to be decided on a case-by-case basis.	Not applicable – no bulk storage of solids.	N/A
BAT 84.		
Where it neither compromises product quality, plant safety, nor water resources, BAT for loading/unloading drift sensitive, wettable products is to moisten the product as described in Sections 4.4.6.8, 4.4.6.9 and 4.3.6.1. Risk of freezing of the product, risk of slippery situations because of ice forming or wet product on the road and shortage of water are examples when this BAT might not be applicable.	Not applicable – no bulk storage of solids.	N/A
BAT 85.		
For loading/unloading activities, BAT is to minimise the speed of descent and the free fall height of the product; see Sections 4.4.5.6 and 4.4.5.7 respectively. Minimising the speed of descent can be achieved by the following techniques that are BAT:		
installing baffles inside fill pipes	Not applicable – no bulk storage of solids.	N/A
applying a loading head at the end of the pipe or tube to regulate the output speed		
applying a cascade (e.g. cascade tube or hopper)		
applying a minimum slope angle with, e.g. chutes.		



BAT 86.	Not applicable – no bulk storage of solids.	N/A		
To minimise the free fall height of the product, the outlet of the discharger should reach down onto the bottom of the cargo space or onto the material already piled up. Loading techniques that can achieve this, and that are BAT, are:				
height adjustable fill pipes				
height adjustable fill tubes, and				
height adjustable cascade tubes.				
These techniques are BAT, except when loading/unloading non drift sensitive products, for which the free fall height is not that critical.				
5.4.2 Considerations on transfer techniques				
BAT 87.	Not applicable – no bulk storage of solids.	N/A		
For applying a grab, BAT is to follow the decision diagram as shown in Section 4.4.3.2 and to leave the grab in the hopper for a sufficient time after the material discharge.				
BAT 88.		N/A		
BAT for new grabs, is to apply grabs with the following properties (see Section 4.4.5.1):	Not applicable – no bulk storage of solids.			
geometric shape and optimal load capacity				
• the grab volume is always higher than the volume that is given by the grab curve				
the surface is smooth to avoid material adhering, and				
a good closure capacity during permanent operation.				
BAT 89.	Not applicable – no bulk storage of solids.	N/A		
For all types of substances, BAT is to design conveyor to conveyor transfer chutes in such a way that spillage is reduced to a minimum. A				



modelling process is available to generate detail designs for new and existing transfer points. For more details see Section 4.4.5.5.		
BAT 90.		
For non or very slightly drift sensitive products (S5) and moderately drift sensitive, wettable products (S4), BAT is to apply an open belt conveyor and additionally, depending on the local circumstances, one or a proper combination of the following techniques:	Not applicable – no bulk storage of solids.	N/A
lateral wind protection, see Section 4.4.6.1		
• spraying water and jet spraying at the transfer points, see Sections 4.4.6.8 and 4.4.6.9, and/or		
belt cleaning, see Section 4.4.6.10.		
BAT 91.		
For highly drift sensitive products (S1 and S2) and moderately drift sensitive, not wettable products (S3) BAT for new situations, is to:		N/A
apply closed conveyors, or types where the belt itself or a second belt locks the material (see Section 4.4.5.2), such as:		
pneumatic conveyors		
trough chain conveyors		
screw conveyors		
tube belt conveyor	Not applicable – no bulk storage of solids.	
loop belt conveyor		
double belt conveyor		
or to apply enclosed conveyor belts without support pulleys (see Section 4.4.5.3), such as:		
aerobelt conveyor		
low friction conveyor		
conveyor with diabolos.		



The type of conveyor depends on the substance to be transported and on the location and has to be decided on a case-by-case basis.		
BAT 92.		
For existing conventional conveyors, transporting highly drift sensitive products (S1 and S2) and moderately drift sensitive, not wettable products (S3), BAT is to apply housing; see Section 4.4.6.2. When applying an extraction system, BAT is to filter the outgoing air stream; see Section 4.4.6.4.	Not applicable – no bulk storage of solids.	N/A
BAT 93.		
To reduce energy consumption for conveyor belts (see Section 4.4.5.2), BAT is to apply:	Not applicable – no bulk storage of solids.	N/A
a good conveyor design, including idlers and idler spacing		
an accurate installation tolerance, and		
a belt with low rolling resistance.		

