## 9c) Confirm if non-condensable gases and tallow are combusted in the existing boilers.

BEP-3 – Natural gas, diesel, or tallow can be combusted as fuel in the Standby boiler.

AEP 2 – The Thermal Oxidiser can operate on natural gas, diesel, or tallow.

Non-condensable cannot be combusted within the standby boiler.