

29 March 2023

Office of Environmental Sustainability
Environmental Protection Agency
PO Box 3000
Johnstown Castle Estate
Co. Wexford

Unit 5, ATS Building,
Carrigaline Industrial Estate, Carrigaline,
Co. Cork, Ireland

T: + 353 21 438 7400
F: + 353 21 483 4606
E: info@awnconsulting.com
W: www.awnconsulting.com

RE: Regulation 10(2)(b)(ii) of the EPA (Industrial Emissions) (Licensing) Regulations 2013, in respect of the licence application P1182-01

Dear Sir/Madam,

As requested by the Regulation 10(2)(b)(ii) Notice received on 14 March 2023 Amazon Data Services Ireland Limited is required to supply additional information.

Request 1: Confirm the minimum volume of water, if any, that is retained in each of the attenuation tanks under dry weather conditions.

Response to Request 1: There is negligible retained water within the attenuation ponds under dry weather conditions.

Request 2: Confirm the allowable greenfield runoff rate (m^3/hour) for the installation, required under the relevant planning permission(s).

Response to Request 2: The cumulative discharge rate from the overall landholding will not exceed the permitted discharge rate granted under planning reg ref: FW17A/0025 of 126.3l/s

Sincerely,



Jonathan Gauntlett

Principal Environmental Consultant
AWN Consulting

Dublin Office
The Tecpro Building,
Clonsaugh Business & Technology Park,
Dublin 17, Ireland.
T: + 353 1 847 4220
F: + 353 1 847 4257

AWN Consulting Limited
Registered in Ireland No. 319812
Directors: F Callaghan, C Dilworth,
T Donnelly, T Hayes, D Kelly, E Porter