

***Extract from the Minutes of the 1128<sup>th</sup> Licensing Meeting of the Agency was held on 1 August 2023, in EPA Headquarters, Johnstown Castle Estate, County Wexford.***

The 1128<sup>th</sup> Licensing Meeting of the Agency was held on 1 August 2023, in the EPA Headquarters, Johnstown Castle Estate, County Wexford.

Directors Present: L Burke (Chair);  
G O' Leary, M Lehane & E Cotter (via Video Conference).

**4. Objection to a Proposed Determination of an Application for an Industrial Emissions (IE) Licence**

*Licensee:* **SSE Generation Ireland Limited  
Great Island Generating Station  
Campile  
New Ross  
County Wexford**

*Register of Licence No:* **P0606-04**

The Directors considered the following documentation: Proposed Determination issued on 9 February 2022; one First-Party objection; five third party objections, one submission on the objections and the Report and Recommendations of the Technical Committee, Office of Environmental Sustainability.

A copy of the licence application was available electronically.

Philip Stack, Alison McCarthy and Marie O' Connor gave verbal presentations.

**Technical Committee Report**

The Directors noted the Technical Committee Report. The Directors approved the recommendations of the Technical Committee with the following amendment:

**A.5 Auxiliary Boilers - Monitoring and Flow Limits**

The recommendation should be amended as follows:

Non-Continuous Monitoring:

- (i) For flow, no hourly or daily mean value, calculated on the basis of appropriate spot readings, shall exceed the relevant emission limit value.
- (ii) For nitrogen oxides and carbon monoxide, no 60 minute mean value shall exceed the hourly average emission limit value.
- (iii) For all other parameters, no 60 minute mean value shall exceed the daily average emission limit value.
- (iv) ~~A suitable sampling period regime should be employed, subject to approval by the Agency~~ For any parameter applicable to the auxiliary boilers where, due to sampling or analytical limitations, a 60 minute sample is inappropriate, ~~a suitable sampling period should be employed, subject to approval by the Agency.~~ The value obtained therein shall not exceed the emission limit value.

*Reason for Decision:*

In the interests of providing clarity on the Recommendation.

Following discussion, the Directors decided to grant a licence, as modified, to SSE Generation Ireland Limited, Great Island Generating Station, Campile, New Ross, County Wexford, Register of Licence P0606-04, subject to the conditions as set out in the licence.