

Waste Water Discharge Authorisation (WWDA) Examination Report

Part 1

Inspector's Name	Christine Murphy
Date of examination	29 th June 2021
Agglomeration Name	Castlemartyr
Authorisation Reg No	D0134-01
Receiving Waterbody Name and WFD Code	Womanagh_020 IE_SW_19W011300
Final Decision Issue Date	25/07/2014

Part 2

An examination has been carried of the WWDA and relevant information. The following action is recommended:

	Tick one
No Further Action	
Amend the WWDA	
Review the WWDA	✓

The conclusion of the examination is as follows:

	Tick one
It is considered that the WWDA satisfies the environmental requirements of the WWDA 2007 regulations as amended.	
It is considered that the WWDA does not satisfy the environmental requirements of the WWDA 2007 regulations as amended.	✓

The reasons for this conclusion and recommendation are summarised as follows:

1. The licence was granted over 3 years ago.
2. Planning application is due to be submitted in 2021 for proposed development works associated with the licence.
3. The agglomeration is included in Irish Water's investment plan.
4. Non-compliance with completion of improvement works to the waste water treatment plant as set out in Schedule C: Specified Improvement Programme, of this licence, by 31/12/2019 and emission limit values as set out in Schedule A: Discharges and Discharge Monitoring.