

Ms Charlene Rooney, Abbvie Ireland NL.BV, Ballytivnan, Co. Sligo **Uisce Éireann**Bosca OP 6000
Baile Átha Cliath 1
Éire

Irish Water PO Box 6000 Dublin 1 Ireland

T: +353 1 89 25000 F: +353 1 89 25001 www.water.ie

Reg No: P1087-01

13/Apr/2023

Dear Ms Rooney,

I refer to our telephone correspondence dated 03/04/23 in relation to your proposed and requested amendment to the trade effluent emission limit values (ELV) set out in EPA Licence Reg. No. P1087-01. Uisce Éireann have assessed your proposal and are satisfied to support amendment of Schedule B.3 Emissions to Sewer as outlined below;

Schedule B.3 Emissions to Sewer

Emission Point Reference No.: SE1

Discharge Location: SE1 (Grid Reference (169925E, 337335N)

Volume of Trade effluent emitted: Maximum in any one day: 180 m³

Maximum in any hour: 12.7 m³

Parameter	Emission Limit Values	
Temperature	35°C (max)	
рН	6-9 pH Units	
	Concentration (mg/l)	Daily Load (Kg/day)
BOD 5 days with inhibition (Carbonaceous BOD)	377	61
COD - Cr	599	97
Suspended Solids	333	54

Stiúrthóirí / Directors: Tony Keohane (Chairman), Niall Gleeson (CEO), Christopher Banks, Fred Barry, Gerard Britchfield, Liz Joyce, Patricia King, Eileen Maher, Cathy Mannion, Michael Walsh

Oifig Chláraithe / Registered Office: Teach Colvill, 24–26 Sráid Thalbóid, Baile Átha Cliath 1, D01 NP86 / Colvill House, 24–26 Talbot Street, Dublin 1 D01 NP86 Is cuideachta ghníomhaíochta ainmnithe atá faoi theorainn scaireanna é Uisce Éireann / Irish Water is a designated activity company, limited by shares.

Uimhir Chláraithe in Éirinn / Registered in Ireland No.: 530363

Total Nitrogen (as N)	12	2
Chlorides	6000	18
Sulphates (as SO4)	400	-
Fats, Oils & Greases	50	-
Detergents (as MBAS)	20	-

If you have any further queries please do not hesitate to contact Uisce Éireann.

Yours sincerely

Kanen (m

DocuSigned by:

Wastewater Source Control and Licensing