

Headquarters
P.O. Box 3000
Johnstown Castle Estate
County Wexford
Ireland

TECHNICAL AMENDMENT A
TO
INDUSTRIAL EMISSIONS LICENCE

Licence Register Number:	P1087-01
Company Registration Number:	906838
Licensee:	AbbVie Ireland NL B.V.
Location of Installation:	Old Bundoran Road Ballytivnan Sligo

Reasons for the Decision

The Environmental Protection Agency is satisfied, on the basis of the information available, that subject to compliance with the conditions of Licence Reg. No. P1087-01 granted on 24 April 2020 as well as any amendments noted herein, any emissions from the activity will comply with and not contravene any of the requirements of Section 83(5) of the Environmental Protection Agency Act 1992 as amended.

A screening for Appropriate Assessment was undertaken to assess, in view of best scientific knowledge and the conservation objectives of the site, if the activity, individually or in combination with other plans or projects is likely to have a significant effect on any European Site. In this context, particular attention was paid to the European Site(s) at Cummeen Strand/Drumcliff Bay (Sligo Bay) SAC (Site Code 000627), Cummeen Strand SPA (Site Code 004035), Lough Gill SAC (Site Code 001976).

The activity is not directly connected with or necessary to the management of any European Site and the Agency considered, for the reasons set out below, that it can be excluded, on the basis of objective information, that the activity, individually or in combination with other plans or projects, will have a significant effect on any European Site and accordingly determined that an Appropriate Assessment of the activity was not required.

This determination is based on the following reasons:

- the installation is not located within any European site; and
- wastewater from the installation discharges to sewer and undergoes treatment at Sligo WWTP (licensed under WWDL D0014-01). Considering both the nature of the discharges from the installation and the capacity of the receiving WWTP it is considered that the changes will not indirectly have a significant effect on European Sites in the vicinity of the WWTP discharge to the Garavoge Estuary (IE_WE_470_0100).

Technical Amendment

In pursuance of the powers conferred on it by Section 96(1)(c) of the Environmental Protection Agency Act 1992 as amended, the Agency amends the licence, granted to AbbVie Ireland NL B.V., for an installation located at Old Bundoran Road, Ballytivnan, Co. Sligo.

Henceforth, the licence shall be read in conjunction with the amendments set out below.

This Technical Amendment is limited to the following Schedule:

Amendments

Amend Schedule B.3 Emissions to Sewer, of the existing licence to read as follows:

B.3 Emissions to Sewer

Emission Point Reference No:	SE1
Name of Sewer:	Uisce Éireann Sewer
Monitoring Location	Waste Water Tanks Building Flow meter SE1a (Grid Reference (169843E, 337621N)) Composite Sampler SE1b (Grid Reference (169845E, 337620N))
Discharge Location:	SE1 (Grid Reference (169925E, 337335N))
Volume to be emitted:	Maximum in any one day:: 180 m ³ Maximum rate per hour: 12.7 m ³

Parameter	Emission Limit Value	
Temperature	35 °C (max)	
pH	6 – 9	
	mg/l	kg/day
BOD	377	61
COD	599	97
Suspended Solids	333	54
Total Nitrogen	12	2
Chlorides	6000	18
Sulphates (as SO ₄)	400	-
Oils, Fats and Greases	50	-
Detergents (as MBAS)	20	-



This Technical Amendment shall be cited as Amendment A to the licence.

Sealed by the Seal of the Agency on this the 25th day of April 2024

PRESENT when the seal of the Agency was affixed hereto

Tara Gillen, Authorised Person

IED Technical Amendment P1087-01/A

