



MANHOLE NAME	FEATURE
SE 1	TIE IN TO EXISTING FOUL WATER NETWORK E: 718353.2785 N: 740309.1183
SE 2	TIE IN TO EXISTING FOUL WATER NETWORK E: 718426.2194 N: 740419.6558
SE 3	TIE IN TO EXISTING FOUL WATER NETWORK E: 718451.5696 N: 740623.1573
SE 4	TIE IN TO EXISTING FOUL WATER NETWORK E: 718441.4614 N: 740545.4173
SE 5	TIE IN TO EXISTING FOUL WATER NETWORK E: 718433.2045 N: 740212.5609
FR 1	FULL RETENTION, CLASS 1 HYDROCARBON INTERCEPTOR E: 718297.6507 N: 740632.5755
FR 2	FULL RETENTION, CLASS 2 HYDROCARBON INTERCEPTOR E: 718332.4371 N: 740480.7592
FR 3	FULL RETENTION, CLASS 1 HYDROCARBON INTERCEPTOR E: 718351.6386 N: 740316.4347
FR 4	FULL RETENTION, CLASS 2 HYDROCARBON INTERCEPTOR E: 718454.4203 N: 740174.5988

DRAWING IS PRODUCED USING THE
IRISH TRANSVERSE MERCATOR
GEOGRAPHIC COORDINATE SYSTEM

A0

LEGEND

SITE BOUNDARY

DATA CENTRE BUILDING

CAMPUS ROADS

NEWBURY 110KV SUB STATION

CAMPUS SECURITY FENCE

CAMPUS BOUNDARY FENCE

FUEL UNLOADING AREA

BUNDED AREA

CAMPUS FW NETWORK

EXISTING FW NETWORK

NOTE:
DRAWINGS ARE NOT TO BE SCALE
DRAWINGS ARE FOR THE PROPOSED EPA LICENSE
NOT FOR CONSTRUCTION

C06	REVISED EPA-ISSUE	LOB	PM	16.06.2025
C05	REVISED EPA-ISSUE	TN	PM	26.02.2025
C04	REVISED EPA-ISSUE	GN	PM	23.05.2024
C03	LICENSE REVISION	DM	PM	17.11.2023
C02	EPA-ISSUE	DM	PM	13.03.2023
C01	EPA-ISSUE	DM	PM	30.03.2022
P01	FOR COMMENT	DM	PM	22.03.2022
Rev	Description	Drawn	Checked	Date

Clifton Scannell Emerson
Associates Limited
Consulting Engineers,
3rd Floor The Heights,
Barnes Road, Parnall Road,
Donaghadee, Co. Dublin,
Ireland, A94 KW25

T: +353 1 288 5008
F: +353 1 283 3486
E: info@csea.ie
W: www.csea.ie

ADSIL

Client

Project

Drawn By

Checked By

Project Code

Originator

Zone

Phase

Level

Type

Role

Drawn No

DATA CENTRE CLONSHAUGH
BUSINESS & TECHNOLOGY PARK
FOUL WATER LAYOUT PLAN

GN

MARCH 2022

PM

1:1000 @ A0

21_123F - CSE - 00 - XX - DR - C - 1200

21_123

CSEA Job No.

S2

C06

FOR INFORMATION

EPA-LICENSE

OSI Licence No: EN 004242 © OSI/GOVERNMENT OF IRELAND - © CSEA 2022