

Amazon Data Services Ireland Limited

IE Licence Application

Attachment 4-4-1 Capacity Calculations

Reference:

Issue | 2 July 2025

This report takes into account the particular instructions and requirements of our client. It is not intended for and should not be relied upon by any third party and no responsibility is undertaken to any third party.

Job number 305131

Ove Arup & Partners Ireland Limited 50 Ringsend Road Dublin 4 D04 T6X0 Ireland arup.com

Attachment 4-4-1 Capacity Calculations



Document Verification

Project title	IE Licence Application
---------------	------------------------

Document title Attachment 4-4-1 Capacity Calculations

Job number 305131

Document ref File reference

Revision	Date	Filename			
		Description			
			Prepared by	Checked by	Approved by
		Name			
		Signature			
		Filename			
		Description			
			Prepared by	Checked by	Approved by
		Name			
		Signature			
		Filename			
		Description			
			Prepared by	Checked by	Approved by
			Prepared by	Спескей ву	Approved by
		Name			
		Signature			
I D		on with Document			

Attachment 4-4-1 Capacity Calculations

Contents

1. Attachment 4-4-1 Capacity Calculations

1

Attachment 4-4-1 Capacity Calculations

The relevant requirement for an Industrial Emissions (IE) Licence is outlined within the First Schedule of the EPA Act 1992. Activity 'Class 2.1 Combustion of fuels in installations with a total rated thermal input of 50 MW or more' specifically relates to this facility. For activity Class 1.1 of the Industrial Emissions Directive (IED) 2010/75/EU (as transposed into Irish law as Class 2.1 of the EPA Act 1992) there is no threshold at unit level i.e. the general aggregation rule applies which means that all combustion activities within an installation need to be considered in respect of the 'capacity' and the relevant threshold. If the total rated thermal input of all those combustion activities within the installation is 50 MW or more, then the whole installation falls under the scope of IE Licencing.

The Installation will include 14 no. 7.73 megawatt thermal (MW_{th}) critical emergency generators; 1 no. 2.50 MW_{th} house emergency generator; and 2 no. 0.57 MW_{th} fire sprinkler pumps.

The combined thermal input (total capacity) of the Installation is 111.9 MW_{th}, this exceeds the 50MW_{th} threshold of Class 2.1 First Schedule of the EPA Act 1992. The applicant is applying to the Environmental Protection Agency (EPA) for an Industrial Emissions (IE) Licence principally relating to the operation of emergency generators under Activity Class 2.1.